

**From:** [Beaudin, Lauren@Waterboards](mailto:Beaudin,Lauren@Waterboards)  
**To:** [Beaudin, Lauren@Waterboards](mailto:Beaudin,Lauren@Waterboards)  
**Subject:** FW: MCH Gauge  
**Date:** Wednesday, November 3, 2021 12:13:57 PM

---

**From:** Bill Hardwick <[billhlmwc@att.net](mailto:billhlmwc@att.net)>  
**Sent:** Wednesday, November 3, 2021 11:45 AM  
**To:** Ekdahl, Erik@Waterboards <[Erik.Ekdahl@waterboards.ca.gov](mailto:Erik.Ekdahl@waterboards.ca.gov)>; Sobeck, Eileen@Waterboards <[Eileen.Sobeck@Waterboards.ca.gov](mailto:Eileen.Sobeck@Waterboards.ca.gov)>  
**Cc:** Bartlett, Tina@Wildlife <[Tina.Bartlett@wildlife.ca.gov](mailto:Tina.Bartlett@wildlife.ca.gov)>; Roberts, Jason@Wildlife <[Jason.Roberts@wildlife.ca.gov](mailto:Jason.Roberts@wildlife.ca.gov)>; Louie, Stephen@Waterboards <[Stephen.Louie@Waterboards.ca.gov](mailto:Stephen.Louie@Waterboards.ca.gov)>; Williamson, Nicole@Waterboards <[Nicole.Williamson@waterboards.ca.gov](mailto:Nicole.Williamson@waterboards.ca.gov)>; Mitterhofer, Conny@Waterboards <[Conny.Mitterhofer@waterboards.ca.gov](mailto:Conny.Mitterhofer@waterboards.ca.gov)>; Dustin Cooper <[dcooper@minasianlaw.com](mailto:dcooper@minasianlaw.com)>  
**Subject:** Fw: MCH Gauge

EXTERNAL:

Good afternoon,

Just wanted to pass on the latest from DWR on gauge calibrations. Please find Lester Grade's email below.

Thanks,

Bill

Bill Hardwick  
General Manager  
Los Molinos Mutual Water Company  
25162 Josephine St., Los Molinos, Ca., 96055  
(530)-384-2737

----- Forwarded Message -----

**From:** Bill Hardwick <[lmmutual@att.net](mailto:lmmutual@att.net)>  
**To:** Bill Hardwick <[billhlmwc@att.net](mailto:billhlmwc@att.net)>  
**Sent:** Wednesday, November 3, 2021, 11:35:22 AM PDT  
**Subject:** Fw: MCH Gauge

Bill Hardwick  
General Manager  
Los Molinos Mutual Water Company  
25162 Josephine St., Los Molinos, Ca. 96055  
530-384-2737

----- Forwarded Message -----

**From:** Grade, Lester@DWR <[lester.grade@water.ca.gov](mailto:lester.grade@water.ca.gov)>  
**To:** Bill Hardwick <[lmmutual@att.net](mailto:lmmutual@att.net)>  
**Sent:** Wednesday, November 3, 2021, 10:05:54 AM PDT  
**Subject:** Re: MCH Gauge

Hi Bill,

The measured low for Mill Creek below Highway 99 was 184 CFS at a gage height of 5.79'.

The tech has made the shift table and sent it to CDEC to be uploaded. I will send you another email once I have confirmation that it was done.

Lester Grade  
Department of Water Resources  
Northern Region Office  
Surface Water Investigations Section  
2440 Main St  
Red Bluff Ca 96080  
Cell #530-949-0917

---

**From:** Bill Hardwick <[lmmutual@att.net](mailto:lmmutual@att.net)>  
**Sent:** Wednesday, November 3, 2021 09:28  
**To:** Grade, Lester@DWR <[Lester.Grade@water.ca.gov](mailto:Lester.Grade@water.ca.gov)>  
**Subject:** Re: MCH Gauge

Lester,

Any update?

Bill Hardwick  
General Manager  
Los Molinos Mutual Water Company  
25162 Josephine St., Los Molinos, Ca. 96055  
530-384-2737

On Monday, November 1, 2021, 10:54:23 AM PDT, Grade, Lester@DWR <[lester.grade@water.ca.gov](mailto:lester.grade@water.ca.gov)> wrote:

Bill,

Sorry for the delay on this. The tech's will be going out there tomorrow morning to get a new

measurement. They should have the shift put into CDEC by Wednesday.

Lester Grade  
Department of Water Resources  
Northern Region Office  
Surface Water Investigations Section  
2440 Main St  
Red Bluff Ca 96080  
Cell #530-949-0917

---

**From:** Bill Hardwick <[lmmutual@att.net](mailto:lmmutual@att.net)>  
**Sent:** Monday, November 1, 2021 08:12  
**To:** Grade, Lester@DWR <[Lester.Grade@water.ca.gov](mailto:Lester.Grade@water.ca.gov)>  
**Subject:** MCH Gauge

Hi Lester,

Have you had a chance to recalibrate the MCH gauge? There is quite a difference between the MLM and MCH gauges.

Thanks,

Bill

Bill Hardwick  
General Manager  
Los Molinos Mutual Water Company  
25162 Josephine St., Los Molinos, Ca. 96055  
530-384-2737