

STATE WATER RESOURCES CONTROL BOARD  
RESOLUTION NO. 85- 73

DENIAL OF A PETITION BY GOLETA SANITARY DISTRICT  
REQUESTING AN EXCEPTION TO THE SUSPENDED SOLIDS  
LIMITATION IN TABLE A OF THE WATER QUALITY CONTROL  
PLAN, OCEAN WATERS OF CALIFORNIA

WHEREAS:

1. The 1983 Water Quality Control Plan, Ocean Waters of California (Ocean Plan), under Chapter VI F, allows exceptions to be granted provided:
  - a. The exception will not compromise protection of ocean waters for beneficial uses, and
  - b. The public interest will be served.
2. The Goleta Sanitary District (District) petitioned the State Board for an exception to the Ocean Plan Table A suspended solids limitations. The District requested an effluent suspended solids limit of 90 mg/l.
3. The State Board finds, after review of the evidence submitted, that the District did not provide sufficient information to demonstrate that the exception requested will not compromise protection of ocean waters for beneficial uses.
4. The State Board also finds that the public interest will not be served by granting the District's petition.
5. The California Environmental Quality Act in Division 13 of the Public Resources Code, commencing with Section 21000, does not apply to projects rejected or disapproved by a public agency.

THEREFORE BE IT RESOLVED:

That the State Board denies the District's petition for an exception to the Ocean Plan Table A suspended solids limitations.

CERTIFICATION

The undersigned, Executive Director of the State Water Resources Control Board, does hereby certify that the foregoing is a full, true, and correct copy of a resolution duly and regularly adopted at a meeting of the State Water Resources Control Board held on September 19, 1985.

*Raymond Walsh*

Raymond Walsh  
Interim Executive Director