

**CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
CENTRAL COAST REGION
895 Aerovista Place, Suite 101
San Luis Obispo, California 93401**

MONITORING AND REPORTING PROGRAM NO. R3-2016-0044

For the

**CITY OF PACIFIC GROVE
PACIFIC GROVE LOCAL WATER PROJECT
MONTEREY COUNTY**

EFFLUENT MONITORING

Representative samples from the effluent shall be collected and analyzed according to the following schedule:

Constituent	Units	Sample Type	Minimum Sampling and Analysis Frequency
Daily Flow	gal/day	Metered	Continuous
Turbidity [†]	NTU	Metered	Continuous
Total Coliform	MPN/100 mL	Grab	Daily
pH	--	Grab	Daily
Settleable Solids	mL/L	Grab	Daily
BOD ₅	mg/L	Grab	Weekly
Suspended Solids	mg/L	Grab	Weekly
Ammonia (as N)	mg/L	Grab	Monthly
Priority Pollutants ^{††}		Grab	Annually

[†] Should the continuous turbidity meter and recorder fail, grab sampling at a minimum frequency of 1.2-hours may be substituted for a period of up to 24-hours.

^{††} Priority Pollutants are found in Appendix A to 40 CFR Part 423.

REPORTING

For all monitoring specified above, results shall be submitted quarterly by the 20th day of January, April, July, and October. The report shall also include a summary of any operational or equipment problems, reasons for any violations of waste discharge requirements, and corrective actions taken to eliminate violations.

Ordered By: _____
John M. Robertson, Executive Officer

Date: December 8, 2016 _____