

STATE OF CALIFORNIA  
 CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD  
 CENTRAL COAST REGION  
 895 Aerovista Place, Suite 101  
 San Luis Obispo, CA 93401

**MONITORING AND REPORTING PROGRAM NO. R3-2008-0017**  
 Waste Discharger Identification No. 3 420607119

For

**SAND CITY DESALINATION PLANT**  
**Monterey County**

This Monitoring and Reporting Program is issued pursuant to Water Code section 13267 and is incorporated by reference into Waste Discharge Requirements Order NO. R5-2008-0017. The Discharger named in this Order are subject to Section 13267 because they operate the facility. The monitoring and reporting set forth in this order is necessary to assure compliance with the Order and to protect waters of the state.

**EFFLUENT MONITORING**

Representative samples of the brine discharged to the injection well shall be collected and analyzed for the constituents and at the frequencies specified below:

Constituent	Units	Sample Type	Minimum Sampling and Analyzing Frequency
Flow Volume	gallons	metered	Daily
Max. Daily Flow	gpd	metered	Continually
Mean Daily Flow	gpd	calculated	-
Total Dissolved Solids	mg/L	measured	Monthly

**REPORTING**

Quarterly Reporting

Reports shall contain all effluent data collected and calculated, all analytical reports from a state-certified laboratory, and all observations made during the previous month. Reports are due by the 20<sup>th</sup> of the month following the quarter's end.

Ordered By \_\_\_\_\_  
 Executive Officer

\_\_\_\_\_  
 Date