



California Sportfishing Protection Alliance

"An Advocate for Fisheries, Habitat and Water Quality"

3536 Rainier Avenue, Stockton, CA 95204

T: 209-464-5067, F: 209-464-1028, E: deltakeep@me.com, W: www.calsport.org

20 April 2012

Mr. Ken Landau, Assistant Executive Officer
Ms. Diana Messina, Supervising WRCE
Mr. Jim Marshall, Sr. WRCE
Ms. Dania Jimmerson WRCE
Regional Water Quality Control Board
Central Valley Region
11020 Sun Center Drive, Suite 200
Rancho Cordova, CA 95670-6144

VIA: Electronic Submission
Hardcopy if Requested

RE: Renewal of Waste Discharge Requirements (NPDES No. CA0079103) for City of Modesto Wastewater Quality Control Facility, Stanislaus County

Dear Messrs. Landau, Marshall and Mesdames Messina and Jimmerson,

The California Sportfishing Protection Alliance (CSPA) has reviewed the proposed Waste Discharge Requirements (NPDES No. CA0079103) for City of Modesto Wastewater Quality Control Facility (Permit) and submits the following comments.

CSPA requests status as a designated party for this proceeding. CSPA is a 501(c)(3) public benefit conservation and research organization established in 1983 for the purpose of conserving, restoring, and enhancing the state's water quality and fishery resources and their aquatic ecosystems and associated riparian habitats. CSPA has actively promoted the protection of water quality and fisheries throughout California before state and federal agencies, the State Legislature and Congress and regularly participates in administrative and judicial proceedings on behalf of its members to protect, enhance, and restore California's degraded water quality and fisheries. CSPA members reside, boat, fish and recreate in and along waterways throughout the Central Valley, including Stanislaus County.

- A. The proposed Permit fails to discuss compliance with the California Environmental Quality Act (CEQA) for a significant expansion of the wastewater treatment plant and the allowance to increase wastewater discharge flows to surface waters.**

The proposed Permit, Finding No. E, simply states that the action to adopt an NPDES permit is exempt from CEQA. The proposed Permit discusses that the Discharger is undertaking a major project to expand the capacity of their tertiary treatment system which will result in an increased flow to surface waters. The Regional Board is a responsible agency for expansion of wastewater treatment systems that could impact waters of the state. Finding E should include a discussion of the wastewater treatment plant expansion and the resulting impacts to water quality identified in the CEQA document which must be prepared prior to allowing any such discharge.

B. The proposed Permit fails to contain mass-based effluent limits for Aluminum, Carbon Tetrachloride, Chlorine, Copper, Dibromochloromethane, Dichlorobromomethane, Iron, Manganese and Molybdenum as required by Federal Regulations 40 CFR 122.45(b).

Federal Regulation, 40 CFR 122.45 (b) requires that in the case of POTWs, permit Effluent Limitations, standards, or prohibitions shall be based on design flow.

Concentration is not a basis for design flow. Mass limitations are concentration multiplied by the design flow and therefore meet the regulatory requirement. Mass limits are critically important to assure that the facility is properly designed and capable of removing individual pollutants and to assure that the treatment facilities are not overloaded with the individual pollutant. The Regional Board's approach to priority pollutants is that treatment plants are designed to remove BOD, TSS and pathogens and that the removal of other priority pollutants is incidental; hence their removal of mass limitations from permits. This approach may have been generally successful prior to adoption of the National and California Toxics Rules which established stringent numerical limitations for priority pollutants. It is easy to recognize the failure of relying on conventional treatment plant design for addressing priority pollutants by the number of Time Schedule Orders and Cease and Desist Orders for noncompliant treatment systems regulated by the Central Valley Regional Board. This is also evidenced by the number of NTR and CTR noncompliant wastewater treatment plants in California's Central Valley. The design flow for priority pollutants is different for each individual pollutant and is different again from the conventional design flow for BOD and TSS. The treatment plant design flow for BOD and TSS removal is not the design flow rate for individual priority pollutants and toxic constituents such as ammonia and aluminum. A prime example of the requirements for individual pollutant removal is ammonia removal or nitrification; the design of activated sludge systems has been modified from simply being designed for BOD removal to achieve nitrification in many cases by providing extended aeration. This is likely why the proposed Permit contains mass limits for ammonia. Failure to include mass limits and design flows for priority pollutants maintains the incidental nature of past compliance and will not reliably achieve compliance with water quality standards for priority pollutants. For Aluminum, Carbon Tetrachloride, Chlorine, Copper, Dibromochloromethane, Dichlorobromomethane, Iron, Manganese and Molybdenum

the proposed Permit does not specify the design flow and does therefore not comply with the requirements of 40 CFR 122.45(b).

C. Effluent Limitations for Manganese, Iron and Aluminum are improperly regulated as an annual average contrary to Federal Regulations 40 CFR 122.45 (d)(2) and common sense.

Federal Regulation 40 CFR 122.45 (d)(2) requires that permit for POTWs establish Effluent Limitations as average weekly and average monthly unless impracticable. The proposed Permit establishes Effluent Limitations for aluminum, iron and manganese as an annual average contrary to the cited Federal Regulation. Establishing the Effluent Limitations for aluminum, iron and manganese in accordance with the Federal Regulation is not impracticable; to the contrary the Central Valley Regional Board has a long history of having done so. The Regional Board fails to recognize that the impacts of these pollutants, in effecting the taste and odor of water and discoloring plumbing fixtures and laundry, occurs instantaneously not over a period of a year. Proof of impracticability is properly a steep slope and the Regional Board has not presented any evidence that properly and legally limiting aluminum, iron and manganese is impracticable.

D. The proposed Permit does not contain enforceable Effluent Limitations for chronic toxicity and therefore does not comply with the Basin Plan, Federal Regulations, at 40 CFR 122.44 (d)(1)(i) and the *Policy for Implementation of Toxics Standards for Inland Surface Waters, Enclosed Bays, and Estuaries of California* (SIP).

Proposed Permit, State Implementation Policy states that: “On March 2, 2000, the State Water Board adopted the *Policy for Implementation of Toxics Standards for Inland Surface Waters, Enclosed Bays, and Estuaries of California* (State Implementation Policy or SIP). The SIP became effective on April 28, 2000 with respect to the priority pollutant criteria promulgated for California by the USEPA through the NTR and to the priority pollutant objectives established by the Regional Water Board in the Basin Plan. The SIP became effective on May 18, 2000 with respect to the priority pollutant criteria promulgated by the USEPA through the CTR. The State Water Board adopted amendments to the SIP on February 24, 2005 that became effective on July 13, 2005. The SIP establishes implementation provisions for priority pollutant criteria and objectives and provisions for chronic toxicity control. Requirements of this Order implement the SIP.”

The SIP, Section 4, Toxicity Control Provisions, Water Quality-Based Toxicity Control, states that: “A chronic toxicity effluent limitation is required in permits for all dischargers that will cause, have a reasonable potential to cause, or contribute to chronic toxicity in receiving waters.” The SIP is a state *Policy* and CWC Sections 13146 and 13247 require that the Board in carrying out activities which affect water quality shall comply with state policy for water quality control

unless otherwise directed by statute, in which case they shall indicate to the State Board in writing their authority for not complying with such policy.

Federal regulations, at 40 CFR 122.44 (d)(1)(i), require that limitations must control all pollutants or pollutant parameters which the Director determines are or may be discharged at a level which will cause, or contribute to an excursion above any State water quality standard, including state narrative criteria for water quality. There has been no argument that domestic sewage contains toxic substances and presents a reasonable potential to cause toxicity if not properly treated and discharged. The Water Quality Control Plan for the Sacramento/ San Joaquin River Basins (Basin Plan), Water Quality Objectives (Page III-8.00) for Toxicity is a narrative criteria which states that all waters shall be maintained free of toxic substances in concentrations that produce detrimental physiological responses in human, plant, animal, or aquatic life. The Proposed Permit contains a narrative Effluent Limitation prohibiting the discharge of chronically toxic substances: however a *Compliance Determination* has been added to the proposed Permit, page 25, 26 and 38: Compliance with the accelerated monitoring and TRE/TIE provisions of Provision VI.C.2.a shall constitute compliance with effluent limitations. The *Compliance Determination* nullifies the Effluent Limitation and makes toxic discharges unenforceable.

The Basin Plan narrative Toxicity Objective states that: “All waters shall be maintained free of toxic substances in concentrations that produce detrimental physiological responses in human, plant, or aquatic life. This objective applies regardless of whether the toxicity is caused by a single substance or the interactive effect of multiple substances. Compliance with this objective will be determined by analyses of indicator organisms, species diversity, population density, growth anomalies, and biotoxicity tests of appropriate duration or other methods as specified by the Regional Board.”

According to the Basin Plan toxicity sampling is required to determine compliance with the requirement that all waters be maintained free of toxic substances. Sampling does not equate with or ensure that waters are free of toxic substances. The Tentative Permit requires the Discharger to conduct an investigation of the possible sources of toxicity if a threshold is exceeded. This language is not a limitation and essentially eviscerates the Regional Board’s authority, and the authority granted to third parties under the Clean Water Act, to find the Discharger in violation for discharging chronically toxic constituents. An enforceable effluent limitation for chronic toxicity must be included in the Order.

E. The proposed Permit contains Compliance Schedules for electrical conductivity (EC) that exceed the maximum ten years allowed under the Basin Plan and fails to allocate a maximum allowable load as required for 303d listed pollutants.

The Water Quality Control Plan (Basin Plan), page IV-17-00, for the Sacramento and San Joaquin Rivers allows for maximum compliance schedules to be included in NPDES permits where it is infeasible to achieve immediate compliance. NPDES permit No. R5-2008-0059 contained a compliance schedule for achieving compliance with effluent limitations for electrical conductivity (EC). Therefore, the maximum allowable compliance period of ten years would expire in 2018. The proposed Permit, page 33, allows a continuing compliance schedule until 2022 or 2026, clearly beyond 2018 as would be allowed under the Basin Plan.

Proposed Permit, page 7, Finding H, states that: “*Pollutants identified on the California 303(d) List as impairing the San Joaquin River include boron, selenium, electrical conductivity, chlorpyrifos, diazinon, DDT, Group A pesticides, mercury, and unknown toxicity.*” The Basin Plan, page IV-15.00, contains *The Water Quality Limited Segment Policy* which states that: “Additional treatment beyond minimum federal requirements will be imposed on dischargers to water Quality Limited Segments. Dischargers will be assigned or allocated a maximum allowable load of critical pollutants so that water quality objectives can be achieved in the segment.”

The proposed Permit does not comply with the Basin Plan requirement for maximum allowable compliance schedules. The proposed Permit fails to address the 303d listing requirements for EC of requiring treatment beyond minimum federal requirements and also fails to allocate a maximum allowable load. The proposed Permit contains the hollow Finding cited above regarding 303d listings but fails to implement the associated requirements for treatment and allocation of a maximum loading rate for which a TMDL would be required.

F. The proposed Permit fails to assess compliance and require compliance with and the Receiving Water Limitation for Toxicity, which is based on the Basin Plan narrative toxicity water quality objective.

The proposed Permit contains a Receiving Water Limitation which requires that the wastewater discharge not cause: “Toxic substances to be present, individually or in combination, in concentrations that produce detrimental physiological responses in human, plant, animal, or aquatic life.” An identical Receiving Water Limitation is contained in the existing NPDES permit for Modesto.

Threatened violation:

The increasing production and use of pharmaceuticals and personal care products (PPCPs) – some of which may be endocrine disrupting compounds (EDCs) – have led to a growing concern about the occurrence of these compounds in the environment. Recent studies have reported the occurrence worldwide of EDCs, PPCPs, and other organic wastewater contaminants (OWCs) – collectively referred to as “constituents of emerging

concern” (CECs) or “emerging constituents” (ECs) – in wastewater treatment plant (WWTP) effluents, surface waters used as drinking water supplies, and in some cases, finished drinking waters. Of the 126 samples analyzed for the project, one sample (American River at Fairbairn drinking water treatment plant [DWTP] intake collected in April 2008) had no detectable levels of any EDCs, PPCPs, or OWCs. All other samples had one or more analytes detected at or above the corresponding MRLs. The five most frequently detected PPCPs were caffeine, carbamazepine, primidone, sulfamethoxazole, and tris(2-chloroethyl) phosphate (TCEP). At the sample sites upstream of WWTP discharges in all three watersheds, the concentrations of selected PPCPs, except for caffeine, were low (i.e., ≤ 13 ng/L), pointing to WWTP discharges as the main source of most PPCPs and OWCs in the environment. (Source, Fate, and Transport of Endocrine disruptors, Pharmaceuticals, and Personal Care Products in Drinking Water Sources in California, National Water Research Institute Fountain Valley, California, May 2010)

Over the last 10 years, reports of feminized wildlife have fueled chilling headlines. Most of these reports have focused on the many ways that estrogen in sewage effluent can distort normal male development. Now a new study reveals one way that the hormone pollutant can affect females: Too much estrogen causes subtle changes in female fish's courting behavior, which could alter a population's genetic makeup (Environ. Sci. Technol., DOI: 10.1021/es101185b).

Increase in intersex fish downstream from WWTP possibly associated with endocrine-active contaminants. (Boulder Colorado, Colorado University, 2008)

Skewed sex ratio downstream from WWTP possibly associated with endocrine-active contaminants. (Boulder Colorado, Colorado University, 2006)

Fluoxetine (FLX), Sertraline (SER) and their degradates NFLX, and NSER were the primary antidepressants in brain tissue samples. Little or no venlafaxine (VEN), the dominant antidepressant in both water and bed sediment, was present. Degradates were measured at higher concentrations in brain samples than parent compounds. (Boulder Creek, Colorado & Fourmile Creek, Iowa, the College of Wooster, 2010)

SAR sites (with WWTP or urban runoff influent) males had significantly lower Testosterone (T) than the reference site males. Males from SAR sites had significantly higher 17 β -estradiol (E2) than reference site. Females from SAR sites had significantly lower E2 than the reference site females. (USGS, Santa Ana River (SAR) SAR sites, 2009)

“Several recent studies have documented endocrine disruption in Delta fish. One of the biomarkers of EDCs is intersex fish, fish with both male and female reproductive organs.

A recent histopathological evaluation of delta smelt for the Pelagic Organism Decline found 9 of 144 maturing delta smelt (6%) collected in the fall were intersex males. This study provides evidence that delta smelt are being exposed to EDCs. Brander and Cherr (2008) observed choriogenin induction in male silversides from Suisun Marsh. Riordan and Adam (2008) reported endocrine disruption in male fathead minnows following in-situ exposures below the Modesto Treatment Plant. Lavado, et al. (in press) conducted studies in 2006 and 2007 to evaluate the occurrence and potential sources of EDCs in Central Valley waterways. In their study, estrogenic activity was repeatedly observed at 6 of 16 locations in the Bay-Delta watershed, including in water from the Lower Napa River and Lower Sacramento River in the Delta. Further studies are needed to identify the compounds responsible for the observed estrogenic activity and their sources.” (Alameda County Water District, Alameda County Flood Control and Water Conservation District, Zone 7, Metropolitan Water District of Southern California, San Luis & Delta-Mendota Water Authority, Santa Clara Valley Water District, State Water Contractors, June 1, 2010)

A recent study by the Toxic Substances Hydrology Program of the U.S. Geological Survey (USGS) shows that a broad range of chemicals found in residential, industrial, and agricultural wastewaters commonly occurs in mixtures at low concentrations downstream from areas of intense urbanization and animal production. The chemicals include human and veterinary drugs (including antibiotics), natural and synthetic hormones, detergent metabolites, plasticizers, insecticides, and fire retardants. One or more of these chemicals were found in 80 percent of the streams sampled. Half of the streams contained 7 or more of these chemicals, and about one-third of the streams contained 10 or more of these chemicals. This study is the first national-scale examination of these organic wastewater contaminants in streams and supports the USGS mission to assess the quantity and quality of the Nation's water resources. A more complete analysis of these and other emerging water-quality issues is ongoing. Knowledge of the potential human and environmental health effects of these 95 chemicals is highly varied; drinking-water standards or other human or ecological health criteria have been established for 14. Measured concentrations rarely exceeded any of the standards or criteria. Thirty-three are known or suspected to be hormonally active; 46 are pharmaceutically active. Little is known about the potential health effects to humans or aquatic organisms exposed to the low levels of most of these chemicals or the mixtures commonly found in this study. ("Pharmaceuticals, hormones, and other organic wastewater contaminants in U.S. streams, 1999-2000: A national reconnaissance," an article published in the March 15, 2002 issue of *Environmental Science & Technology*, v. 36, no. 6, pages 1202-1211. Data are presented in a companion USGS report, "Water-quality data for pharmaceuticals, hormones, and other organic wastewater contaminants

in U.S. streams, 1999-2000" (USGS Open-File Report 02-94). These and other reports, data, and maps can be accessed on the Internet at <http://toxics.usgs.gov>.)

PPCPs are found where people or animals are treated with drugs and people use personal care products. PPCPs are found in any water body influenced by raw or treated sewage, including rivers, streams, ground water, coastal marine environments, and many drinking water sources. PPCPs have been identified in most places sampled. The U.S. Geological Survey (USGS) implemented a national reconnaissance to provide baseline information on the environmental occurrence of PPCPs in water resources. You can find more information about this project from the USGS's [What's in Our Wastewaters and Where Does it Go?](#) site. PPCPs in the environment are frequently found in aquatic environments because PPCPs dissolve easily and don't evaporate at normal temperature and pressures. Practices such as the use of sewage sludge ("biosolids") and reclaimed water for irrigation brings PPCPs into contact with the soil.
(<http://www.epa.gov/ppcp/faq.html#ifthereareindeed>)

From the recent scientific investigations and literature it is reasonable to conclude that "constituents of emerging concern" (CECs) are present in the wastewater discharge from the Modesto wastewater treatment plant. It is also reasonable to conclude that the wastewater discharge contains CECs in concentrations that at a minimum threaten to violate the Receiving Water Limitation for toxicity which prohibits toxic substances to be present in concentrations that produce detrimental physiological responses in human or aquatic life. The proposed Permit is silent with regard to CECs. Monitoring for CECs in the wastewater discharge, in the receiving stream or in agricultural diversions taken from within the proposed mixing zones is not required in the proposed Permit. It is undoubted that the Regional Board's response will be that the individual chemical pollutants do not have promulgated water quality standards and monitoring for CECs would therefore be unproductive. However, the Regional Board has an obligation to require an investigation of the potential violation of the Receiving Water Limitation for Toxicity. The Discharger is also required to assess compliance with all limitations and report any instances of non-compliance with limitations, including Receiving Water Limitations. The Regional Board is also, by 40 CFR 122.44, required to develop Effluent Limitations if the discharge presents a reasonable potential to exceed a water quality standard, including the narrative toxicity objective.

US EPA has compiled a database; *Treating Contaminants of Emerging Concern A Literature Review Database* (August 2010). Local wastewater treatment system design Engineers, such as Dr. Robert Emerick, have also been testing treatment system capabilities for removing CECs. There appear to be treatment technologies that are capable of removing significant levels of CECs.

At a minimum, the proposed Permit should include a requirement for a study of the presence of CECs in the wastewater discharge, the receiving stream and in agricultural intakes within the proposed mixing zone and the effectiveness of different treatment technologies to remove CECs. The report should be made available to the public. At a time when the proposed Permit will likely require advanced treatment systems to be designed and constructed; investigating the technologies that are capable of removing CECs would make sense economically and environmentally.

G. The proposed Permit contains an allowance for a mixing zone that does not comply with the requirements of Federal Regulation 40 CFR Section 131.12 (a)(1) and the Policy for Implementation of Toxics Standards for Inland Surface Waters, Enclosed Bays, and Estuaries of California (SIP) or the Basin Plan.

“A mixing zone is an area where an effluent discharge undergoes initial dilution and is extended to cover the secondary mixing in the ambient waterbody. A mixing zone is an allocated impact zone where water quality criteria can be exceeded as long as acutely toxic conditions are prevented” according to EPA’s *Technical Support Document for Water Quality-based Toxics Control* (TSD) (USEPA, 1991), (Water quality criteria must be met at the edge of a mixing zone.) Mixing zones are regions within public waters adjacent to point source discharges where pollutants are diluted and dispersed at concentrations that routinely exceed human health and aquatic life water quality standards (the maximum levels of pollutants that can be tolerated without endangering people, aquatic life, and wildlife.) Mixing zone policies allow a discharger’s point of compliance with state and federal water quality standards to be moved from the “end of the pipe” to the outer boundaries of a dilution zone. The CWA was adopted to minimize and eventually eliminate the release of pollutants into public waters because fish were dying and people were getting sick. The CWA requires water quality standards (WQS) be met in all waters to prohibit concentrations of pollutants at levels assumed to cause harm. Since WQS criteria are routinely exceeded in mixing zones it is likely that in some locations harm is occurring. The general public is rarely aware that local waters are being degraded within these mixing zones, the location of mixing zones within a waterbody, the nature and quantities of pollutants being diluted, the effects the pollutants might be having on human health or aquatic life, or the uses that may be harmed or eliminated by the discharge. Standing waist deep at a favorite fishing hole, a fisherman has no idea that he is in the middle of a mixing zone for pathogens for a sewage discharger that has not been required to adequately treat their waste.

In 1972, backed by overwhelming public support, Congress overrode President Nixon’s veto and passed the Clean Water Act. Under the CWA, states are required to classify surface waters by uses – the beneficial purposes provided by the waterbody. For example, a waterbody may be designated as a drinking water source, or for supporting the growth and propagation of aquatic life, or for allowing contact recreation, or as a water source for industrial activities, or all of the

above. States must then adopt criteria – numeric and narrative limits on pollution, sufficient to protect the uses assigned to the waterbody. Uses + Criteria = Water Quality Standards (WQS). WQS are regulations adopted by each state to protect the waters under their jurisdiction. If a waterbody is classified for more than one use, the applicable WQS are the criteria that would protect the most sensitive use.

All wastewater dischargers to surface waters must apply for and receive a permit to discharge pollutants under the National Pollutant Discharge Elimination System (NPDES.) Every NPDES permit is required to list every pollutant the discharger anticipates will be released, and establish effluent limits for these pollutants to ensure the discharger will achieve WQS. NPDES permits also delineate relevant control measures, waste management procedures, and monitoring and reporting schedules.

It is during the process of assigning effluent limits in NPDES permits that variances such as mixing zones alter the permit limits for pollutants by multiplying the scientifically derived water quality criteria by dilution factors. The question of whether mixing zones are legal has never been argued in federal court.

Mixing zones are never mentioned or sanctioned in the CWA. To the contrary, the CWA appears to speak against such a notion:

“whenever...the discharges of pollutants from a point source...would interfere with the attainment or maintenance of that water quality...which shall assure protection of public health, public water supplies, agricultural and industrial uses, and the protection and propagation of a balanced population of shellfish, fish and wildlife, and allow recreational activities in and on the water, effluent limitations...shall be established which can reasonably be expected to contribute to the attainment or maintenance of such water quality.”

A plain reading of the *above paragraph calls for the application of effluent limitations whenever necessary to assure that WQS will be met in all waters.* Despite the language of the Clean Water Act; US EPA adopted 40 CFR 131.13, General policies, that allows States to, at their discretion, include in their State standards, policies generally affecting their application and implementation, such as mixing zones, low flows and variances. According to EPA, (EPA, Policy and Guidance on Mixing Zones, 63 Fed Reg. 36,788 (July 7, 1998)) as long as mixing zones do not eliminate beneficial uses in the whole waterbody, they do not violate federal regulation or law. California has mixing zone policies included in individual Water Quality Control Plans (Basin Plans) and the *Policy for Implementation of Toxics Standards for Inland Surface Waters, Enclosed Bays, and Estuaries of California* (2005) permitting pollutants to be diluted before being measured for compliance with the state’s WQS.

Federal Antidegradation regulations at 40 CFR 131.12 requires that states protect waters at their present level of quality and that all beneficial uses remain protected. The corresponding State Antidegradation Policy, Resolution 68-16, requires that any degradation of water quality not unreasonably affect present and anticipated beneficial uses. Resolution 68-16 further requires that: “Any activity which produces or may produce or increase volume or concentration of waste and which discharges or proposes to discharge to existing high quality waters will be required to meet waste discharge requirements which will result in the best practicable treatment or control of the discharge necessary to assure that (a) a pollution or nuisance will not occur and (b) the highest water quality consistent with the maximum benefit to the people of the State will be maintained.”

- Pollution is defined in the California Water Code as an alteration of water quality to a degree which unreasonably affects beneficial uses. In California, Water Quality Control Plans (Basin Plans) contain water quality standards and objectives which are necessary to protect beneficial uses. The Basin Plan for California’s Central Valley Regional Water Board states that: “According to Section 13050 of the California Water Code, Basin Plans consist of a designation or establishment for the waters within a specified area of beneficial uses to be protected, water quality objectives to protect those uses, and a program of implementation needed for achieving the objectives. State law also requires that Basin Plans conform to the policies set forth in the Water Code beginning with Section 13000 and any state policy for water quality control. Since beneficial uses, together with their corresponding water quality objectives, can be defined per federal regulations as water quality standards, the Basin Plans are regulatory references for meeting the state and federal requirements for water quality control (40 CFR 131.20).”
- Nuisance is defined in the California Water Code as anything which is injurious to health, indecent, offensive or an obstruction of the free use of property which affects an entire community and occurs as a result of the treatment or disposal of waste.

The Antidegradation Policy (Resolution 68-16) allows water quality to be lowered as long as beneficial uses are protected (pollution or nuisance will not occur), best practicable treatment and control (BPTC) of the discharge is provided, and the degradation is in the best interest of the people of California. Water quality objectives were developed as the maximum concentration of a pollutant necessary to protect beneficial uses and levels above this concentration would be considered pollution. The Antidegradation Policy does not allow water quality standards and objectives to be exceeded. Mixing zone are regions within public waters adjacent to point source discharges where pollutants are diluted and dispersed at concentrations that routinely exceed water quality standards.

The Antidegradation Policy (Resolution 68-16) requires that best practicable treatment or control (BPTC) of the discharge be provided. Mixing zones have been allowed in lieu of treatment to meet water quality standards at the end-of-the-pipe prior to discharge. To comply with the Antidegradation Policy, the trade of receiving water beneficial uses for lower utility rates must be in the best interest of the people of the state and must also pass the test that the Discharger is providing BPTC. By routinely permitting excessive levels of pollutants to be legally discharged, mixing zones act as an economic disincentive to Dischargers who might otherwise have to design and implement better treatment mechanisms. Although the use of mixing zones may lead to individual, short-term cost savings for the discharger, significant long-term health and economic costs may be placed on the rest of society. An assessment of BPTC, and therefore compliance with the Antidegradation Policy, must assess whether treatment of the wastestream can be accomplished, is feasible, and not simply the additional costs of compliance with water quality standards. A BPTC case can be made for the benefits of prohibiting mixing zones and requiring technologies that provide superior waste treatment and reuse of the wastestream.

EPA's Water Quality Standards Handbook states that: "It is not always necessary to meet all water quality criteria within the discharge pipe to protect the integrity of the waterbody as a whole." The primary mixing area is commonly referred to as the zone of initial dilution, or ZID. Within the ZID acute aquatic life criteria are exceeded. To satisfy the CWA prohibition against the discharge of toxic pollutants in toxic amounts, regulators assume that if the ZID is small, significant numbers of aquatic organisms will not be present in the ZID long enough to encounter acutely toxic conditions. EPA recommends that a ZID not be located in an area populated by non-motile or sessile organisms, which presumably would be unable to leave the primary mixing area in time to avoid serious contamination.

Determining the impacts and risks to an ecosystem from mixing pollutants with receiving waters at levels that exceed WQS is extremely complex. The range of effects pollutants have on different organisms and the influence those organisms have on each other further compromises the ability of regulators to assess or ensure "acceptable" short and long-term impacts from the use of mixing zones. Few if any mixing zones are examined prior to the onset of discharging for the potential effects on impacted biota (as opposed to the physical and chemical fate of pollutants in the water column). Biological modeling is especially challenging – while severely toxic discharges may produce immediately observable effects, long-term impacts to the ecosystem can be far more difficult to ascertain. The effects of a mixing zone can be insidious; impacts to species diversity and abundance may be impossible to detect until it is too late for reversal or mitigation.

The *CALIFORNIA CONSTITUTION, ARTICLE 10, WATER, SEC. 2* states that: "It is hereby declared that because of the conditions prevailing in this State the general welfare requires that the water resources of the State be put to beneficial use to the fullest extent of which they are

capable, and that the waste or unreasonable use or unreasonable method of use of water be prevented, and that the conservation of such waters is to be exercised with a view to the reasonable and beneficial use thereof in the interest of the people and for the public welfare. The right to water or to the use or flow of water in or from any natural stream or water course in this State is and shall be limited to such water as shall be reasonably required for the beneficial use to be served, and such right does not and shall not extend to the waste or unreasonable use or unreasonable method of use or unreasonable method of diversion of water. Riparian rights in a stream or water course attach to, but to no more than so much of the flow thereof as may be required or used consistently with this section, for the purposes for which such lands are, or may be made adaptable, in view of such reasonable and beneficial uses; provided, however, that nothing herein contained shall be construed as depriving any riparian owner of the reasonable use of water of the stream to which the owner's land is riparian under reasonable methods of diversion and use, or as depriving any appropriator of water to which the appropriator is lawfully entitled. This section shall be self-executing, and the Legislature may also enact laws in the furtherance of the policy in this section contained.” The granting of a mixing zone is an unreasonable use of water when proper treatment of the wastestream can be accomplished to meet end-of-pipe limitations. Also contrary to the California Constitution, a mixing zone does not serve the beneficial use; to the contrary, beneficial uses are degraded within the mixing zone.

The Central Valley Regional Water Quality Control Board’s Basin Plan, page IV-16.00, requires the Regional Board use EPA’s *Technical Support Document for Water Quality Based Toxics Control (TSD)* in assessing mixing zones. The TSD, page 70, defines a first stage of mixing, close to the point of discharge, where complete mixing is determined by the momentum and buoyancy of the discharge. The second stage is defined by the TSD where the initial momentum and buoyancy of the discharge are diminished and waste is mixed by ambient turbulence. The TSD goes on to state that in large rivers this second stage mixing may extend for miles. The TSD, Section 4.4, requires that if complete mix does not occur in a short distance mixing zone monitoring and modeling must be undertaken.

The State’s *Policy for Implementation of Toxics Standards for Inland Surface Waters, Enclosed Bays and Estuaries of California (SIP)*, Section 1.4.2.2, contains requirements for a mixing zone study which must be analyzed before a mixing zone is allowed for a wastewater discharge. Properly adopted state Policy requirements are not optional. The proposed Effluent Limitations in the proposed Permit are not supported by the scientific investigation that is required by the SIP and the Basin Plan.

SIP Section 1.4.2.2 requires that a mixing zone shall not:

1. Compromise the integrity of the entire waterbody.
2. Cause acutely toxic conditions to aquatic life.
3. Restrict the passage of aquatic life.
4. Adversely impact biologically sensitive habitats.

5. Produce undesirable aquatic life.
6. Result in floating debris.
7. Produce objectionable color, odor, taste or turbidity.
8. Cause objectionable bottom deposits.
9. Cause Nuisance.
10. Dominate the receiving water body or overlap a different mixing zone.
11. Be allowed at or near any drinking water intake.

The proposed Permit's states that:

“The Discharger’s mixing zone study only evaluated mixing to a point 200 meters downstream of the discharge. Therefore, the point of complete mixing was not determined, and although a mixing zone was allowed in the previous permit, the edge of mixing zone was not defined. The State Water Board found in a precedential water quality order (WQ 2009-0003 for the City of Tracy Wastewater Treatment Plant) that it is necessary to define the edge of all mixing zones, including mixing zones for long-term criteria where any impacts are expected to occur far downstream after complete mixing. This Order carries forward the mixing zone and dilution credits for human health carcinogen criteria from the previous permit, but requires the Discharger submit a study that demonstrates the edge of the mixing zones.”

A very clear unaddressed requirement (SIP Section 1.4.2.2) for mixing zones is that the point(s) in the receiving stream where the applicable criteria must be met shall be specified in the proposed Permit. The “edge of the mixing zone” has not been defined. Granting of a mixing zone should only be allowed following the mixing zone scientific investigation ; here the Regional Board puts the cart before the horse and allows a mixing zone without a complete investigation of the impacts.

Federal regulation 40 CFR Section 131.12 (a)(1) the Antidegradation Policy requires that: “Existing instream water uses and the level of water quality necessary to protect the existing uses shall be maintained and protected.” The Central Valley Regional Board routinely grants mixing zones above the drinking water maximum contaminant level (MCL) for human health criteria despite that municipal and domestic supply is a designated beneficial use of the receiving stream. The designated beneficial use of drinking water is not protected within the reach of the stream, which is often established as some unknown length, contrary to 40 CFR 131.12.

Few mixing zones are adequately evaluated to determine whether the modeling exercise was in fact relevant or accurate, or monitored over time to assess the impacts of the mixing zone on the aquatic environment. The sampling of receiving waters often consists of analyzing one or two points where the mixing zone boundary is supposed to be – finding no pollution at the mixing

zone boundary is often considered proof that mixing has been “successful” when in fact the sampling protocol might have missed the plume altogether.

H. The proposed Permit establishes Effluent Limitations for metals based on the hardness of the effluent and the downstream hardness as opposed to the ambient instream receiving water hardness and fails to use the mandated equations as required by Federal Regulations, the California Toxics Rule (CTR, 40 CFR 131.38(c)(4)).

The proposed Permit, page F-31, states that: *“The secondary effluent hardness ranged from 136 mg/L to 327 mg/L, based on 37 samples from October 2006 to March 2011. The upstream receiving water hardness varied from 48 mg/L to 450 mg/L, based on 83 samples from November 2006 to January 2011. Under the effluent dominated condition, the reasonable worst-case downstream ambient hardness is 128 mg/L. As demonstrated in the example shown in Table F-4, below, using this hardness to calculate the ECA for all Concave Down Metals will result in WQBELs that are protective under all flow conditions, from the effluent dominated condition to the high flow condition.”*

The Regional Board failed to use the lowest observed, most protective, in stream ambient hardness.

Introduction

Several toxic metals are currently regulated in the California Toxics Rule (CTR) based on the hardness of the water column. This regulation is based on the fact that these metals exhibit greater toxicity to aquatic life in lower hardness waters. To reflect the hardness/toxicity relationship, US EPA developed an equation for metals limitations using hardness as a variable. Use of the CTR equation with the lowest observed hardness will result in the most protective limitation for hardness dependant toxic metals. In most instances, the upstream surface water hardness is lower than the effluent hardness. Hence, US EPA in writing the CTR (40 CFR 131.38(c)(4) stated that: *“For purposes of calculating freshwater aquatic life criteria for metals from the equations in paragraph (b)(2) of this section, for waters with a hardness of 400 mg/l or less as calcium carbonate, the actual ambient hardness of the surface water shall be used in those equations.”* Clearly, by stating that the ambient hardness of the surface water shall be used in the equations to develop metals limitations; the CTR prohibits the use of the effluent hardness.

Confirming that US EPA requires use of the upstream (ambient) hardness the Federal Register, Volume 65, No. 97/Thursday, May 18th 2000 (31692), adopting the California Toxics Rule states that: *“If it appears that an effluent causes hardness to be inconsistent with alkalinity and/or pH the intended level of protection will usually be maintained or exceeded if either (1) data are available to demonstrate that alkalinity and/or pH do not affect the toxicity of the metal, or (2)*

the hardness used in the hardness equation is the hardness of upstream water that does not include the effluent.”

In their biological opinion of the CTR the US Fish and Wildlife Service (Service) and the National Marine Fisheries Service (NMFS) concluded that: *“The CTR should clearly state that to obtain a site hardness value, samples should be collected upstream of the effluent source(s).”*

Following adoption of the CTR, a local consulting engineer, Dr. Robert Emerick, worrying whether his newly designed and constructed treatment plant at Lincoln would be able to comply with stringent metals limitations developed a technical paper evaluating the metal toxicity/hardness relationship. The “Emerick” paper concluded that hardness values other than the most restrictive surface water values could be used with modified equations to establish less restrictive metals limitations. The “Emerick” paper concluded that the metals limitations could be less restrictive while protecting aquatic life and the method eliminated the development of overly protective limitations.

Further reading of the Service’s and NMFS biological however shows that the lower limits obtained using the lowest observed hardness were not “overly protective: *“The CTR should clearly state that to obtain a site hardness value, samples should be collected upstream of the effluent source(s). Clearly stating this requirement in the CTR would avoid the computation of greater-than-intended site criteria in cases where samples were collected downstream of effluents that raise ambient hardness, but not other important water qualities that affect metal toxicity (e.g., pH, alkalinity, dissolved organic carbon, calcium, sodium, chloride, etc.). Clearly, it is inappropriate to use downstream site water quality variables for input into criteria formulas because they may be greatly altered by the effluent under regulation.”*

Using the latest available science to develop new copper criteria US EPA concluded that the use of the hardness alone often resulted in limitations that were not fully protective of aquatic life even using the most restrictive hardness and that one could not predict whether the hardness based equations would result in limitations that were overly or under restrictive. U.S. EPA’s latest ambient criteria for copper (*Aquatic Life Ambient Freshwater Quality Criteria—Copper 2007 Revision*), utilizes the other constituents that affect metal toxicity. Since EPA published the hardness-based recommendation for copper criteria in 1984, new data have become available on copper toxicity and its effects on aquatic life. The Biotic Ligand Model (BLM) – a metal bioavailability model that uses receiving water body characteristics to develop site-specific water quality criteria – utilizes the best available science and serves as the basis for the new national recommended criteria. The BLM requires ten input parameters to calculate a freshwater copper criterion (a saltwater BLM is not yet available): temperature, pH, dissolved organic carbon (DOC), calcium, magnesium, sodium, potassium, sulfate, chloride, and alkalinity. The BLM is used to derive the criteria rather than as a post-derivation adjustment as was the case with the

hardness-based criteria. This allows the BLM-based criteria to be customized to the particular water under consideration. EPA states in the Federal Register (Federal Register / Vol. 72, No. 35 / Thursday, February 22, 2007 / Notices, 7985) that: *“Unlike the empirically derived hardness-dependent criteria, the BLM explicitly accounts for individual water quality variables and addresses variables that EPA had not previously factored into the hardness relationship. Where the previous freshwater aquatic life criteria were hardness-dependent, these revised criteria are dependent on a number of water quality parameters (e.g., calcium, magnesium, dissolved organic carbon) described in the document. BLM-based criteria can be more stringent than the current hardness-based copper criteria and in certain cases the current hardness-based copper criteria may be overly stringent for particular water bodies”*.

The water quality standard and aquatic toxicity specialists from the Service, NMFS and US EPA determined that the metals limitations based solely on hardness could not be shown to be overly protective. This conclusion is contrary to the central premise of the “Emerick” paper which relies solely on hardness. Hardness based toxic metal limitations cannot be shown to be overly protective without evaluating the discharge specific impacts of temperature, pH, dissolved organic carbon (DOC), calcium, magnesium, sodium, potassium, sulfate, chloride, and alkalinity. The Regional Board has relied on the “Emerick” methodology to develop limitations for hardness dependent toxic metals in NPDES permits citing that use of the lowest observed hardness and use of the CTR equation would result in overly protective limitations. The Regional Board has commented that the Services’ and NMFS comments were directed at CTR development and have ignored the science. The Regional Board has also refused to use US EPA’s new criteria for copper (a CTR toxic metal) that utilizes all the parameters that can impact the toxicity of a metal. The “Emerick” method and the Regional Board’s adherence to that method does not eliminate “overly protective” limitations but instead develops limits that are less restrictive than prescribed by the CTR and are in most instances not protective of aquatic life.

The Regional Board rarely requires NPDES wastewater Dischargers to sample for of dissolved organic carbon (DOC), calcium, magnesium, sodium, potassium, sulfate or chloride. Each of these parameters can be significantly altered in the receiving stream by wastewater discharges. Therefore, based on the latest science and advice from the water quality standards and toxicity experts they could not even make an intelligent guess whether limitations for toxic hardness dependant metals are overly protective. This complete lack of data also precludes the Regional Board from using US EPA’s latest ambient criteria for copper, a hardness dependant toxic metal. The Regional Board’s dependence on a single study (Emerick) that only evaluates hardness with regard to metals toxicity to reach a conclusion that using the lowest observed hardness and the CTR equations is overly protective is without merit and is not supported by the latest available science.

The “Emerick” paper, page 4, states that: *“As depicted, because of the concave downward relationship between the copper water quality objective and hardness, assimilative capacity is always produced when two waters of differing hardness are mixed. Therefore, it is appropriate and protective to assign copper (and any other contaminant exhibiting a concave downward relationship) water quality objectives based on the hardness of the effluent.”* As is detailed by the US Fish and Wildlife Service, the National Marine Fisheries and US EPA in their updated copper criteria, using hardness alone one cannot state that the hardness based metals limitations are sufficiently stringent, let alone to conclude that there is “assimilative capacity” within the receiving stream. Since the “Emerick” paper is solely based on hardness and does not evaluate all the other parameters that can impact toxicity, the conclusions that metals limitations are overly stringent and there is assimilative capacity for metals is simply wrong. The Regional Board has no knowledge that hardness based limitations are overly restrictive when using the CTR equations and the lowest observed hardness to develop discharge limitations for metals. The single and sole reason for using the “Emerick” method is to relax discharge limitations for toxic metals.

The Effluent and Downstream Mixed Hardness Were Used in the proposed Permit

The proposed Permit, page F-31, states that: *“The secondary effluent hardness ranged from 136 mg/L to 327 mg/L, based on 37 samples from October 2006 to March 2011. The upstream receiving water hardness varied from 48 mg/L to 450 mg/L, based on 83 samples from November 2006 to January 2011. Under the effluent dominated condition, the reasonable worst-case downstream ambient hardness is 128 mg/L. As demonstrated in the example shown in Table F-4, below, using this hardness to calculate the ECA for all Concave Down Metals will result in WQBELs that are protective under all flow conditions, from the effluent dominated condition to the high flow condition.”*

The proposed Permit, page F-32 and 33, also states that: *“The ECA, as calculated using Equation 4, is based on the reasonable worst-case upstream receiving water hardness, the lowest observed effluent hardness, and assuming no receiving water assimilative capacity for metals (i.e., ambient background metals concentrations are at their respective CTR criterion). Equation 4 is not used in place of the CTR equation (Equation 1). Rather, Equation 4, which is derived using the CTR equation, is used as a direct approach for calculating the ECA. This replaces an iterative approach for calculating the ECA. The CTR equation has been used to evaluate the receiving water downstream of the discharge at all discharge and flow conditions to ensure the ECA is protective (e.g., see Table F 5).”* (Emphasis added)

Again in both cases the Regional Board failed to use the upstream ambient instream hardness which is the most stringent hardness and will produce significantly more restrictive effluent limitations than the methodology used by the Regional Board. Contrary to the Regional Board’s statement; the CTR methodology is not an iterative approach. Using the CTR

methodology; one simply uses the lowest observed hardness into the prescribed equations and the solution is given.

The Wrong Equations Were Used

The California Toxics Rule (CTR) Federal Regulation 40 CFR 131.38(c)(4) states that: “For purposes of calculating freshwater aquatic life criteria for metals from the equations in paragraph (b)(2) of this section, for waters with a hardness of 400 mg/l or less as calcium carbonate, the actual ambient hardness of the surface water shall be used in those equations.” (Emphasis added).

The CTR requires the use of the equations presented in paragraph (b)(2) of 40 CFR 131.38 for the development of effluent limitations for hardness dependant metals. The required CTR equation is:

$$\text{CTR Criterion} = \text{WER} \times (\exp(m[\ln(H)]+b))$$

where: H = hardness (mg/L as CaCO₃), WER = water-effect ratio (with a default value of 1) and m, b = metal and criterion specific constants.

The CTR equation is cited as “equation 1” in the proposed Permit (page F-18). The proposed Permit cites a 2006 technical paper prepared by Robert Emerick (see footnote 7 on page F-18) as the source of the equations used by the Regional Board in developing the Permit effluent limitations for some hardness dependant metals (see Table F-6 footnote 2). Dr. Emerick’s equation 4 is presented on page F-23 of the proposed Permit. Equation 4 is not the same as equation 1 which is prescribed by the CTR.

The use of equations other than those prescribed by the CTR for development of effluent limitations for hardness dependant metals is contrary to the requirements of the CTR.

The “ambient” hardness was not used

Federal Regulation 40 CFR 131.38(c)(4) states that: “For purposes of calculating freshwater aquatic life criteria for metals from the equations in paragraph (b)(2) of this section, for waters with a hardness of 400 mg/l or less as calcium carbonate, the actual ambient hardness of the surface water shall be used in those equations.” (Emphasis added).

The common dictionary definition of *ambient* is “in the surrounding area”, “encompassing on all sides”.

The common definition of ambient of surrounding would eliminate any areas that included the wastewater effluent in consideration of the hardness used in determining criteria for hardness

dependant metals. It is reasonable to assume, after considering the definition of ambient, that EPA is referring to the hardness of the receiving stream before it is potentially impacted by an effluent discharge. It is also reasonable to make this assumption based on past interpretations and since EPA, in permit writers' guidance and other reference documents, generally assumes receiving streams have dilution, which would ultimately "encompass" the discharge. Ambient conditions are in-stream conditions unimpacted by the discharge. Confirming this definition, the SIP Sections 1.4.3.1 *Ambient Background Concentration as an Observed Maximum* and 1.4.3.2 state in part that: "If possible, preference should be given to ambient water column concentrations measured immediately upstream or near the discharge, but not within an allowed mixing zone for the discharge. The RWQCB shall have discretion to consider if any samples are invalid for use as applicable data due to evidence that the sample has been erroneously reported or the sample is not representative of the ambient receiving water column that will mix with the discharge."

CSPA's view regarding the term ambient is also supported by a biological opinion issued by the US Fish and Wildlife Service (Service) and the National Marine Fisheries Service (NMFS) on March 24th 2000. On March 24, 2000 the US Fish and Wildlife Service (Service) and the National Marine Fisheries Service (NMFS) issued a biological opinion on the effects of the final promulgation of the CTR on listed species and critical habitats in California in accordance with section 7 of the Endangered Species Act of 1973, as amended (16 USC 1531 et seq.; Act). The biological opinion was issued to the U.S. Environmental Protection Agency, Region 9, with regard to the "Final Rule for the Promulgation of Water Quality Standards: Establishment of Numeric Criteria for Priority Toxic Pollutants for the State of California" (CTR)". The document represented the Services' final biological opinion on the effects of the final promulgation of the CTR on listed species and critical habitats in California in accordance with section 7 of the Endangered Species Act of 1973, as amended (16 USC 1531 et seq.; Act). The biological opinion contains the following discussion, beginning on page 205, regarding the use of hardness in developing limitations for toxic metals:

"The CTR should more clearly identify what is actually to be measured in a site water to determine a site-specific hardness value. Is the measure of hardness referred to in the CTR equations a measure of the water hardness due to calcium and magnesium ions only? If hardness computations were specified to be derived from data obtained in site water calcium and magnesium determinations alone, confusion could be avoided and more accurate results obtained (APHA 1985). Site hardness values would thus not include contributions from other multivalent cations (e.g., iron, aluminum, manganese), would not rise above calcium + magnesium hardness values, or result in greater-than-intended site criteria when used in formulas. In this Biological opinion, what the Services refer to as hardness is the water hardness due to calcium + magnesium ions only.

The CTR should clearly state that to obtain a site hardness value, samples should be collected upstream of the effluent source(s). Clearly stating this requirement in the CTR would avoid the computation of greater-than-intended site criteria in cases where samples were collected downstream of effluents that raise ambient hardness, but not other important water qualities that affect metal toxicity (e.g., pH, alkalinity, dissolved organic carbon, calcium, sodium, chloride, etc.). Clearly, it is inappropriate to use downstream site water quality variables for input into criteria formulas because they may be greatly altered by the effluent under regulation. Alterations in receiving water chemistry by a discharger (e.g., abrupt elevation of hardness, changes in pH, exhaustion of alkalinity, abrupt increases in organic matter etc.) should not result, through application of hardness in criteria formulas, in increased allowable discharges of toxic metals. If the use of downstream site water quality variables were allowed, discharges that alter the existing, naturally-occurring water composition would be encouraged rather than discouraged. Discharges should not change water chemistry even if the alterations do not result in toxicity, because the aquatic communities present in a water body may prefer the unaltered environment over the discharge-affected environment. Biological criteria may be necessary to detect adverse ecological effects downstream of discharges, whether or not toxicity is expressed.”

The Regional Board has argued however that they had discretion to redefine “ambient” and were not constrained by common dictionary definitions. The Regional Board’s definition of “ambient” included the wastewater effluent.

The Regional Board in the proposed Permit continues to use the effluent and downstream mixed hardness as “ambient” in their calculation of criteria for hardness dependant metals contrary to common definition, the language in the SIP, guidance from the US Fish and Wildlife Service and the National Marine Fisheries Service.

Use of the “Surface Water Hardness”

Federal Regulation 40 CFR 131.38(c)(4) states that: “For purposes of calculating freshwater aquatic life criteria for metals from the equations in paragraph (b)(2) of this section, for waters with a hardness of 400 mg/l or less as calcium carbonate, the actual ambient hardness of the surface water shall be used in those equations.” (Emphasis added).

As is stated above, the proposed Permit continues to utilize the wastewater effluent hardness when establishing criteria for hardness dependant metals. This is also confirmed in the text regarding hardness in the Fact Sheet and by “equation 4” on page F-32 which is partly based on the “lowest observed effluent hardness”.

The wastewater effluent is not “surface water”. The Regional Board has not argued this point but has steadfastly refused to acknowledge or discuss the CTR requirement that the hardness of the surface water be used in calculating the criteria for hardness dependant metals. The proposed Permit is again based on the hardness of the effluent, not surface water, for hardness dependant metals.

The “Emerick” Paper cannot be used

The proposed Permit relies on the “Emerick” paper in developing effluent limitations for hardness dependant metals. The “Emerick” paper is inappropriate for use based on the following:

- The “Emerick” paper does not utilize the hardness of the surface water but also heavily relies on the effluent hardness. Recall that 40 CFR 131.38 requires use of the actual ambient hardness of the surface water.
- The “Emerick” paper does not solely use the equations specified in 40 CFR 131.38(c)(4).
- The “Emerick” paper does not utilize the ambient hardness also heavily relies on the effluent hardness.
- The “Emerick” paper ignores the other important water qualities that affect metal toxicity (e.g., pH, alkalinity, dissolved organic carbon, calcium, sodium, chloride, etc.) and focuses solely on hardness. As can be seen the U.S. EPA’s latest ambient criteria for copper (*Aquatic Life Ambient Freshwater Quality Criteria—Copper 2007 Revision*), the latest science utilizes these other quality that affect metal toxicity. Since EPA published the hardness-based recommendation for copper criteria in 1984, new data have become available on copper toxicity and its effects on aquatic life. The Biotic Ligand Model (BLM) – a metal bioavailability model that uses receiving water body characteristics to develop site-specific water quality criteria – utilizes the best available science and serves as the basis for the new national recommended criteria. The BLM requires ten input parameters to calculate a freshwater copper criterion (a saltwater BLM is not yet available): temperature, pH, dissolved organic carbon (DOC), calcium, magnesium, sodium, potassium, sulfate, chloride, and alkalinity. The BLM is used to derive the criteria rather than as a post-derivation adjustment as was the case with the hardness-based criteria. This allows the BLM-based criteria to be customized to the particular water under consideration. The Regional Board failed to utilize the latest science in developing the proposed Permit.

Establishing a protective limitation

For the great majority of wastewater discharges to surface waters the hardness of the effluent is much greater than the hardness or the upstream surface water. In such cases, use of the higher hardness of the effluent to calculate discharge limitations for hardness dependant metals results

in significantly less stringent discharge limitations. The “Emerick” method uses the higher effluent hardness to determine criteria as the effluent mixes with surface water. The Regional Board has used the “Emerick” method to generate these less stringent limitations stating that the methodology only eliminates what would have otherwise been overly protective limitations¹. Adherence to the required CTR methodology using the lower surface water hardness would, under these circumstances, produce more stringent criteria. In reviewing the Central Valley Regional Board’s NPDES permits it can be seen that use of the “Emerick” method is used by default, ignoring the mandated CTR method of calculating criteria for hardness dependant metals. It has been questioned whether the Regional Board’s default use of the “Emerick” method constitutes an underground regulation. "Regulation" means every rule, regulation, order, or standard of general application or the amendment, supplement, or revision of any rule, regulation, order or standard adopted by any state agency to implement, interpret, or make specific the law enforced or administered by it, or to govern its procedure.” (Government Code section 11342.600).

The Regional Board cannot produce a technical defense that use of the CTR prescribed methods is overly protective. To the contrary, the US Fish and Wildlife Service and the National Marine Fisheries Service in their biological opinion and U.S. EPA in developing new ambient criteria for copper, all state that the use of hardness alone, ignoring temperature, pH, dissolved organic carbon (DOC), calcium, magnesium, sodium, potassium, sulfate, chloride, and alkalinity, may not be protective of water quality. The agencies, in their biological opinion, state that only the lower upstream hardness should be used to account for the inaccuracies of using hardness alone. The Regional Board does not present any technical information to rebut the technical fisheries and water quality standards development experts at US Fish and Wildlife Service, the National Marine Fisheries Service or U.S. EPA. The Regional Board has refused to discuss the technical merits of the opinions given by the US Fish and Wildlife Service, the National Marine Fisheries Service and U.S. EPA, stating only that the opinions address the CTR and are not applicable to individual permitting actions.

I. The proposed Permit fails to contain an Effluent Limitation for aluminum in accordance with Federal Regulations 40 CFR 122.44, US EPA’s interpretation of the regulation, and California Water Code, Section 13377.

¹ See permits for Sacramento Regional (http://www.swrcb.ca.gov/centralvalley/board_decisions/adopted_orders/sacramento/r5-2010-0114_npdes.pdf, at pages F-22 and 23), The City of Auburn (http://www.swrcb.ca.gov/centralvalley/board_decisions/adopted_orders/placer/r5-2010-0090-01.pdf, page F-23 “An ECA based on a lower hardness (e.g., lowest upstream receiving water hardness) would also be protective, but would result in unreasonably stringent effluent limits considering the known conditions.”), Placer County SMD-1 (http://www.swrcb.ca.gov/centralvalley/board_decisions/adopted_orders/placer/r5-2010-0092.pdf, page F-26, “Use of a lower ECA (e.g., calculated based solely on the lowest upstream receiving water hardness) is also protective, but would lead to unreasonably stringent effluent limits considering the known conditions.”)

Federal Regulations, 40 CFR 122.44 (d)(i), requires that; “Limitations must control all pollutants or pollutant parameters (either conventional, nonconventional, or toxic pollutants) which the Director determines are or may be discharged at a level which will cause, have the reasonable potential to cause, or contribute to an excursion above any State water quality standard, including State narrative criteria for water quality.” The Basin Plan contains a narrative water quality objective for toxicity that states in part that “[a]ll waters shall be maintained free of toxic substances in concentrations that produce detrimental physiological responses in human, plant, animal, or aquatic life” (narrative toxicity objective). Where numeric water quality objectives have not been established, 40 CFR §122.44(d) specifies that WQBELs may be established using USEPA criteria guidance under CWA section 304(a), proposed State criteria or a State policy interpreting narrative criteria supplemented with other relevant information, or an indicator parameter. U.S. EPA developed National Recommended Ambient Water Quality Criteria for protection of freshwater aquatic life for aluminum to prevent toxicity to freshwater aquatic life. The recommended ambient criteria four-day average (chronic) and one-hour average (acute) criteria for aluminum are 87 µg/l and 750 µg/l, respectively.

Aluminum in the effluent has been measured as high as 370 µg/l. Freshwater Aquatic habitat is a beneficial use of the receiving stream.

US EPA’s 87 ug/l chronic criterion was developed using low pH and hardness testing. California Central Valley waters, the Sacramento River, at the Valley floor, have been sampled to have hardnesses as low as 39 mg/l CaCO₃ by the USGS in February 1996 for the *National Water Quality Assessment Program*. Contributory streams, especially foothill streams, have also been sampled and shown to contain even lower hardness levels. US EPA recognized in their ambient criteria development document, (Ambient Water Quality Criteria for Aluminum, EPA 440/5-86-008) that the pH was in the range 6.5 to 6.6 and that the hardness was below 20 mg/l. Typical values for pH and hardness in the Central Valley alone warrant use of the chronic ambient criteria for aluminum. Despite the hardness and pH values used in the development of the criteria; U.S. EPA’s conclusions in their *Ambient Criteria for the Protection of Freshwater Aquatic Life* recommends that application of the ambient criteria as necessary to be protective of the aquatic beneficial uses of receiving waters in lieu of site-specific criteria.

The Regional Board and their proposed Permit cites US EPA’s *Ambient Criteria for the Protection of Freshwater Aquatic Life for Aluminum* (criteria) as not being representative or necessary because the chronic criteria were based on a low hardness and low pH. The Regional Board cites one section of the criteria development document but ignores the final recommendation to use the recommended criteria absent a site-specific objective for aluminum. The Regional Board then defaults to the US EPA recommended acute criteria of 750 ug/l. The Regional Board’s citation of the criteria development document is incomplete its review, for example the *criteria* development document (EPA 440/5-86-008) also cites that:

169 ug/l of aluminum caused a 24% reduction in the growth of young brook trout.

174 ug/l of aluminum killed 58% of the exposed striped bass.

Bioaccumulation factors ranged from 50 to 231 for young brook trout exposed to aluminum for 15 days.

Aluminum at 169 ug/l caused a 24% reduction in the weight of young brook trout.

US EPA recommends that understanding the *Guidelines for Deriving Numerical National Water Quality Criteria for the Protection of Aquatic Organisms and Their Uses* is necessary in order to understand the text, tables and calculations of a criteria document. The Regional Board's assessment of the use of low hardness and low pH clearly shows they did not heed EPA's advice in reviewing the criteria development procedures for water quality criteria or the final recommendations. The Regional Board occasionally cites individual aluminum toxicity testing at Yuba City; again individual testing is not a valid replacement for developing fully protective criteria. A prime example of a state utilizing good water quality standards development techniques for developing a site specific standard for aluminum is the state of Indiana where a final chronic criterion of 174 ug/l was established in 1997. In 2003, Canada adopted pH dependant freshwater aquatic life criteria for aluminum that ranges from 84 ug/l to 252 ug/l. Ignoring the final recommendation of the criteria misses the protective intermediate measures to protect against mortality and reductions to growth and reproduction. The Regional Board's single use of the acute criteria for aluminum is not protective of the beneficial uses of the receiving stream.

Based on information included in analytical laboratory reports submitted by the Discharger, aluminum in the discharge has a reasonable potential to cause or contribute to an in-stream excursion above a level necessary to protect aquatic life, and, therefore to violate the Basin Plan's narrative toxicity objective.

Federal Regulations, 40 CFR 122.44 (d)(i), requires that; "Limitations must control all pollutants or pollutant parameters (either conventional, nonconventional, or toxic pollutants) which the Director determines are or may be discharged at a level which will cause, have the reasonable potential to cause, or contribute to an excursion above any State water quality standard, including State narrative criteria for water quality." US EPA has interpreted 40 CFR 122.44(d) in *Central Tenets of the National Pollutant Discharge Elimination System (NPDES) Permitting Program* (Factsheets and Outreach Materials, 08/16/2002) that although States will likely have unique implementation policies there are certain tenets that may not be waived by State procedures. These tenets include that "where valid, reliable, and representative effluent data or instream background data are available they MUST be used in applicable reasonable potential and limits derivation calculations. Data may not be arbitrarily discarded or ignored." The California Water Code (CWC), Section 13377 states in part that: "...the state board or the regional boards

shall...issue waste discharge requirements... which apply and ensure compliance with ...water quality control plans, or for the protection of beneficial uses...” Section 122.44(d) of 40 CFR requires that permits include water quality-based effluent limitations (WQBELs) to attain and maintain applicable numeric and narrative water quality criteria to protect the beneficial uses of the receiving water. A water quality standard for Failure to include an effluent limitation for aluminum which prevents chronic toxicity in the proposed permit violates 40 CFR 122.44 and CWC 13377.

J. The proposed Permit contains Effluent Limitations less stringent than the existing permit contrary to the Antidegradation requirements of the Clean Water Act and Federal Regulations, 40 CFR 122.44 (I)(1).

Under the Clean Water Act (CWA), point source dischargers are required to obtain federal discharge (NPDES) permits and to comply with water quality based effluent limits (WQBELs) in NPDES permits sufficient to make progress toward the achievement of water quality standards or goals. The antidegradation and antidegradation rules clearly spell out the interest of Congress in achieving the CWA’s goal of continued progress toward eliminating all pollutant discharges. Congress clearly chose an overriding environmental interest in clean water through discharge reduction, imposition of technological controls, and adoption of a rule against relaxation of limitations once they are established.

Upon permit reissuance, modification, or renewal, a discharger may seek a relaxation of permit limitations. However, according to the CWA, relaxation of a WQBEL is permissible only if the requirements of the antidegradation rule are met. The antidegradation regulations prohibit EPA from reissuing NPDES permits containing interim effluent limitations, standards or conditions less stringent than the final limits contained in the previous permit, with limited exceptions. These regulations also prohibit, with some exceptions, the reissuance of permits originally based on best professional judgment (BPJ) to incorporate the effluent guidelines promulgated under CWA §304(b), which would result in limits less stringent than those in the previous BPJ-based permit. Congress statutorily ratified the general prohibition against backsliding by enacting §§402(o) and 303(d)(4) under the 1987 Amendments to the CWA. The amendments preserve present pollution control levels achieved by dischargers by prohibiting the adoption of less stringent effluent limitations than those already contained in their discharge permits, except in certain narrowly defined circumstances.

When attempting to backslide from WQBELs under either the antidegradation rule or an exception to the antidegradation rule, relaxed permit limits must not result in a violation of applicable water quality standards. The general prohibition against backsliding found in §402(o)(1) of the Act contains several exceptions. Specifically, under §402(o)(2), a permit may be renewed, reissued, or modified to contain a less stringent effluent limitation applicable to a

pollutant *if*: (A) material and substantial alterations or additions to the permitted facility occurred after permit issuance which justify the application of a less stringent effluent limitation; (B)(i) information is available which was not available at the time of permit issuance (other than revised regulations, guidance, or test methods) and which would have justified the application of a less stringent effluent limitation at the time of permit issuance; or (ii) the Administrator determines that technical mistakes or mistaken interpretations of law were made in issuing the permit under subsection (a)(1)(B) of this section; (C) a less stringent effluent limitation is necessary because of events over which the permittee has no control and for which there is no reasonably available remedy [(e.g., Acts of God)]; (D) the permittee has received a permit modification under section 1311(c), 1311(g), 1311(h), 1311(i), 1311(k), 1311(n), or 1326(a) of this title; or (E) the permittee has installed the treatment facilities required to meet the effluent limitations in the previous permit, and has properly operated and maintained the facilities, but has nevertheless been unable to achieve the previous effluent limitations, in which case the limitations in the reviewed, reissued, or modified permit may reflect the level of pollutant control actually achieved (but shall not be less stringent than required by effluent guidelines in effect at the time of permit renewal, reissuance, or modification).

Even if a discharger can meet either the requirements of the antidegradation rule under §303(d)(4) or one of the statutory exceptions listed in §402(o)(2), there are still limitations as to how far a permit may be allowed to backslide. Section 402(o)(3) acts as a floor to restrict the extent to which BPJ and water quality-based permit limitations may be relaxed under the antibacksliding rule. Under this subsection, even if EPA allows a permit to backslide from its previous permit requirements, EPA may never allow the reissued permit to contain effluent limitations which are less stringent than the current effluent limitation guidelines for that pollutant, or which would cause the receiving waters to violate the applicable state water quality standard adopted under the authority of §303.49.

Federal regulations 40 CFR 122.44 (l)(1) have been adopted to implement the antibacksliding requirements of the CWA:

- (1) Reissued permits. (1) Except as provided in paragraph (l)(2) of this section when a permit is renewed or reissued, interim effluent limitations, standards or conditions must be at least as stringent as the final effluent limitations, standards, or conditions in the previous permit (unless the circumstances on which the previous permit was based have materially and substantially changed since the time the permit was issued and would constitute cause for permit modification or revocation and reissuance under Sec. 122.62.)
- (2) In the case of effluent limitations established on the basis of Section 402(a)(1)(B) of the CWA, a permit may not be renewed, reissued, or modified on the basis of effluent guidelines promulgated under section 304(b) subsequent to the original issuance of such

permit, to contain effluent limitations which are less stringent than the comparable effluent limitations in the previous permit.

(i) Exceptions--A permit with respect to which paragraph (l)(2) of this section applies may be renewed, reissued, or modified to contain a less stringent effluent limitation applicable to a pollutant, if:

(A) Material and substantial alterations or additions to the permitted facility occurred after permit issuance which justify the application of a less stringent effluent limitation;

(B)(1) Information is available which was not available at the time of permit issuance (other than revised regulations, guidance, or test methods) and which would have justified the application of a less stringent effluent limitation at the time of permit issuance; or (2) The Administrator determines that technical mistakes or mistaken interpretations of law were made in issuing the permit under section 402(a)(1)(b);

(C) A less stringent effluent limitation is necessary because of events over which the permittee has no control and for which there is no reasonably available remedy;

(D) The permittee has received a permit modification under section 301(c), 301(g), 301(h), 301(i), 301(k), 301(n), or 316(a); or

(E) The permittee has installed the treatment facilities required to meet the effluent limitations in the previous permit and has properly operated and maintained the facilities but has nevertheless been unable to achieve the previous effluent limitations, in which case the limitations in the reviewed, reissued, or modified permit may reflect the level of pollutant control actually achieved (but shall not be less stringent than required by effluent guidelines in effect at the time of permit renewal, reissuance, or modification).

(ii) Limitations. In no event may a permit with respect to which paragraph (l)(2) of this section applies be renewed, reissued, or modified to contain an effluent limitation which is less stringent than required by effluent guidelines in effect at the time the permit is renewed, reissued, or modified. In no event may such a permit to discharge into waters be renewed, issued, or modified to contain a less stringent effluent limitation if the implementation of such limitation would result in a violation of a water quality standard under section 303 applicable to such waters.

Backsliding in the proposed Permit is simply based on a statistical analysis using a limited data set. The Regional Board states in their discussion of backsliding, beginning on page F-71, that the coefficient of variation is different than that used to develop the previous NPDES permit. This is due to the fact that the Regional Board only used data from February 2009 to March 2011 (permit at F-10). There is no justification for using the limited data set. The treatment processes and the character of the wastewater, influent or effluent, did not change. The Regional Board fails to cite any exception to the federal regulations that would allow for backsliding based on a new statistical analysis by using a limited data set. To the contrary, the Regional Board is required by regulation to use all relevant and valid data, which they failed to do:

Federal Regulations, 40 CFR 122.44(d), requires that limits must be included in permits where pollutants will cause, have reasonable potential to cause, or contribute to an exceedance of the State's water quality standards. US EPA has interpreted 40 CFR 122.44(d) in *Central Tenets of the National Pollutant Discharge Elimination System (NPDES) Permitting Program* (Factsheets and Outreach Materials, 08/16/2002) that; although States will likely have unique implementation policies there are certain tenets that may not be waived by State procedures. These tenets include that "where valid, reliable, and representative effluent data or instream background data are available they MUST be used in applicable reasonable potential and limits derivation calculations. Data may not be arbitrarily discarded or ignored." The Regional Board has failed to use valid, reliable and representative data in developing limitations, contrary to the cited Federal Regulation.

The *Policy for Implementation of Toxics Standards for Inland Surface Waters, Enclosed Bays, and Estuaries Of California* (SIP), Section 1.2 requires that: "When implementing the provisions of this Policy, the RWQCB shall use all available, valid, relevant, representative data and information, as determined by the RWQCB. The RWQCB shall have discretion to consider if any data are inappropriate or insufficient for use in implementing this Policy. Instances where such consideration is warranted include, but are not limited to, the following: evidence that a sample has been erroneously reported or is not representative of effluent or ambient receiving water quality; questionable quality control/quality assurance practices; and varying seasonal conditions."

The proposed Permit must be reanalyzed using all of the available valid, reliable, and representative effluent data, including that used to develop the previous NPDES permit. The Regional Board's use of limited data to conduct reasonable potential analyses is not "new" information as required for backsliding and is contrary to 40 CFR 122.44(d) as interpreted by US EPA and the SIP.

K. The proposed Permit contains an inadequate antidegradation analysis that does not comply with the requirements of Section 101(a) of the Clean Water Act, Federal Regulations 40 CFR § 131.12, the State Board's Antidegradation Policy (Resolution 68-16) and California Water Code (CWC) Sections 13146 and 13247.

CWC Sections 13146 and 13247 require that the Board in carrying out activities which affect water quality shall comply with state policy for water quality control unless otherwise directed by statute, in which case they shall indicate to the State Board in writing their authority for not complying with such policy. The State Board has adopted the Antidegradation Policy

(Resolution 68-16), which the Regional Board has incorporated into its Basin Plan. The Regional Board is required by the CWC to comply with the Antidegradation Policy.

Section 101(a) of the Clean Water Act (CWA), the basis for the antidegradation policy, states that the objective of the Act is to “restore and maintain the chemical, biological and physical integrity of the nation’s waters.” Section 303(d)(4) of the CWA carries this further, referring explicitly to the need for states to satisfy the antidegradation regulations at 40 CFR § 131.12 before taking action to lower water quality. These regulations (40 CFR § 131.12(a)) describe the federal antidegradation policy and dictate that states must adopt both a policy at least as stringent as the federal policy as well as implementing procedures.

California’s antidegradation policy is composed of both the federal antidegradation policy and the State Board’s Resolution 68-16 (State Water Resources Control Board, Water Quality Order 86-17, p. 20 (1986) (“Order 86-17”); Memorandum from Chief Counsel William Attwater, SWRCB to Regional Board Executive Officers, “federal Antidegradation Policy,” pp. 2, 18 (Oct. 7, 1987) (“State Antidegradation Guidance”). As a state policy, with inclusion in the Water Quality Control Plan (Basin Plan), the antidegradation policy is binding on all of the Regional Boards (Water Quality Order 86-17, pp. 17-18).

Implementation of the state’s antidegradation policy is guided by the State Antidegradation Guidance, SWRCB Administrative Procedures Update 90-004, 2 July 1990 (“APU 90-004”) and USEPA Region IX, “Guidance on Implementing the Antidegradation Provisions of 40 CFR 131.12” (3 June 1987) (“Region IX Guidance”), as well as Water Quality Order 86-17.

The Regional Board must apply the antidegradation policy whenever it takes an action that will lower water quality (State Antidegradation Guidance, pp. 3, 5, 18, and Region IX Guidance, p. 1). Application of the policy does not depend on whether the action will actually impair beneficial uses (State Antidegradation Guidance, p. 6). Actions that trigger use of the antidegradation policy include issuance, re-issuance, and modification of NPDES and Section 404 permits and waste discharge requirements, waiver of waste discharge requirements, issuance of variances, relocation of discharges, issuance of cleanup and abatement orders, increases in discharges due to industrial production and/or municipal growth and/or other sources, exceptions from otherwise applicable water quality objectives, etc. (State Antidegradation Guidance, pp. 7-10, Region IX Guidance, pp. 2-3). Both the state and federal policies apply to point and nonpoint source pollution (State Antidegradation Guidance p. 6, Region IX Guidance, p. 4).

Tier 2 waters are provided additional protections against unnecessary degradation in places where the levels of water quality are better than necessary to support existing uses. Tier 2 protections strictly prohibit degradation unless the state finds that a degrading activity is: 1) necessary to accommodate important economic or social development in the area, 2) water

quality is adequate to protect and maintain existing beneficial uses and 3) the highest statutory and regulatory requirements and best management practices for pollution control are achieved (40 CFR § 131.12(a) (2)). Cost savings to a discharger alone, absent a demonstration by the project proponent as to how these savings are “necessary to accommodate important economic or social development in the area,” are not adequate justification for allowing reductions in water quality (Water Quality Order 86-17, p. 22; State Antidegradation Guidance, p. 13). If the waterbody passes this test and the degradation is allowed, degradation must not impair existing uses of the waterbody (48 Fed. Reg. 51403). Virtually all waterbodies in California may be Tier 2 waters since the state, like most states, applies the antidegradation policy on a parameter-by-parameter basis, rather than on a waterbody basis (APU 90-004, p. 4). Consequently, a request to discharge a particular chemical to a river, whose level of that chemical was better than the state standards, would trigger a Tier 2 antidegradation review even if the river was already impaired by other chemicals.

The State Board’s APU 90-004 specifies guidance to the Regional Boards for implementing the state and federal antidegradation policies and guidance. The guidance establishes a two-tiered process for addressing these policies and sets forth two levels of analysis: a simple analysis and a complete analysis. A simple analysis may be employed where a Regional Board determines that: 1) a reduction in water quality will be spatially localized or limited with respect to the waterbody, e.g. confined to the mixing zone; 2) a reduction in water quality is temporally limited; 3) a proposed action will produce minor effects which will not result in a significant reduction of water quality; and 4) a proposed activity has been approved in a General Plan and has been adequately subjected to the environmental and economic analysis required in an EIR. A complete antidegradation analysis is required if discharges would result in: 1) a substantial increase in mass emissions of a constituent; or 2) significant mortality, growth impairment, or reproductive impairment of resident species. Regional Boards are advised to apply stricter scrutiny to non-threshold constituents, i.e., carcinogens and other constituents that are deemed to present a risk of source magnitude at all non-zero concentrations. If a Regional Board cannot find that the above determinations can be reached, a complete analysis is required.

Even a minimal antidegradation analysis would require an examination of: 1) existing applicable water quality standards; 2) ambient conditions in receiving waters compared to standards; 3) incremental changes in constituent loading, both concentration and mass; 4) treatability; 5) best practicable treatment and control (BPTC); 6) comparison of the proposed increased loadings relative to other sources; 7) an assessment of the significance of changes in ambient water quality and 8) whether the waterbody was a ONRW. A minimal antidegradation analysis must also analyze whether: 1) such degradation is consistent with the maximum benefit to the people of the state; 2) the activity is necessary to accommodate important economic or social development in the area; 3) the highest statutory and regulatory requirements and best management practices for pollution control are achieved; and 4) resulting water quality is

adequate to protect and maintain existing beneficial uses. A BPTC technology analysis must be done on an individual constituent basis; while tertiary treatment may provide BPTC for pathogens, dissolved metals may simply pass through.

Any antidegradation analysis must comport with implementation requirements in State Board Water Quality Order 86-17, State Antidegradation Guidance, APU 90-004 and Region IX Guidance. The conclusory, unsupported, undocumented statements in the Permit are no substitute for a defensible antidegradation analysis.

The antidegradation review process is especially important in the context of waters protected by Tier 2. See EPA, Office of Water Quality Regulations and Standards, *Water Quality Standards Handbook*, 2nd ed. Chapter 4 (2nd ed. Aug. 1994). Whenever a person proposes an activity that may degrade a water protected by Tier 2, the antidegradation regulation requires a state to: (1) determine whether the degradation is “necessary to accommodate important economic or social development in the area in which the waters are located”; (2) consider less-degrading alternatives; (3) ensure that the best available pollution control measures are used to limit degradation; and (4) guarantee that, if water quality is lowered, existing uses will be fully protected. 40 CFR § 131.12(a)(2); EPA, Office of Water Quality Regulations and Standards, *Water Quality Standards Handbook*, 2nd ed. 4-1, 4-7 (2nd ed. Aug. 1994). These activity-specific determinations necessarily require that each activity be considered individually.

For example, the APU 90-004 states:

“Factors that should be considered when determining whether the discharge is necessary to accommodate social or economic development and is consistent with maximum public benefit include: a) past, present, and probably beneficial uses of the water, b) economic and social costs, tangible and intangible, of the proposed discharge compared to benefits. The economic impacts to be considered are those incurred in order to maintain existing water quality. The financial impact analysis should focus on the ability of the facility to pay for the necessary treatment. The ability to pay depends on the facility’s source of funds. In addition to demonstrating a financial impact on the publicly – or privately – owned facility, the analysis must show a significant adverse impact on the community. The long-term and short-term socioeconomic impacts of maintaining existing water quality must be considered. Examples of social and economic parameters that could be affected are employment, housing, community services, income, tax revenues and land value. To accurately assess the impact of the proposed project, the projected baseline socioeconomic profile of the affected community without the project should be compared to the projected profile with the project...EPA’s *Water Quality Standards Handbook* (Chapter 5) provides additional guidance in assessing financial and socioeconomic impacts”

There is nothing resembling an economic or socioeconomic analysis in the Permit. As a rule-of-thumb, USEPA recommends that the cost of compliance should not be considered excessive until it consumes more than 2% of disposable household income in the region. This threshold is meant to suggest more of a floor than a ceiling when evaluating economic impact. In the Water Quality Standards Handbook, USEPA interprets the phrase “necessary to accommodate important economic or social development” with the phrase “substantial and widespread economic and social impact.”

The antidegradation analysis must discuss the relative economic burden as an aggregate impact across the entire region using macroeconomics. Considering the intrinsic value of the Delta to the entire state and the potential effects upon those who rely and use Delta waters, it must also evaluate the economic and social impacts to water supply, recreation, fisheries, etc. from the Discharger’s degradation of water quality in the Delta. Nor has the case been made that there is no alternative for necessary housing other than placing it where its wastewater must discharge directly into sensitive but seriously degraded waters. It is unfortunate that the agency charged with implementing the Clean Water Act has apparently decided it is more important to protect the polluter than the environment.

There is nothing in the Permit resembling an analysis that ensures that existing beneficial uses are protected. While the Permit identifies the constituents that are included on the 303(d) list as impairing receiving waters, it fails to discuss how and to what degree the identified beneficial uses will be additionally impacted by the discharge. Nor does the Permit analyze the incremental and cumulative impact of increased loading of non-impairing pollutants on beneficial uses. In fact, there is almost no information or discussion on the composition and health of the identified beneficial uses. Any reasonably adequate antidegradation analysis must discuss the affected beneficial uses (i.e., numbers and health of the aquatic ecosystem; extent, composition and viability of agricultural production; people depending upon these waters for water supply; extent of recreational activity; etc.) and the probable effect the discharge will have on these uses.

The Antidegradation analysis only analyzed near and far field water quality impacts. The near field impacts are assessed at one mile downstream of the wastewater treatment plant. It is amazing that if you look far enough downstream the impacts are “minimal”. There is no discussion of what occurs in the mixing zone, for which the point where complete mixing has yet to be identified. The antidegradation analysis does not discuss the backsliding allowed under the proposed Permit and the use of a limited data set for determining reasonable potential. The antidegradation analysis does not discuss the use of a hardness that is higher than the upstream ambient hardness in developing limitations for hardness dependant metals. The antidegradation analysis discusses economics with conclusory and unsupported statements and contains no economic analysis of the environmental impacts. For example the proposed Permit states that: “requiring the Discharger to implement control measures that would maintain existing water quality

and mass emissions in the San Joaquin River, would have significant adverse economic and social impacts on the City of Modesto and surrounding communities and their citizens and businesses” however this analysis is simply based on the local costs and sewer rates. Ignored are the possible impacts associated with providing a cleaner environment and improving the quality of life which could actually improve the economic setting by attracting businesses that provide higher paying jobs. Using the economic approach provided in the antidegradation analysis, no expansion of wastewater facilities would ever be rejected, the sewer rates are higher for cleaner water. The antidegradation analysis concludes that: “The benefits of maintaining existing water quality and mass emissions for the constituents analyzed are not commensurate with the costs of additional treatment. Therefore, no feasible alternatives currently exist to reduce the impacts” which is the only conclusion that can be derived when the analysis is limited to analyzing the costs to the discharger and looking at the water quality impacts far enough downstream.

The antidegradation analysis does not discuss the fact that a mixing zone for pollutants is being allowed absent a complete analysis of the impacts. “This Order allows mixing zones and dilution credits for human health carcinogen water quality criteria and agricultural water quality criteria, which are long-term criteria. For these long-term criteria, critical environmental impacts are expected to occur far downstream from the discharge, and the mixing zones have been allowed to extend to the point of complete mixing. However, the Discharger’s mixing zone study only evaluated mixing to a point 200 meters downstream of the discharge. Therefore, the point of complete mixing was not determined, and although a mixing zone was allowed in the previous permit, the edge of mixing zone was not defined. The State Water Board found in a precedential water quality order (WQ 2009 0003 for the City of Tracy Wastewater Treatment Plant) that it is necessary to define the edge of all mixing zones, including mixing zones for long-term criteria where any impacts are expected to occur far downstream after complete mixing. This Order carries forward the mixing zone and dilution credits for human health carcinogen criteria from the previous permit, but requires the Discharger submit a study that demonstrates the edge of the mixing zone. The Discharger shall conduct a study to evaluate the point of complete mixing under critical reasonable worst-case conditions.” (page F-91) The permit states that there are no drinking water intakes near the point of discharge, however fails to address how allowing an unidentified length of California waterway to exceed drinking water standards is in the best interest of the people of California. California’s drinking and irrigation water supplies are stressed due to overuse and limited availability. While the skewed economic analysis shows that actually treating sewage is more expensive than allowing it to be diluted in surface water, there is nothing showing that this is in the best interest of the people of California beyond the service area of the Discharger. For irrigated agriculture, there is no such statement regarding the absence of irrigation water intakes. While allowing human health drinking water, such as for carcinogens, and irrigation water quality standards to be exceeded may be in the best economic interest for the people of Modesto, (since the discharge is not upstream of them), there is no information that allows one to conclude

that degradation of drinking and irrigation water supplies is in the best interest of all Californians.

L. The proposed Permit fails to require that all environmental analyses be conducted at certified laboratories as required by CWC 131176 and CWC 13383.

CWC § 13176. Certified laboratories (a) The analysis of any material required by this division shall be performed by a laboratory that has accreditation or certification pursuant to Article 3 (commencing with Section 100825) of Chapter 4 of Part 1 of Division 101 of the Health and Safety Code. (b) No person or public entity of the state shall contract with a laboratory for environmental analyses for which the State Department of Health Services requires accreditation or certification pursuant to this chapter, unless the laboratory holds a valid certification or accreditation.

CWC § 13383. Monitoring requirements (a) The state board or a regional board may establish monitoring, inspection, entry, reporting, and recordkeeping requirements, as authorized by Sections 13160, 13376, or 13377 or by subdivisions (b) and (c) of this section, for any person who discharges, or proposes to discharge, to navigable waters, any person who introduces pollutants into a publicly owned treatment works, any person who owns or operates, or proposes to own or operate, a publicly owned treatment works or other treatment works treating domestic sewage, or any person who uses or disposes, or proposes to use or dispose, of sewage sludge.

(b) The state board or the regional boards may require any person subject to this section to establish and maintain monitoring equipment or methods, including, where appropriate, biological monitoring methods, sample effluent as prescribed, and provide other information as may be reasonably required.

(c) The state board or a regional board may inspect the facilities of any person subject to this section pursuant to the procedure set forth in subdivision (c) of Section 13267.

However, the proposed Permit allows that: *“In the event a certified laboratory is not available to the Discharger for any onsite field measurements such as pH, DO, turbidity, temperature, and residual chlorine, such analyses performed by a noncertified laboratory will be accepted provided a Quality Assurance-Quality Control Program is instituted by the laboratory.”* The Regional Board does not have the authority to simply ignore the law.

Thank you for considering these comments. If you have questions or require clarification, please don't hesitate to contact us.

Sincerely,

A handwritten signature in black ink, appearing to read "Bill Jennings". The signature is written in a cursive, flowing style with some loops and flourishes.

Bill Jennings, Executive Director
California Sportfishing Protection Alliance