

LATE REVISIONS
MOUNTAIN HOUSE COMMUNITY SERVICES DISTRICT
WASTEWATER TREATMENT PLANT
SAN JOAQUIN COUNTY
NPDES Permit Renewal (NPDES NO. CA0084271)
Regional Water Quality Control Board, Central Valley Region
Board Meeting – 31 January 2013
ITEM # 13

1. Limitations and Discharge Requirements – Effluent Limitations. Section IV.A.1.i. Final Effluent Limitations – Discharge Point No. 001

Modify section VI.A.1.i. to specify the effective date of the methylmercury effluent limitations, as shown in underline/strikeout format below:

- i. **Methylmercury. Effective 31 December 2030,** ~~the~~ effluent calendar annual methylmercury load shall not exceed 0.37 grams, in accordance with the Delta Mercury Control Program.

2. Limitations and Discharge Requirements – Special Provisions. Section VI.A.2.f. Standard Provisions

Modify section VI.A.2.f. to include a requirement to immediately notify downstream drinking water agencies if there are spills of untreated or partially treated wastewater from the Mountain House Community Services District Wastewater Treatment Plant or collection system that reach Delta waters, as shown in underline/strikeout format below:

- f. The Discharger shall take all reasonable steps to minimize any adverse effects to waters of the State or users of those waters resulting from any discharge or sludge use or disposal in violation of this Order. Reasonable steps shall include such accelerated or additional monitoring as necessary to determine the nature and impact of the non-complying discharge or sludge use or disposal, and adequate public notification to downstream water agencies or others whose contact is reasonably foreseeable with the non-complying discharge.

3. Limitations and Discharge Requirements – Compliance Determination. Section VII.E.

Remove section VII.E due to duplicate compliance determination language included in section VII.H, and renumber following sections.

- ~~**E. Priority Pollutant Effluent Limitations.** Compliance with effluent limitations for priority pollutants shall be determined in accordance with Section 2.4 (Reporting Requirements) of the State Water Board *Implementation of Toxic Standards for Inland Surface Waters, Enclosed Bays, and Estuaries of California Policy*, using sample reporting protocols defined in Attachment A and Attachment E of this Order. For purposes of reporting and administrative enforcement by the Central Valley Water Board and the State Water Board, the Discharger shall be deemed out of compliance with effluent limitations if the concentration of the priority pollutant in the monitoring sample is both greater than the effluent limitation and greater than or equal to the reporting level (RL).~~

4. Attachment I. Table I-1. Priority Pollutants and Other Constituents of Concern

Modify Table I-1 to include three new constituents, as shown in underline/strikeout format below, to correct an oversight in the proposed permit. Monitoring for these drinking water constituents is consistent with NPDES permits adopted by the Central Valley Water Board for other Sacramento-San Joaquin Delta dischargers and is needed to evaluate drinking water impacts of the discharge.

CTR #	Constituent	CAS Number	Maximum Reporting Level µg/L or noted
	<u>Total Organic Kjeldahl Nitrogen</u>		
	<u>Total Organic Carbon</u>		
	<u>Dissolved Organic Carbon</u>		