

CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
CENTRAL VALLEY REGION

ORDER NO. R5-

RESCINDING CEASE AND DESIST ORDERS AND TIME SCHEDULE ORDERS

- a. **Bear Valley Water District Wastewater Treatment Plant, Alpine County**
On 20 October 2005, the Central Valley Water Board adopted Time Schedule Order (TSO) R5-2005-0140 for the Bear Valley Water District Wastewater Treatment Plant (WWTP). The WWTP is owned and operated by the Bear Valley Water District (Discharger). The TSO required the Discharger to comply with iron and manganese effluent limitations by 1 October 2011. There has never been a discharge to Bloods Creek and therefore the Discharger could not collect effluent monitoring data. The Reasonable Potential Analysis in WDRs Order R5-2011-0053 concluded that the effluent would not violate iron and manganese limitations and therefore compliance with the effluent limitations is feasible. Because Order R5-2011-0053 concludes that compliance with iron and manganese is feasible and because TSO R5-2011-0054 does not include a compliance schedule for iron and manganese, Order R5-2005-0140 is no longer necessary.
- b. **City of Lodi White Slough Water Pollution Control Facility, San Joaquin County**
On 14 September 2007, the Central Valley Water Board adopted Time Schedule Order (TSO) R5-2007-0114 for the City of Lodi White Slough Water Pollution Control Facility. The facility is owned and operated by the City of Lodi (Discharger). The TSO required the Discharger to comply with effluent limitations for manganese, nitrate, and nitrite by 18 May 2010. The Discharger constructed modifications to the Water Pollution Control Facility, and as of 1 January 2010 complied with the effluent limitations for manganese, nitrate, and nitrite. Therefore, Order R5-2007-0114 is no longer necessary.
- c. **City of Woodland Wastewater Treatment Plant, Yolo County**
On 23 January 1998, the Central Valley Water Board adopted Cease and Desist Order (CDO) 98-022; on 13 March 2003, adopted CDO R5-2003-0032; and on 16 September 2005 adopted CDO R5-2003-0032-R01 for the City of Woodland Wastewater Treatment Plant (WWTP). The WWTP is owned and operated by the City of Woodland (Discharger). The CDOs required the Discharger to comply with effluent limitations for aluminum, biochemical oxygen demand, beryllium, total suspended solids, settleable solids, chlorine residual, oil and grease, organochlorine pesticides, total coliform organisms, total suspended solids, mercury, and bis(2-ethylhexyl)phthalate. In 2006 and 2007, the Discharger constructed tertiary filtration and ultraviolet disinfection. As of December 2007, the Discharger has achieved compliance with the limitations in all three Cease and Desist Orders. Therefore, Orders 98-021, R5-2003-0031, and R5-2003-0031-R01 are no longer necessary.
- d. **Lake County Sanitation District, Kelseyville County Water Works District No. 3 Wastewater Treatment Facility (WWTF), Lake County.** On 27 January 2005, the Central Valley Water Board issued Cease and Desist Order (CDO) R5-2005-0007 for the Lake County Sanitation District's Kelseyville County Water Works District No. 3

CDO/TSO Rescission

WWTF. The CDO was issued to address wastewater capacity problems that resulted in violations of Waste Discharge Requirements (WDRs) Order 99-094. The CDO required the Discharger to: (a) comply with the WDRs, (b) submit and implement emergency and short term contingency plans to prevent unauthorized discharges of wastewater, (c) submit an Inflow and Infiltration Assessment Report, (d) submit a Long Term Wastewater Master Plan, (e) submit a Report of Waste Discharge to allow the WDRs to be revised to reflect the proposed improvements to the WWTF, (f) submit a Revenue Plan, (g) submit a Sanitary Sewer System Operation, Maintenance, Overflow Prevention, and Response Plan, (h) submit a Groundwater Monitoring Well Installation Workplan and Report, and (i) submit semi-annual progress reports. The Discharger has completed all of the tasks in the CDO, and had upgraded the facility. New WDRs were adopted in 2009. Therefore, it is appropriate to rescind the Order.

- e. **Linda County Water District Wastewater Treatment Plant, Yuba County**
On 16 June 2000, the Central Valley Water Board adopted Cease and Desist Order (CDO) 5-00-166 for the Linda County Water District Wastewater Treatment Plant (WWTP). The CDO required the Discharger to disinfect the effluent waste stream discharged to the Feather River by 1 June 2005. The Discharger has achieved compliance by providing disinfection prior to discharge required by the CDO. Therefore, Order 5-00-166 is no longer necessary.
- f. **Mountain House Community Services District, Mountain House Wastewater Treatment Plant, San Joaquin County** . On 3 August 2012, the Central Valley Water Board adopted Time Schedule Order (TSO) R5-2012-0073 for the Mountain House Community Services District (Discharger), Mountain House Wastewater Treatment Plant (Facility). The TSO required the Discharger to comply with the effluent limitations for chlorodibromomethane and dichlorobromomethane specified in Waste Discharge Requirements (WDR) Order R5-2007-0039 by 23 June 2017. On 31 January 2013, the Central Valley Water Board adopted WDR Order R5-2013-0004 for the Facility and rescinded WDR Order R5-2007-0039. The new Order revised the final water quality-based effluent limitations for chlorodibromomethane and dichlorobromomethane. The Facility can immediately comply with the revised effluent limitations, therefore, a time schedule order is no longer needed.
- g. **Nevada County Sanitation District No. 1, Cascade Shores Wastewater Treatment Plant, Nevada County** On 23 August 2005, the Central Valley Water Board adopted Cleanup and Abatement Order (CAO) R5-2005-0714 and on 4 May 2006 adopted Cease and Desist Order (CDO) R5-2008-0112 for the Nevada County Sanitation District No. 1, Cascade Shores Wastewater Treatment Plant (WWTP). The CAO and CDO required the Discharger to relocate the wastewater treatment plant and to comply with effluent limitations for ammonia, nitrate, and total coliform organisms by 18 May 2010. The Discharger has achieved compliance by expending \$4.541 million on the relocation and construction of a new WWTP and as of June 2010, fully complies with the effluent limitations for ammonia, nitrate, and total coliform organisms in the WDRs. Therefore, Orders R5-2005-0714 and R5-2008-0112 are no longer necessary.

CDO/TSO Rescission

IT IS HEREBY ORDERED that the above Cease and Desist Orders and Time Schedule Orders are rescinded.

I, PAMELA C. CREEDON, Executive Officer, do hereby certify the foregoing is a full, true, and correct copy of an Order adopted by the California Regional Water Quality Control Board, Central Valley Region on April 12, 2013.

PAMELA C. CREEDON, Executive Officer