

**Regional Water Quality Control Board
Central Valley Region
Board Meeting – 30-31 May 2013**

**Response to Written Comments for Mariposa County,
Don Pedro Sewer Zone 1, Wastewater Treatment Facility
Tentative Waste Discharge Requirements**

At a public hearing scheduled for 30 and 31 May 2013, the Regional Water Quality Control Board, Central Valley Region, (Central Valley Water Board) will consider adoption of Waste Discharge Requirements (WDRs) for the Mariposa County (County) Don Pedro Sewer Zone 1, Wastewater Treatment Facility. This document contains responses to written comments received from interested parties regarding the Tentative WDRs (TWDRs) initially circulated on 26 March 2013. Written comments from interested parties were required by public notice to be received by the Central Valley Water Board by 26 April 2013 to receive full consideration. Comments were received by Central Valley Clean Water Association.

Written comments from the above interested party are summarized below, followed by the response of the Central Valley Water Board staff.

CENTRAL VALLEY CLEAN WATER ASSOCIATION (CVCWA) COMMENTS

CVCWA Letter – COMMENT No. 1: CVCWA states that the Provision in the TWDRs requiring the County to submit a Salinity Management Plan is too burdensome for a small community, and the requirement is inconsistent with CV-SALTS. CVCWA requests that Provision H.3. be deleted from the TWDRs.

RESPONSE: Staff agrees that in this particular case, the requirement to submit a Salinity Management Plan is unnecessary. Provision H.3. of the TWDRs has been deleted.