

LATE REVISIONS – 5/6 June 2014

Item ___ **Colusa Industrial Properties, Colusa County – Consideration of Revised Waste Discharge Requirements**

Waste Discharge Requirements:

Page 7 Revise paragraph 2 in Finding 23 as follows:

“However, the Colusa County Department of Planning and Building Administration has not approved a Use Permit for the biomass combustion plant, which means that it is still possible that the design of the plant could change significantly. Though an initial evaluation of wastewater’s volume and character indicates that CIP would have the capacity to accept wastewater from the plant without creating any significant threat to water quality, **the RWD did not adequately characterize the wastewater quality, and the design of the facility is still subject to change** ~~changes could potentially alter this conclusion.~~ Therefore, until the Colusa County Department of Planning and Building Administration approves a final design for the biomass plant and until the Board receives a **new or updated** RWD that **adequately** characterizes the volume and character of the wastewater generated by the plant, the Board will prohibit CIP from accepting this waste stream.”

Page 7 Revise Finding 25 as follows:

“The Discharger’s water balance demonstrates that similar wastewater flows to Pond 3 during the months of April ~~and~~ **through** October...”

Page 23 Revise the table in Flow Limitation B.2 as follows:

Flow Measurement	Flow Limit
Average Daily Flow ¹	5,500 6,400 GPD
Annual Flow ²	4.54 1.76 MG

Page 24 Revise the table in Flow Limitation B.3 as follows:

Flow Measurement	Flow Limit
Average Daily Influent Flow ¹ to Pond 3	0.02 0.03 MGD

Page 24 Revise the table in Flow Limitation B.4 as follows:

Flow Measurement	Flow Limit
Average Daily Flow ¹ to the 118-acre LAAs Fields 1 through 4	0.69 MGD

Page 30 Revise Land Application Area Specification F.8 as follows:

“Irrigation using process wastewater shall not be performed during rainfall or when the ground is saturated, except when applied for rice straw decomposition.

Application of process wastewater to rice fields for the purpose of rice straw decomposition is allowed from 1 November through 31 March.”

Page 34 Revise Provision I.2 as follows:

“If the Discharger wishes to accept wastewater from the biomass combustion plant for application to the LAAs, the Discharger shall submit a **new or updated** Report of Waste Discharge (RWD) **at least 6 months prior to the planned application of biomass wastewater to the LAAs...**The **new or updated** RWD shall include a description and analysis demonstrating that the new wastewater source will not cause violation of this Order including the groundwater limitations. The Discharger may not accept wastewater from the biomass combustion plant for application to the LAAs unless and until the Board revises these WDRs **following the submittal of the new or updated RWD**, ~~either by adding additional substantive provisions or by removing Prohibition 10, should additional modifications prove unnecessary to mitigate any threat to water quality.”~~

Information Sheet:

Page 1 Revise the last paragraph as follows:

“The Colusa County Department of Planning and Building Administration...Therefore, wastewater discharges from the biomass plant to CIP’s industrial wastewater disposal system are prohibited until approval of the Use Permit and submittal of an **new or updated** Report of Waste Discharge that completely characterizes the wastewater flow and quality...”

Page 6 Delete the Flow Limitations section (Paragraphs 1 through 4 on Page 6).

Page 8 Revise Paragraph 6 under the Provisions section as follows:

“If the Discharger wishes to accept wastewater from the biomass combustion plant for application to the LAAs, the Discharger shall submit evidence that the CEQA evaluation of the biomass plant has been completed and a **new or updated** Report of Waste Discharge **at least 1-year 6 months...**”