

CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
COLORADO RIVER BASIN REGION

ORDER NO. 78-74

WASTE DISCHARGE REQUIREMENTS
FOR
ROBERT W. & MARGRETE S. WALKER TRAILER PARK
GOLD ROCK TRADING POST
Northwest of Winterhaven - Imperial County

The California Regional Water Quality Control Board, Colorado River Basin Region, finds that:

1. R. W. and M.S. Walker (hereinafter also referred to as the discharger), P.O. Box 697 Gold Rock Trading Post, Winterhaven, CA 92283, submitted updated information on June 14, 1978, regarding the discharge of wastes.
2. The discharger proposes to discharge a maximum of 4,500 gallons-per-day of domestic sewage from a travel trailer park having 24 existing trailer spaces and 10 proposed trailer spaces. The wastewater is discharged through septic tank/leach field disposal systems located in the SW $\frac{1}{4}$, SE $\frac{1}{4}$ of Section 4, and the NW $\frac{1}{4}$, NE $\frac{1}{4}$ of Section 9, T15S, R20E, SBB&M.
3. The discharger has reserved areas of sufficient size for 100% replacement of each of the leach fields. These areas are designated on Attachment "A" incorporated herein and made a part of this Order.
4. The discharge of this travel trailer park has been subject to waste discharge requirements adopted in Board Order No. 71-30.
5. The Water Quality Control Plan for the West Colorado River Basin was adopted by the Board on April 10, 1975. The Basin Plan contains water quality objectives for the Amos-Ogilby Hydrologic Unit.
6. The beneficial use of the groundwaters of the Amos-Ogilby Hydrologic Unit is agricultural supply.
7. The discharger reports that depth to groundwater near the site is in excess of 400 feet.
8. The Board has notified the discharger and interested agencies and persons of its intent to update waste discharge requirements for the discharge.

*Rescinded
1/26/83
Jy 83-3*

9. The Board in a public meeting heard and considered all comments pertaining to the discharge.
10. This travel trailer park constitutes an ongoing project in accordance with provisions of the California Environmental Quality Act (Public Resources Code Section 21000 et seq.) and the State Guidelines because the governmental approvals on or after April 5, 1973, do not involve a greater degree of responsibility or control over such activity than the governmental approvals received prior to that date.

IT IS HEREBY ORDERED, the discharger shall comply with the following:

A. Discharge Specifications


1. Neither the treatment nor the discharge of wastewater shall create a pollution or a nuisance as defined in Division 7 of the California Water Code.
2. No wastewater other than domestic sewage shall be discharged at this location.
3. Sewage effluent discharged subsurface shall be retained underground with no surfacing.
4. There shall be no discharge of sewage within 200 feet of any domestic water well.
5. Adequate protective works shall be provided to assure that flood or surface drainage waters do not erode or otherwise render portions of the discharge facilities inoperable.
6. Septic tank cleanings shall be discharged only by a duly authorized service.

B. Provisions

1. The areas reserved for 100% replacement of the leach fields, as shown on Attachment "A" shall at all times be retained servient to this travel trailer park, for the purpose of providing additional subsurface sewage disposal capacity, until such time as this park is connected to a municipal sewerage system.


2. Upon request from this Board's Executive Officer, the discharger shall furnish technical and/or monitoring reports on the treatment and discharge of waste.
3. Prior to any modifications in this facility which would result in material change in the quality or quantity of wastewater discharged, or any material change in location of discharge, the discharger shall report in writing to the Regional Board.
4. Prior to any future change of ownership of this travel trailer park, the discharger shall:
 - a. Specify as a condition of transfer that said sewage disposal areas must remain servient to the park, for the purpose of providing subsurface sewage disposal capacity, until such time as this park is connected to a municipal sewerage system.
 - b. Notify the succeeding owner, in writing, of the existence of this Order, and forward a copy of said correspondence to the Regional Board.
5. This Order supersedes Board Resolution No. 71-30.

I, Arthur Swajian, Executive Officer, do hereby certify the foregoing is a full, true, and correct copy of an Order adopted by the California Regional Water Quality Control Board, Colorado River Basin Region, on September 27, 1978.



Executive Officer

CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD - 7




SITE MAP

ROBERT W. & MARGRETE S. WALKER TRAILER PARK
 GOLD ROCK TRADING POST
 Northwest of Winterhaven - Imperial County
 Location of Discharge: SW $\frac{1}{4}$, SE $\frac{1}{4}$ of Section 4, and NW $\frac{1}{4}$, NE $\frac{1}{4}$
 of Section 9, T15S, R20E, SBB&M
 USGS Ogilby 15 min. Topographic Map

Order No. 78-74

CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD - 7



ATTACHMENT A

ROBERT W. & MARGRETE S. WALKER TRAILER PARK
GOLD ROCK TRADING POST
Northwest of Winterhaven - Imperial County

Order No. 78-74