

CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
COLORADO RIVER BASIN REGION

ORDER NO. 82-18

WASTE DISCHARGE REQUIREMENTS
FOR
BERMUDA DUNES RECREATIONAL VEHICLE PARK
Bermuda Dunes - Riverside County

The California Regional Water Quality Control Board, Colorado River Basin Region, finds that:

1. Bermuda Dunes R.V. Park, c/o Mainiero, Smith & Associates, Inc. (hereinafter also referred to as the discharger), 2225 E. Tahquitz-McCallum Way, Palm Springs, California 92262, submitted a Report of Waste Discharge dated August 27, 1981.
2. The discharger proposes to discharge a maximum of 62,000 gallons-per-day of domestic sewage from a recreational vehicle park designed to have 333 spaces and a recreation building. The wastewater is to be discharged into septic tanks and seepage pits located in the SW 1/4 of the NE 1/4 of Section 8, T5S, R7E, SBB&M.
3. The discharger informs that dry sewers are to be installed along with the systems described in Finding No. 2 (above), to facilitate eventual connection to the proposed sewer line on Varner Road adjacent to the park.
4. The discharger is reserving areas of sufficient size for possible future 100 percent replacement of the seepage pits.
5. Wastewater from a swimming pool would be periodically discharged into a separate seepage pit.
6. There are no domestic wells within 200 feet of the proposed discharge facilities described in Findings No. 2 and 4 (above).
7. The Water Quality Control Plan for the West Colorado River Basin was adopted by the Board on April 10, 1975. The Basin Plan contains water quality objectives for the Coachella Hydrologic Subunit.
8. The beneficial uses of the groundwater of the Coachella Hydrologic Subunit are:
 - a. Municipal supply
 - b. Agricultural supply
 - c. Industrial supply

*Rescinded
by 86-51
7/9/86*

9. The Riverside County Planning Department has approved Negative Declaration CU No. 2552 (filing date October 1, 1981) for this proposed park. The Regional Board has reviewed this Negative Declaration. The below waste discharge requirements are designed to assure against any significant adverse effects on water quality.
10. The Board has notified the discharger and interested agencies and persons of its intent to prescribe waste discharge requirements for the proposed discharge.
11. The Board in a public meeting heard and considered all comments pertaining to the proposed discharge.

IT IS HEREBY ORDERED, the discharger shall comply with the following:

A. Discharge Specifications


1. Neither the treatment nor the discharge of wastewater shall create a pollution or a nuisance as defined in Division 7 of the California Water Code.
2. No wastewater other than domestic sewage and swimming pool wastewater shall be discharged at this location.
3. Sewage effluent discharged subsurface shall be retained underground with no surfacing.
4. Adequate measures shall be taken to assure that flood or surface drainage waters do not erode or otherwise render portions of the discharge facilities inoperable.
5. Septic tank cleanings shall be discharged only by a duly authorized service.
6. Swimming pool wastewater shall not be discharged into a sewage disposal system.

B. Provisions


1. Sufficient land area shall be reserved for possible future 100 percent replacement of the seepage pit fields until such time as this park is connected to a municipal sewerage system.
2. Upon request from this Board's Executive Officer, the discharger shall furnish technical and/or monitoring reports on the treatment and discharge of waste.
3. Prior to any modifications in this facility which would result in material change in the quality or quantity of wastewater discharged, or any material change in location of discharge, the discharger shall report in writing to the Regional Board.

4. Prior to any change of ownership of this recreational vehicle park, the discharger shall:
 - a. Specify as a condition of transfer that the area specified in Provision B.1. (above) remain servient to the development for the purpose of providing additional subsurface sewage disposal capacity, until such time as this development is connected to a municipal sewerage system.
 - b. Notify the succeeding owner, in writing, of the existence of this Order, and forward a copy of said correspondence to the Regional Board.

I, Arthur Swajian, Executive Officer, do hereby certify that the foregoing is a full, true and correct copy of an Order adopted by the California Regional Water Quality Control Board, Colorado River Basin Region, on March 24, 1982.


Executive Officer

CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD - 7



N.
Scale:
1" = 2,000'

SITE MAP
BERMUDA DUNES RECREATIONAL VEHICLE PARK
Bermuda Dunes - Riverside County
Portion of the SW 1/4, NE 1/4 of Section 8, T5S, R7E, SBB&M
USGS Myoma 7.5 min. Topographic Map

Order No. 82-18