

CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
COLORADO RIVER BASIN REGION

ORDER NO. 83-4

WASTE DISCHARGE REQUIREMENTS
FOR
RIVER VIEW TRAILER PARK
North of Earp - San Bernardino County

The California Regional Water Quality Control Board, Colorado River Basin Region, finds that:

1. Erle Holm, lessee and operator of River View Trailer Park, (hereinafter also referred to as the discharger), 4112 Highland Avenue, Manhattan Beach, CA 90266, has not submitted a report of waste discharge, which was requested by the Regional Board staff on the following three separate dates: August 23, 1982, September 29, 1982 and November 16, 1982. The park is located on land of the Colorado River Indian Tribes.
2. On August 19, 1982 the Board staff observed that two of three oxidation basins, which comprise the $\frac{1}{2}$ acre of sewage disposal facilities for the subject park, overflowed into the Colorado River during a recent storm.
3. The Board has determined that waste discharge requirements are necessary to insure prevention of unauthorized discharges to the Colorado River, which could result in degradation of water quality.
4. The discharger is discharging approximately 25,000 gallons-per-day of domestic sewage from a mobile home park having about 100 spaces. The oxidation basins are located in SE $\frac{1}{4}$ of the SE $\frac{1}{4}$ of Section 13, T1N, R25E, SBB&M.
5. There are no domestic wells within 200 feet of the sewage disposal facilities described in Findings No. 2 and 4 (above).
6. The Water Quality Control Plan for the East Colorado River Basin Region was adopted on April 10, 1975. The Basin Plan contains water quality objectives for the Colorado Hydrologic Unit.
7. The beneficial uses of the ground water of the Colorado Hydrologic Unit are:
 - a. Municipal supply
 - b. Industrial supply
 - c. Agricultural supply
8. The Board has notified the discharger and interested agencies and persons of its intent to prescribe waste discharge requirements for the discharge.

*replaced
by 88-080*

9. The Board in a public meeting heard and considered all comments pertaining to the discharge.
10. The issuance of waste discharge requirements for this discharge is exempt from the provisions of the California Environmental Quality Act (Public Resources Code, Section 21000 et. seq.) in accordance with Section 15101, Title 14, California Administrative Code.

IT IS HEREBY ORDERED, the discharger shall comply with the following:


A. Discharge Specifications

1. Neither the treatment nor the discharge of wastewater shall create a pollution or a nuisance as defined in Division 7 of the California Water Code.
2. No wastewater other than domestic sewage shall be discharged at this location.
3. A minimum freeboard depth of at least two feet shall be maintained in each basin.
4. Adequate measures shall be taken to assure that unauthorized persons and animal pets are effectively excluded from contact with the discharge.
5. Adequate protective works shall be provided to assure that a flood which would be expected to occur on a frequency of once in a 100 year period, would not erode or otherwise render portions of the treatment and discharge facilities inoperable.
6. Treated or untreated sludge, or similar solid waste materials, shall not be discharged to or enter any drainage channels or Colorado River.
7. There shall be no surface flow of wastewater away from the discharge facilities, and there shall be no direct discharge to any drainage channel or Colorado River.
8. Treatment and disposal by ponding shall be conducted in such manner that there shall be no stranded or exposed sewage solids.
9. Treatment and discharge of wastewater shall be conducted by technical procedures which will maintain a surface aerobic environment.
10. Infiltration facilities shall be maintained and operated so as to maximize infiltration and minimize the increase in salinity of the infiltrating wastewater.
11. Standby power and pumping facilities shall be provided in the event of pump and/or commercial power failure.

B. Provisions

1. By May 15, 1983, the discharger shall submit to the Regional Board for approval by the Executive Officer a technical report signed by a California Registered Civil Engineer, showing field data and proposed construction plans designed to meet Discharge Specifications A.3., A.5., A.7, and A.11.
2. By July 15, 1983, the discharger shall complete the construction approved in Provision No. B.1., (above) to the satisfaction of the Executive Officer and shall submit a certificate signed by a California Registered Civil Engineer stating that the wastewater facilities are constructed to meet Discharge Specifications A.3., A.5., A.7., and A.11.
3. Prior to any modifications in this facility which would result in material change in the quality or quantity of wastewater discharged, or any material change in location of discharge, the discharger shall report in writing to the Regional Board.
4. Upon request from this Board's Executive Officer the discharger shall furnish technical and/or monitoring reports on the treatment and discharge of waste.

I, Arthur Swajian, Executive Officer, do hereby certify the foregoing is a full, true and correct copy of an Order adopted by the California Regional Water Quality Control Board, Colorado River Basin Region, on March 16, 1983.


Executive Officer

**CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
COLORADO RIVER BASIN REGION**

**MONITORING AND REPORTING PROGRAM NO. 83-4
FOR
RIVER VIEW TRAILER PARK
North of Earp - San Bernardino County**

Location of Discharge: SE $\frac{1}{4}$ of SE $\frac{1}{4}$ of Section 13, T1N, R25E, SBB&M

MONITORING

The discharger shall submit an annual status report on the following:

1. Estimate of maximum daily flow (gpd) of sewage discharged to basin(s).
2. Number of mobile home and RV spaces and restrooms presently connected to the sewerage system.
3. List any proposed changes in the sewage disposal facilities during the upcoming year.

REPORTING

1. Monitoring reports shall be submitted to the Regional Board annually by January 15th of each year.

Submit monitoring reports to:

California Regional Water Quality Control Board
Colorado River Basin Region
73-271 Highway 111, Suite 21
Palm Desert, CA 92260


2. Immediately report to this office by telephone and follow-up by letter any failures of the sewerage system.

ORDERED BY:

Arthur Swajian
Executive Officer

Jan. 26, 1988
Date

CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD - 7



SITE MAP

RIVER VIEW TRAILER PARK
 Northeast of Earp - San Bernardino County
 SE 1/4 of the SE 1/4 of Section 13, T1N, R25E, SBB&M
 USGS Parker Ariz. - Calif. 15 min. Topographic Map

Order No. 83-4