

CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
COLORADO RIVER BASIN REGION

ORDER NO. 84-41

WASTE DISCHARGE REQUIREMENTS
FOR
BELL ENTERPRISES
Cabazon - Riverside County

The California Regional Water Quality Control Board, Colorado River Basin Region, finds that:

1. Claude K. Bell (hereinafter also referred to as the discharger), 50-800 Seminol Drive, Cabazon, California 92230, submitted a Report of Waste Discharge dated January 26, 1984.
2. The discharger is discharging a maximum of 2,400 gallons-per-month of domestic sewage from pumping out septic tanks, seepage pits, and grease trap containers from one restaurant.
3. The discharger discharges the waste (collected in a 1,000 gallon capacity tank truck) by uniformly spreading it over the surface of 5-acres of natural desert located in the SW $\frac{1}{4}$, NE $\frac{1}{4}$, SE $\frac{1}{4}$ of Section 9, T3S, R2E, SBB&M. The discharger states that the wastes are disked into the soil within 24 hours after spreading. This site has been in operation for more than 10 years, and is owned by the discharger.
4. This sewage disposal operation was cited by Riverside County Health Department in a letter to the discharger, dated January 18, 1984, requiring approval from the Regional Board before the discharge of wastes may continue.
5. The discharge area is underlain by recent alluvial fan deposits consisting of mainly rocks and coarse sand. The reported depth to the water table from records of nearby wells in the discharge area is approximately 100 feet below ground surface.
6. The Water Quality Control Plan for the West Colorado River Basin was adopted by the Board on April 10, 1975. The Basin Plan contains water quality objectives for the San Gorgonio Hydrologic Subunit.
7. The beneficial uses of the ground waters of the San Gorgonio Hydrologic Subunit are:
 - a. Municipal supply
 - b. Industrial supply
 - c. Agricultural supply

*Dispersed
by 89-012,
1/25/89*

8. The Board has notified the discharger and interested agencies and persons of its intent to prescribe waste discharge requirements for the discharge.
9. The Board in a public meeting heard and considered all comments pertaining to the discharge.
10. This sewage disposal site constitutes an ongoing project in accordance with provisions of the California Environmental Quality Act (Public Resources Code Section 21000 et. seq.) and the State Guidelines because the governmental approvals on or after April 5, 1973, do not involve a greater degree of responsibility or control over such activity than the governmental approvals received prior to that date.

IT IS HEREBY ORDERED, the discharger shall comply with the following:

A. Discharge Specifications


1. Neither the discharge of wastewater nor the discharge operation shall create a pollution or a nuisance as defined in Division 7 of the California Water Code.
2. No wastewater other than that specified in Finding No. 2 (above) shall be discharged at the designated land disposal site.
3. There shall be no discharge of sewage solids at the disposal site.
4. The disposal area shall be protected by natural or artificial features so as to assure protection from washouts and from inundation which could occur as a result of floods.
5. There shall be no surface exposure of wastes at the close of a day's operations.
6. There shall be no concentration of wastes within limited areas of the reported disposal site.
7. There shall be no ponding of discharged waste effluent, or surface flow of wastewater away from the designated disposal area.
8. The discharge shall not exceed 2,400 gallons-per-month.

B. Provisions

1. Prior to any substantial change in the quality or quantity of wastes to be discharged or the location of discharge, the discharger shall report in writing to the Regional Board.
2. The discharger shall comply with "Monitoring and Reporting Program No. 84-41", and future revisions thereto, as specified by the Executive Officer.

3. Prior to any proposed change in use, or in control or ownership of the land used as the discharge area, the discharger shall:
 - a. Notify this Board of such change; and
 - b. Transmit a copy of this Order to the succeeding owner or operator, and file a copy of the transmittal letter with this Board.
4. Nothing contained herein shall be construed to allow the discharger to discharge wastes onto any land which is not under his ownership or control.

I, Arthur Swajian, Executive Officer, do hereby certify the foregoing is a full, true and correct copy of an Order adopted by the California Regional Water Quality Control Board, Colorado River Basin Region, on March 21, 1984.



Executive Officer

CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
COLORADO RIVER BASIN REGION

MONITORING AND REPORTING PROGRAM NO. 84-41
FOR
BELL ENTERPRISES
Cabazon - Riverside County

Location of Discharge: SW $\frac{1}{4}$, NE $\frac{1}{4}$, SE $\frac{1}{4}$, Section 9, T3S, R2E, SBB&M

MONITORING

The discharger shall report to the Regional Board concerning the following:

ITEM

1. Volume of waste discharged during quarter. This information may be reported as the number of truck loads of specific gallonage.


REPORTING

The quarterly reports shall be submitted by January 15, April 15, July 15, and October 15 of each year.

Mail reports to:

California Regional Water Quality Control Board
Colorado River Basin Region
73-271 Highway 111, Suite 21
Palm Desert, CA 92260


ORDERED BY:


Executive Officer

March 21, 1984

Date

CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD - 7



SITE MAP

BELL ENTERPRISES
Cabazon - Riverside County
Portion of SW $\frac{1}{4}$, NE $\frac{1}{4}$, SE $\frac{1}{4}$ of Section 9, T3S, R2E, SBB&M
USGS Cabazon 7.5 min. Topographic Map

Order No. 84-41