

CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
COLORADO RIVER BASIN REGION

ORDER NO. 84-75

WASTE DISCHARGE REQUIREMENTS
FOR
McINTYRE PARK
South of Blythe - Riverside County

The California Regional Water Quality Control Board, Colorado River Basin Region, finds that:

1. Parks Department, County of Riverside (hereinafter also referred to as the discharger), P. O. Box 3507, Rubidoux, California, 92509, verified on March 26, 1984, that the below updated information is accurate.
2. The discharge from this campground has been subject to waste discharge requirements adopted in Board Order No. 74-53.
3. The discharger is discharging a maximum of 8,000 gallons-per-day of domestic sewage from a campground consisting of 1 mobile home space, 3 recreational vehicle spaces, 100 camp sites without hookups and two restrooms. Wastewater is discharged into septic tank/leach line disposal systems located in the SW $\frac{1}{4}$ of the SW $\frac{1}{4}$ of Section 34, T7S, R23E, SBB&M.
4. The discharger is reserving areas of sufficient size for possible future 100 percent replacement of leach lines.
5. There are no domestic wells within 200 feet of the discharge facilities described in Finding No. 3 (above).
6. The discharger states that the wastewater disposal facilities are more than 200 feet from the high water line of the Colorado River.
7. The Water Quality Control Plan for the Colorado River Basin Region of California was adopted on May 16, 1984. The Basin Plan contains water quality objectives for the Colorado Hydrologic Subunit.
8. The beneficial uses of ground water of the Colorado Hydrologic Subunit are:
 - a. Municipal supply
 - b. Industrial supply
 - c. Agricultural supply
9. The Board has notified the discharger and interested agencies and persons of its intent to update waste discharge requirements for the discharge.

Superseded
89-053
6/28/89

10. The Board in a public meeting heard and considered all comments pertaining to the discharge.
11. This campground constitutes an ongoing project in accordance with provisions of the California Environmental Quality Act (Public Resources Code Section 21000 et. seq.) and the state guidelines because the governmental approvals on or after April 5, 1973, do not involve a greater degree of responsibility or control over such activity than the governmental approvals received prior to that date.

IT IS HEREBY ORDERED, the discharger shall comply with the following:

A. Discharge Specifications


1. Neither the treatment nor the discharge of wastewater shall create a pollution or a nuisance as defined in Division 7 of the California Water Code.
2. No wastewater other than domestic sewage shall be discharged at this location.
3. Wastewater discharged subsurface shall be retained underground with no surfacing.
4. Adequate measures shall be taken to assure that flood or surface drainage waters do not erode or otherwise render portions of the discharge facilities inoperable.
5. Septic tank cleanings shall be discharged only by a duly authorized service.
6. There shall be no discharge of sewage within 200 feet of the regulated high water line of the Colorado River.

B. Provisions

1. Sufficient land area shall be reserved for possible future 100 percent replacement of the leach lines, until such time as this camp is connected to a municipal sewerage system.
2. Upon request from this Board's Executive Officer, the discharger shall furnish technical and/or monitoring reports on the treatment and discharge of wastes.
3. Prior to any modifications in this facility which would result in material change in the quality or quantity of wastewater discharged, or any material change in location of discharge, the discharger shall report in writing to the Regional Board.


4. Prior to any change of ownership of this campground, the discharger shall:
 - a. Specify as a condition of transfer that the area specified in Provision B.1. (above) remain servient to the park for the purpose of providing additional subsurface sewage disposal capacity, until such time as this park is connected to a municipal sewerage system.
 - b. Transmit a copy of this Order to the succeeding owner or operator, and file a copy of the transmittal letter with this Board.
5. This Order supersedes Board Order No. 74-53.

I, Arthur Swajian, Executive Officer, do hereby certify the foregoing is a full, true and correct copy of an Order adopted by the California Regional Water Quality Control Board, Colorado River Basin Region, on June 20, 1984.



Executive Officer

CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD -7



SITE MAP
McINTYRE PARK
South of Blythe - Riverside County
Portion of the SW $\frac{1}{4}$, SW $\frac{1}{4}$ of Section 34, T7S, R23E, SBB&M
USGS Blythe, CA. - Ariz. 7.5 min. Topographic Map