



EDMUND G. BROWN JR.
GOVERNOR

MATTHEW RODRIGUEZ
SECRETARY FOR
ENVIRONMENTAL PROTECTION

State Water Resources Control Board

Division of Drinking Water

August 5, 2016
Certified Mail/Return
7012 3460 0003 1112 7741

Valley View Conservation Camp
P.O. Box 27
Elk Creek, CA 95939

Attention: Randy Fregoso

Subject: Public Water System No. 1110800 – Citation No. 21-16C-019 for failing to monitor and report dual TTHM and HAA5 samples in 2014.

The Valley View Conservation Camp (Valley View C.C.) water system is classified as a nontransient - noncommunity water system. Per Section 64534.2(d)(1), Title 22, of the California Code of Regulations (CCR), Valley View C.C. is required to collect and report one dual sample set triennially for total trihalomethanes (TTHM) and haloacetic acids (HAA5) analysis. The water system did not collect and report this sample in August of 2014 pursuant to the water system's Stage 2 DBP Monitoring Plan.

Therefore, this Citation is hereby issued to the water system for violating the monitoring and reporting requirements per the California Code of Regulations cited above. **Please take note of the time sensitive directives within this citation.**

Section 116577 of the California Safe Drinking Water Act provides for the department to be reimbursed by the public water system for costs incurred for preparing and issuing a citation. The billing rate is approximately \$153 per hour. You will receive a bill for this cost, typically by September 1st, from our Fee Billing Unit in Sacramento.

If you have any questions please call Paul Rowe at (530) 224-4866. You may also contact me directly at (530) 224-4861.

Handwritten signature of Reese B. Crenshaw.

Reese B. Crenshaw, P.E.
Valley District Engineer
DRINKING WATER FIELD
OPERATIONS BRANCH

Enclosures

FELICIA MARCUS, CHAIR | THOMAS HOWARD, EXECUTIVE DIRECTOR

364 Knollcrest Drive, Suite 101, Redding, CA 96002 | www.waterboards.ca.gov

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26

Citation No. 21-16C-019

STATE WATER RESOURCES CONTROL BOARD
DIVISION OF DRINKING WATER

Public Water System: Valley View C.C.
Water System No.: 1110800

To: Valley View C.C.
Attn: Randy Fregoso
P.O. Box 27
Elk Creek, CA 95939

Issued: August 4, 2016
VIA CERTIFIED MAIL

CITATION FOR NONCOMPLIANCE
with Title 22 California Code of Regulations
Section 64534

Section 116650 of the California Health and Safety Code (CHSC) authorizes the issuance of a citation for failure to comply with a requirement of the California Safe Drinking Water Act (CHSC, Division 104, Part 12, Chapter 4, commencing with Section 116270), or any regulation, standard, permit, or order issued thereunder.

1 The State Water Resources Control Board, acting by and through its Division of
2 Drinking Water (hereinafter "Division") and the Deputy Director for the Division,
3 hereby issues a citation to Valley View C.C. for failure to comply with Section
4 64534.2(d)(1), Title 22, of the California Code of Regulations (CCR).

5
6 **APPLICABLE AUTHORITIES**

7 Section 116650 of the CHSC states:

8
9 *(a) If the department determines that a public water system is in violation*
10 *of this chapter or any regulation, permit, standard, citation, or order*
11 *issued or adopted thereunder, the department may issue a citation to*
12 *the public water system. The citation shall be served upon the public*
13 *water system personally or by certified mail. Service shall be deemed*
14 *effective as of the date of personal service or the date of receipt of*
15 *the certified mail. If a person to whom a citation is directed refuses to*
16 *accept delivery of the certified mail, the date of service shall be*
17 *deemed to be the date of mailing.*

18
19 *(b) Each citation shall be in writing and shall describe the nature of the*
20 *violation or violations, including a reference to the statutory provision,*
21 *standard, order, citation, permit, or regulation alleged to have been*
22 *violated.*

23
24 *(c) A citation may specify a date for elimination or correction of the*
25 *condition constituting the violation.*
26

1 (d) A citation may include the assessment of a penalty as specified in
2 subdivision (e).

3
4 (e) The department may assess a penalty in an amount not to exceed
5 one thousand dollars (\$1,000) per day for each day that a violation
6 occurred, and for each day that a violation continues to occur. A
7 separate penalty may be assessed for each violation.
8
9

10 Section 64534.2(d)(1), Title 22, of the CCR states in relevant part:

11
12 (d) By the applicable date specified in Section 64530(d), and in lieu of
13 TTHM and HAA5 monitoring in subsection (a):

14
15 (1) Community and nontransient noncommunity water systems
16 shall monitor for TTHM and HAA5 at the frequencies and
17 location totals indicated in Table 64534.2-C and in accordance
18 with the monitoring plan developed pursuant to Section
19 64534.8;
20
21

22 **STATEMENT OF FACTS**

23 The Valley View C.C. (Water System) is classified as a nontransient - noncommunity
24 water system serving approximately 150 people. Per Table 64534.2-D of the CCR,
25 the Water System is required to collect and report one dual sample set every three
26 years for total trihalomethanes (TTHM) and haloacetic acids (HAA5) analysis. The

1 Water System developed a Stage 2 Disinfection Byproduct Rule (DBPR) monitoring
2 plan and submitted to the Division in February of 2014. The plan specifies the
3 collection of one dual sample set triennially in the month of August. The Water
4 System failed to collect and report this sample set in the year 2014.

6 DETERMINATIONS

7 The Division has determined that the Water System violated Section 64534.2(d)(1),
8 Title 22, of the CCR, in that the Water System failed to collect and report a dual
9 sample set of TTHM and HAA5 samples in August of 2014.

11 DIRECTIVES

12 The Water System is hereby directed to take the following actions:

- 13
14 1. Comply with Section 64534.2, Title 22, of the CCR in all future monitoring
15 periods.
- 16
17 2. The Water System must collect a dual sample set for trihalomethanes
18 (TTHM) and haloacetic acids (HAA5) analysis **by September 4, 2016, then**
19 **again in August of 2017. Thereafter, sampling may resume to triennial.**
- 20
21 3. The Water System shall provide public notification (by inclusion in the **2016**
22 **Consumer Confidence Report**) of the failure to collect and report a dual
23 sample set of TTHM and HAA5 samples in the year 2014. **Within 10 days**
24 **of providing notification**, the Water System shall submit the enclosed
25 proof of notification form (Attachment 1).
26

1 All documents required by this Citation to be submitted to the Division shall be
2 submitted to the following address:

3

4

5

Reese B. Crenshaw, P. E.

6

Valley District Engineer

7

Drinking Water Field Operations

8

Division of Drinking Water

9

State Water Resources Control Board

10

364 Knollcrest Drive, Suite 101

11

Redding, CA 96002

12

(530) 224-4800

13

14

Nothing in this Citation relieves the Water System of its obligation to meet the
15 requirements of Health and Safety Code, Division 104, Part 12, Chapter 4 (California
16 Safe Drinking Water Act), or any regulation, permit, standard or order issued or
17 adopted thereunder.

18

19

The Division reserves the right to make such modifications to this Citation, as it may
20 deem necessary to protect public health and safety. Such modifications may be
21 issued as amendments to this Citation and shall be effective upon issuance.

22

23

FURTHER ENFORCEMENT ACTION

24

The California SDWA authorizes the State Board to: issue citation with assessment of
25 administrative penalties to a public water system for violation or continued violation of
26 the requirements of the California SDWA or any permit, regulation, permit or order



1 issued or adopted thereunder including, but not limited to, failure to correct a violation
2 identified in a citation or compliance order. The California SDWA also authorizes the
3 State Board to take action to suspend or revoke a permit that has been issued to a
4 public water system if the system has violated applicable law or regulations or has
5 failed to comply with an order of the State Board; and to petition the superior court to
6 take various enforcement measures against a public water system that has failed to
7 comply with violates an order of the State Board. The State Board does not waive any
8 further enforcement action by issuance of this citation.

9

10 **PARTIES BOUND**

11 This Citation shall apply to and be binding upon the Water System, its officers,
12 directors, agents, employees, contractors, successors, and assignees.

13

14 **SEVERABILITY**

15 The directives of this Citation are severable, and the Water System shall comply with
16 each and every provision thereof notwithstanding the effectiveness of any other
17 provision.

18

19

20

21 R. Crenshaw

22 Reese B. Crenshaw, P.E., District Engineer
23 Valley District
24 Drinking Water Field Operations Branch

25

26 Attachments: Certification Form (Attachment 1)

8/4/16
Date



