



EDMUND G. BROWN JR.
GOVERNOR



MATTHEW RODRIQUEZ
SECRETARY FOR
ENVIRONMENTAL PROTECTION

State Water Resources Control Board

Division of Drinking Water

May 12, 2015
System No.: 2400170

Mr. Michael Kummer
Hilmar Cheese Company, Incorporated
Environmental Coordinator
P.O. Box 910
Hilmar, CA 95324

RE: Compliance Order No. 03-11-15R-006 Violation of Title 22, California Code of Regulations, Section 64431, Arsenic MCL

Dear Mr. Kummer:

The State Water Resources Control Board – Division of Drinking Water (Division) has issued Compliance Order No. 03-11-15R-006 to the Hilmar Cheese Company, Incorporated (Company) Water System, for violation of the Arsenic Maximum Contaminant Level (MCL). The compliance order is enclosed.

As required in the Compliance Order, the Company is expected to propose a solution and implement a project to ensure that water delivered to customers meets the arsenic MCL. It is noted that the Company is collecting samples of the treated water on a weekly basis. The Company is required to provide quarterly public notification for the arsenic MCL violation and to continue quarterly arsenic monitoring at the sources of supply.

The Company will be billed at the Division's hourly rate (currently estimated at \$128.00) for the time spent on issuing this Compliance Order. The California Health and Safety Code Section 116577 provides that a public water system must reimburse the Division for actual costs incurred by the Division for specified enforcement actions, including but not limited to, preparing, issuing and monitoring compliance with an order. At this time, the Division has spent approximately two hours on enforcement activities associated with this violation.

The Company will receive a bill sent from the Division of Drinking Water Fee Billing Unit in August of the next fiscal year. This bill will contain fees for any enforcement time spent on the Company for the current fiscal year. If you have any questions regarding this matter, please contact me at (559) 447-3316.

Sincerely,

Kassy D. Chauhan, P.E.
Senior Sanitary Engineer,
Merced District
Division of Drinking Water

CLC/KDC/mlm
Enclosures

cc: Merced County Environmental Health Department (w/o attachments)

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27

**STATE OF CALIFORNIA
WATER RESOURCES CONTROL BOARD
DIVISION OF DRINKING WATER**

IN RE: **HILMAR CHEESE COMPANY, INCORPORATED**
Water System No. 2400170

TO: Mr. Michael Kummer
Environmental Coordinator
P.O. Box 910
Hilmar, CA 95324

CC: Merced County Environmental Health Department

COMPLIANCE ORDER NO. 03-11-15R-006

**FOR
VIOLATION OF THE HEALTH AND SAFETY CODE SECTION 116655 (A)(1) AND
THE PRIMARY DRINKING WATER STANDARD FOR ARSENIC**

Issued on May 12, 2015

The State Water Resources Control Board (hereinafter "Board"), acting by and through its Division of Drinking Water (hereinafter "Division") and the Deputy Director for the Division (hereinafter "Deputy Director"), hereby issues a compliance order to the Hilmar Cheese Company, Incorporated (hereinafter "Company") (9001 North Lander Avenue Hilmar CA 95324) for violation of California Code of Regulations (CCR), Title 22, Section 64431.

1 **APPLICABLE AUTHORITIES**

2 The applicable statutes and regulations are provided in Attachment A, attached hereto
3 and incorporated by reference.
4

5 **STATEMENT OF FACTS**

6 The Hilmar Cheese Company is a nontransient-noncommunity water system located in
7 Merced County. The Company serves water to the cheese processing operations and
8 domestic use through four (4) service connections. The Company has a population of
9 1,000 employees for more than six months of the year. The sources of supply for the
10 domestic water supply system are two wells (Wells Nos. 4 and 5).
11

12
13 Prior to April 1, 2014, jurisdiction for regulatory oversight of the Company was
14 maintained by the Merced County Environmental Health Department (County). Effective
15 April 1, 2014, jurisdiction oversight of the Company was transferred to the Division.
16
17

18 Beginning on January 23, 2006, the U.S. Environmental Protection Agency (USEPA)
19 adopted a revised maximum contaminant level (MCL) for arsenic of 0.010 mg/L
20 (milligrams per liter). The arsenic MCL of 0.010 mg/L was adopted for California and
21 became effective on November 28, 2008. Prior to this date, any non-compliance issues
22 were referred to U.S. EPA for enforcement action.
23
24
25
26
27

1 As shown in Table 1 below, the water produced by Wells Nos. 4 and 5 contains levels of
2 arsenic in excess of the MCL. The current running annual average (RAA) for Wells Nos.
3 4 and 5 are 32.0 and 148 ug/l, respectively.
4

5 Table 1 – Raw Water Arsenic Levels

6

7 Sample Date	Well No. 4 (2400170-13)	Well No.5 (2400170-016)
8 May 2014	34.0 ug/l	140.0 ug/l
9 September 2014	34.0 ug/l	150.0 ug/l
10 Nov – Dec 2014	30.0 ug/l	150.0 ug/l
11 March 2015	31.0 ug/l	150.0 ug/l
12 Running Annual Average(RAA)	32.0 ug/l	148 ug/l

13

14
15 In December 2010, the County approved the addition of Well No. 5 and the ATEC
16 Arsenic Treatment Plant to the water system. Prior to this date, the Company was
17 blending water from Well No. 4 with Wells Nos. 1 and 3 to meet the arsenic MCL. By
18 October 2008, Well No. 3 was taken offline due to high nitrate levels. By the time the
19 ATEC arsenic treatment plant was approved, Well No. 1 was taken offline. Well No. 1
20 was failing and contained nitrate levels that were over half of the MCL.
21

22
23 The ATEC treatment plant was installed and on-line starting January 11, 2011. The
24 Company monitors the ATEC plant's effluent for arsenic RAA on a weekly basis as
25 summarized in Attachment E. A review of the ATEC Plant's summarized arsenic RAA
26 revealed that the ATEC's effluent did not come into compliance until March 2012. In
27

1 March 2013 through February 2014, the arsenic RAA was in excess of the MCL. For the
2 most part, the Company maintained the arsenic RAA less than the MCL in months of
3 March 2014 through January 2015. By early February 2015 through March 2015, the
4 Company has exceeded the arsenic MCL.

5
6 Based on this information, the Company has failed to operate the arsenic removal
7 treatment plant in accordance with the operations plan to reliably produce water with
8 arsenic concentrations less than the MCL. Therefore, the Company continues to be out
9 of compliance with the arsenic MCL.
10

11 12 **DETERMINATIONS**

13 Based on the above Statement of Facts, the Division has determined that the Company
14 has violated CHSC, Section 116555 and provisions contained in Title 22, California
15 Code of Regulations (CCR) Section 64431 (a). Specifically, the treated water produced
16 by the Company exceeds the maximum contaminant level of 0.010 mg/L for arsenic,
17 and therefore, does not comply with a primary drinking water standard.
18

19 20 **DIRECTIVES**

21 The Company is hereby directed to take the following actions:

- 22
23
24 1. On or before December 31, 2015, comply with Title 22, CCR, Section 64431 and
25 remain in compliance.
26
27

1 2. On or before June 30, 2015, submit a written response to the Division indicating its
2 agreement to comply with the directives of this Order and with the Corrective Action
3 Plan addressed herein.

4
5 3. Commencing on the date of service of this Order, continue to provide quarterly
6 public notification in accordance with Attachment B, hereto, of the Company's failure to
7 meet the arsenic MCL during any calendar quarter that the four-quarter running annual
8 average exceeds the MCL.
9

10
11 4. Commencing on the date of service of this Order, submit proof of each public
12 notification conducted in compliance with Directive No. 3, herein above, within 10 days
13 following each such notification, using the form provided as Attachment C, hereto.
14

15
16 5. Commencing on the date of service of this Order continue to collect quarterly
17 samples for arsenic from each well, as required by Section 64432(g), and ensure that
18 the analytical results are reported to the Division electronically by the analyzing
19 laboratory no later than the 10th day following the month in which the analysis was
20 completed.
21

22
23 6. Commencing on the date of service of this Order continue to collect weekly samples
24 for arsenic from the treated water, as required by Section 64432.8 (a), and ensure that
25 the analytical results are reported to the Division electronically by the analyzing
26
27

1 laboratory no later than the 10th day following the month in which the analysis was
2 completed.

3
4 7. Prepare for the Division's approval a Corrective Action Plan identifying
5 improvements to the existing arsenic treatment plant to correct the water quality
6 problem (violation of the arsenic MCL) and ensure that the Company delivers water to
7 consumers that meets primary drinking water standards. The plan shall include a time
8 schedule for completion of various phases of the project such as modification to the
9 existing treatment plant per manufacturer's recommendations and a date as of which
10 the Company will be in compliance with the arsenic MCL, which date shall be no later
11 than December 31, 2015.
12

13
14 8. On or before July 31, 2015, provide the Corrective Action Plan required under
15 Directive No. 6, above, to the Division.
16

17
18 9. Timely perform the Division approved Corrective Action Plan and each and every
19 element of said plan according to the time schedule set forth therein.
20

21 10. On or before July 31, 2015 and every month thereafter, submit a report to the
22 Division in the form provided as Attachment D, hereto, showing actions taken during the
23 previous calendar month to comply with the Corrective Action Plan.
24
25
26
27

1 11. Not later than ten (10) days following the date of compliance with the arsenic MCL,
2 demonstrate to the Division that the water delivered by the Company complies with the
3 arsenic MCL.

4
5 12. Notify the Division in writing no later than five (5) days prior to the deadline for
6 performance of any Directive set forth herein if the Company anticipates it will not timely
7 meet such performance deadline.
8

9
10 All submittals required by this Order shall be addressed to:

11 Kassy D. Chauhan, P.E.
12 Senior Sanitary Engineer, Merced District
13 State Water Resources Control Board
14 Division of Drinking Water
15 265 W. Bullard Avenue, Suite 101
16 Fresno, CA 93704
17

18
19 As used in this Order, the date of issuance shall be the date of this Order; and the date
20 of service shall be the date of service of this Order, personal or by certified mail, on the
21 Company.
22

23
24 The Division reserves the right to make such modifications to this Order and/or to issue
25 such further order(s) as it may deem necessary to protect public health and safety.
26
27

1 Such modifications may be issued as amendments to this Order and shall be deemed
2 effective upon issuance.

3
4 Nothing in this Order relieves the Company of its obligation to meet the requirements of
5 the California SDWA, or any regulation, standard, permit or order issued thereunder.
6

7
8 **PARTIES BOUND**

9 This Order shall apply to and be binding upon the Hilmar Cheese Company
10 Incorporated, its officers, directors, agents, employees, contractors, successors, and
11 assignees.
12

13
14 **SEVERABILITY**

15 The Directives of this Order are severable, and the Hilmar Cheese Company
16 Incorporated shall comply with each and every provision thereof notwithstanding the
17 effectiveness of any provisions.
18

19
20 **FURTHER ENFORCEMENT ACTION**

21 The California SDWA authorizes the Board to: issue a citation with assessment of
22 administrative penalties to a public water system for violation or continued violation of
23 the requirements of the California SDWA or any regulation, permit, standard, citation, or
24 order issued or adopted thereunder including, but not limited to, failure to correct a
25 violation identified in a citation or compliance order. The California SDWA also
26 authorizes the Board to take action to suspend or revoke a permit that has been issued
27

1 to a public water system if the public water system has violated applicable law or
2 regulations or has failed to comply with an order of the Board; and to petition the
3 superior court to take various enforcement measures against a public water system that
4 has failed to comply with an order of the Board. The Board does not waive any further
5 enforcement action by issuance of this Order.
6
7
8

9 

5-12-2015
Date

10 Carl Carlucci, P.E., Chief
11 Central California Section
12 State Water Resources Control Board
13 Division of Drinking Water

14 Certified Mail No. 7010 3090 0002 0396 4154



16 Cc: Merced County Environmental Health (w/o attachments)

17 CLC/KDC/mlm
18
19

20 Attachments:

21 Attachment A: Applicable Authorities

22 Attachment B: Public Notification Notice

23 Attachment C: Proof of Notification Form

24 Attachment D: Monthly Progress Report Form

25 Attachment E: Summary of Arsenic RAA
26
27

Applicable Statutes and Regulations for Citation No. 03-11-15R-006

Section 116655 of the CHSC states in relevant part:

(a) Whenever the department determines that any person has violated or is violating this chapter, or any permit, regulation, or standard issued or adopted pursuant to this chapter, the director may issue an order doing any of the following:

- (1) Directing compliance forthwith.
- (2) Directing compliance in accordance with a time schedule set by the department.
- (3) Directing that appropriate preventive action be taken in the case of a threatened violation.

(b) An order issued pursuant to this section may include, but shall not be limited to, any or all of the following requirements:

- (1) That the existing plant, works, or system be repaired, altered, or added to.
- (2) That purification or treatment works be installed.
- (3) That the source of the water supply be changed.
- (4) That no additional service connection be made to the system.
- (5) That the water supply, the plant, or the system be monitored.
- (6) That a report on the condition and operation of the plant, works, system, or water supply be submitted to the department.

Section 64431 of Title 22, California Code of Regulations (CCR) states in relevant part:

§64431. Maximum Contaminant Levels-Inorganic Chemicals.

Public water systems shall comply with the primary MCLs in table 64431-A as specified in this article.

**Table 64431-A
Maximum Contaminant Levels
Inorganic Chemicals**

<i>Chemical</i>	<i>Maximum Contaminant Level, mg/L</i>
Aluminum	1.
Antimony	0.006
Arsenic	0.010
Asbestos	7 MFL*
Barium	1.
Beryllium	0.004
Cadmium	0.005
Chromium	0.05
Cyanide	0.15
Fluoride	2.0
Hexavalent chromium	0.010
Mercury	0.002
Nickel	0.1
Nitrate (as NO ₃)	45.
Nitrate+Nitrite (sum as nitrogen)	10.
Nitrite (as nitrogen)	1.
Perchlorate	0.006
Selenium	0.05
Thallium	0.002

* MFL=million fibers per liter, MCL for fibers exceeding 10 um in length.

Section 64463.4 of Title 22, California Code of Regulations (CCR) states in relevant part:
§64463.4. Tier 2 Public Notice.

- (a) A water system shall give public notice pursuant to this section if any of the following occurs:
- (1) Any violation of the MCL, MRDL, and treatment technique requirements, except:
 - (A) Where a Tier 1 public notice is required under section 64463.1; or
 - (B) Where the Department determines that a Tier 1 public notice is required, based on potential health impacts and persistence of the violations;

.....

- (3) Other violations of the monitoring and testing procedure requirements in this chapter, and chapters 15.5, 17 and 17.5, for which the Department determines that a Tier 2 rather than a Tier 3 public notice is required, based on potential health impacts and persistence of the violations; or
- (4) Failure to comply with the terms and conditions of any variance or exemption in place.

- (b) A water system shall give the notice as soon as possible within 30 days after it learns of a violation or occurrence specified in subsection (a), except that the water system may request an extension of up to 60 days for providing the notice. This extension would be subject to the Department's written approval based on the violation or occurrence having been resolved and the Department's determination that public health and welfare would in no way be adversely affected. In addition, the water system shall:

- (1) Maintain posted notices in place for as long as the violation or occurrence continues, but in no case less than seven days;
- (2) Repeat the notice every three months as long as the violation or occurrence continues. Subject to the Department's written approval based on its determination that public health would in no way be adversely affected, the water system may be allowed to notice less frequently but in no case less than once per year. No allowance for reduced frequency of notice shall be given in the case of a total coliform MCL violation or violation of a Chapter 17 treatment technique requirement; and

.....

- (c) A water system shall deliver the notice, in a manner designed to reach persons served, within the required time period as follows:

- (1) Unless otherwise directed by the Department in writing based on its assessment of the violation or occurrence and the potential for adverse effects on public health and welfare, community water systems shall give public notice by:
 - (A) Mail or direct delivery to each customer receiving a bill including those that provide their drinking water to others (e.g., schools or school systems, apartment building owners, or large private employers), and other service connections to which water is delivered by the water system; and
 - (B) Use of one or more of the following methods to reach persons not likely to be reached by a mailing or direct delivery (renters, university students, nursing home patients, prison inmates, etc.):
 1. Publication in a local newspaper;

2. Posting in conspicuous public places served by the water system, or on the Internet; or
 3. Delivery to community organizations.
- (2) Unless otherwise directed by the Department in writing based on its assessment of the violation or occurrence and the potential for adverse effects on public health and welfare, noncommunity water systems shall give the public notice by:
- (A) Posting in conspicuous locations throughout the area served by the water system; and
 - (B) Using one or more of the following methods to reach persons not likely to be reached by a public posting:
 1. Publication in a local newspaper or newsletter distributed to customers;
 2. E-mail message to employees or students;
 3. Posting on the Internet or intranet; or
 4. Direct delivery to each customer.

Section 64465. of Title 22, California Code of Regulations (CCR) states in relevant part:

§64465. Public Notice Content and Format.

- (a) Each public notice given pursuant to this article, except Tier 3 public notices for variances and exemptions pursuant to subsection (b), shall contain the following:
- (1) A description of the violation or occurrence, including the contaminant(s) of concern, and (as applicable) the contaminant level(s);
 - (2) The date(s) of the violation or occurrence;
 - (3) Any potential adverse health effects from the violation or occurrence, including the appropriate standard health effects language from appendices 64465-A through G;
 - (4) The population at risk, including subpopulations particularly vulnerable if exposed to the contaminant in drinking water;
 - (5) Whether alternative water supplies should be used;
 - (6) What actions consumers should take, including when they should seek medical help, if known;
 - (7) What the water system is doing to correct the violation or occurrence;
 - (8) When the water system expects to return to compliance or resolve the occurrence;
 - (9) The name, business address, and phone number of the water system owner, operator, or designee of the water system as a source of additional information concerning the public notice;
 - (10) A statement to encourage the public notice recipient to distribute the public notice to other persons served, using the following standard language: "Please share this information with all the other people who drink this water, especially those who may not have received this public notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this public notice in a public place or distributing copies by hand or mail"; and
 - (11) For a water system with a monitoring and testing procedure violation, this language shall be included: "We are required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not your drinking water meets health standards. During [compliance period dates], we [did not monitor or test' or 'did not complete all monitoring or testing'] for [contaminant(s)], and therefore, cannot be sure of the quality of your drinking water during that time."

.....

- (c) Each public notice given pursuant to this article shall contain information in Spanish regarding the importance of the notice, or contain a telephone number or address where Spanish-speaking residents may contact the water system to obtain a translated copy of the public notice or assistance in Spanish. For each non-English speaking group other than Spanish-speaking that exceeds 1,000 residents or 10% of the residents in the community served, whichever is less, the public notice shall:
 - (1) Contain information in the appropriate language(s) regarding the importance of the notice, or
 - (2) Contain a telephone number or address where such residents may contact the water system to obtain a translated copy of the notice or assistance in the appropriate language.
- (d) Each public notice given pursuant to this article shall:
 - (1) Be displayed such that it catches people's attention when printed or posted and be formatted in such a way that the message in the public notice can be understood at the eighth-grade level;
 - (2) Not contain technical language beyond an eighth-grade level or print smaller than 12 point; and
 - (3) Not contain language that minimizes or contradicts the information being given in the public notice.

Instructions for Tier 2 Arsenic MCL Notice Template

Template Attached

Since exceeding the arsenic maximum contaminant level (MCL) is a Tier 2 violation, you must provide public notice to persons served as soon as practical but within 30 days after you learn of the violation [California Code of Regulations Title 22, Chapter 15, Section 64463.4(b)]. **Each water system required to give public notice must submit the notice to the Department for approval prior to distribution or posting, unless otherwise directed by the Department [64463(b)].**

Notification Methods

You must use the methods summarized in the table below to deliver the notice to consumers. If you mail, post, or hand deliver, print your notice on letterhead, if available.

<i>If You Are a...</i>	<i>You Must Notify Consumers by...</i>	<i>...and By One or More of the Following Methods to Reach Persons Not Likely to be Reached by the Previous Method...</i>
Community Water System [64463.4(c)(1)]	Mail or direct delivery ^(a)	Publication in a local newspaper
		Posting in public places served by the water system or on the Internet ^(b)
		Delivery to community organizations
Non-Community Water System [64463.4(c)(2)]	Posting in conspicuous locations throughout the area served by the water system ^(b)	Publication in a local newspaper or newsletter distributed to customers
		Email message to employees or students
		Posting on the Internet or intranet ^(b)
		Direct delivery to each customer

(a) Notice must be distributed to each customer receiving a bill including those that provide their drinking water to others (e.g., schools or school systems, apartment building owners, or large private employers), and other service connections to which water is delivered by the water system.

(b) Notice must be posted in place for as long as the violation or occurrence continues, but in no case less than seven days.

The notice attached is appropriate for the methods described above. However, you may wish to modify it before using it for posting. If you do, you must still include all the required elements and leave the health effects and notification language in italics unchanged. This language is mandatory [64465].

Multilingual Requirement

Spanish. Each public notice must contain information in Spanish regarding (1) the importance of the notice or (2) contain a telephone number or address where Spanish-

Attachment B

speaking residents may contact the water system to obtain a translated copy of the public notice or assistance in Spanish.

Non-English Speaking Groups Other than Spanish-Speaking. For each group that exceeds 1,000 residents or 10% of the residents in the community served, whichever is less, the public notice must (1) contain information in the appropriate language(s) regarding the importance of the notice or (2) contain a telephone number or address where such residents may contact the water system to obtain a translated copy of the notice or assistance in the appropriate language.

Population Served

Make sure it is clear who is served by your water system -- you may need to list the areas you serve.

Corrective Action

In your notice, describe corrective actions you are taking. Do not use overly technical terminology when describing treatment methods. Listed below are some steps commonly taken by water systems with chemical or radiological violations. Use one or more of the following actions, if appropriate, or develop your own:

- “We are working with [local/state agency] to evaluate the water supply and researching options to correct the problem. These options may include treating the water to remove arsenic or connecting to [system]’s water supply.”
- “We have stopped using the contaminated well. We have increased pumping from other wells, and we are investigating drilling a new well.”
- “We will increase the frequency at which we test the water for arsenic.”
- “We have since taken samples at this location and had them tested. They show that we meet the standards.”

After Issuing the Notice

Send a copy of each type of notice and a certification that you have met all the public notice requirements to the Department within ten days after you issue the notice [64469(d)]. You should also issue a follow-up notice in addition to meeting any repeat notice requirements the Department sets.

It is recommended that you notify health professionals in the area of the violation. People may call their doctors with questions about how the violation may affect their health, and the doctors should have the information they need to respond appropriately.

It is a good idea to issue a “problem corrected” notice when the violation is resolved.

IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

Este informe contiene información muy importante sobre su agua potable.
Tradúzcalo o hable con alguien que lo entienda bien.

Hilmar Cheese Has Levels of Arsenic Above the Drinking Water Standard

Our water system recently violated a drinking water standard. Although this is not an emergency, as our customers, you have a right to know what you should do, what happened, and what we are doing to correct this situation.

We routinely monitor for the presence of drinking water contaminants. Water sample results received on _____ showed arsenic levels of _____. This is above the U.S. EPA standard, or maximum contaminant level (MCL) of 0.010 milligrams per liter.

What should I do?

- **You do not need to use an alternative water supply (e.g., bottled water).**
- This is not an emergency. If it had been, you would have been notified immediately. However, *some people who drink water containing arsenic in excess of the MCL over many years may experience skin damage or circulatory system problems, and may have an increased risk to getting cancer.*
- If you have other health issues concerning the consumption of this water, you may wish to consult your doctor.

What happened? What is being done?

[Describe corrective action]. We anticipate resolving the problem within [estimated time frame].

For more information, please contact [name of contact] at [phone number] or [mailing address].

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this public notice in a public place or distributing copies by hand or mail.

Secondary Notification Requirements

Upon receipt of notification from a person operating a public water system, the following notification must be given within 10 days [Health and Safety Code Section 116450(g)]:

Attachment B

- SCHOOLS: Must notify school employees, students, and parents (if the students are minors).
- RESIDENTIAL RENTAL PROPERTY OWNERS OR MANAGERS (including nursing homes and care facilities): Must notify tenants.
- BUSINESS PROPERTY OWNERS, MANAGERS, OR OPERATORS: Must notify employees of businesses located on the property.

This notice is being sent to you by [system].

State Water System ID#: _____. Date distributed: _____.

Certification of Completion of Public Notification

This form, when completed and returned to the Division of Drinking Water - Fresno District (265 W. Bullard Ave. #101, Fresno, CA 93704 or fax to 559-447-3304), serves as certification that public notification to water users was completed as required by Title 22, California Code of Regulations, Sections 64463-64465.

Public Water System Name: _____

Public Water System No.: _____

Public notification for failure to comply with the Arsenic MCL for the quarter of 20 was performed by the following method(s) (check and complete those that apply):

The notice was mailed to users on: _____
A copy of the notice is attached.

The notice was hand delivered to water customers on: _____
A copy of the notice is attached.

The notice was published in the local newspaper on: _____
A copy of the newspaper notice is attached.

The notice was published in conspicuous places on: _____
A copy of the notice is attached.
A list of locations the notice was posted is attached.

The notice was delivered to community organizations on: _____
A copy of the notice is attached.
A list of community organizations the notice was delivered to is attached.

I hereby certify that the above information is factual.

Printed Name

Title

Signature

Date

Disclosure: Be advised that Section 116725 and 116730 of the California Health and Safety Code state that any person who knowingly makes any false statement on any report or document submitted for the purpose of compliance with the attached order may be liable for a civil penalty not to exceed five thousand dollars (\$5,000) for separate violation each day that the violation continues. In addition, the violators may be prosecuted in criminal court and, upon conviction, be punished by a fine of not more than \$25,000 for each day of violation, or be imprisoned in the county jail not to exceed one year, or by both the fine and imprisonment.

Due to the Division of Drinking Water within 10 days of issuance of notice to customers
System Number: _____
Enforcement Action No. _____

Monthly Progress Report

Water System:	Water System No.:
Compliance Order No.:	Violation:
Calendar Quarter:	Date Prepared:

This form should be prepared and signed by Water System personnel with appropriate authority to implement the directives of the Compliance Order and the Corrective Action Plan. Please attach additional sheets as necessary. The monthly progress report must be submitted by the 10th day of each subsequent month, to the Division of Drinking Water, Merced District Office.

Summary of Compliance Plan:

Tasks completed in the reporting quarter:

Tasks remaining to complete:

Anticipate compliance date:

Name

Signature

Title

Date

DATE: 05/11/15
 REPORT: R-040/2-3

STATE OF CALIFORNIA
 DRINKING WATER PROGRAM

PAGE: 1

DRINKING WATER ANALYSES RESULTS REPORT
 ALL SAMPLES FOR SELECTED CONSTITUENTS - ALL RESULTS
 FOR SAMPLE DATE RANGE OF 19940101 THRU 20150511
 REPORT OF COUNTY: 24 MERCED

SYSTEM NO: 2400170 NAME: HILMAR CHEESE COMPANY COUNTY: MERCED
 SOURCE NO: 018 NAME: Treated Water - ATEC Arsenic R PSCODE: 2400170-018 CLASS: OTHR STATUS: AT

GROUP IDENTIFICATION CONSTITUENT IDENTIFICATION	SAMPLE DATE	RESULT	MCL	DLR	TRIGGER	UNIT

IO INORGANIC						
01002 ARSENIC	02/03/2011 .	42.0000	10.0000	2.0000	5.0000	UG/L
01002 ARSENIC	02/08/2011 .	28.0000	10.0000	2.0000	5.0000	UG/L
01002 ARSENIC	02/15/2011 .	23.0000	10.0000	2.0000	5.0000	UG/L
01002 ARSENIC	02/22/2011 .	26.0000	10.0000	2.0000	5.0000	UG/L
01002 ARSENIC	03/08/2011 .	87.0000	10.0000	2.0000	5.0000	UG/L
01002 ARSENIC	03/17/2011 .	87.0000	10.0000	2.0000	5.0000	UG/L
01002 ARSENIC	03/22/2011 .	89.0000	10.0000	2.0000	5.0000	UG/L
01002 ARSENIC	03/29/2011 .	11.0000	10.0000	2.0000	5.0000	UG/L
01002 ARSENIC	04/07/2011 .	14.0000	10.0000	2.0000	5.0000	UG/L
01002 ARSENIC	04/19/2011 .	11.0000	10.0000	2.0000	5.0000	UG/L
01002 ARSENIC	04/26/2011 .	11.0000	10.0000	2.0000	5.0000	UG/L
01002 ARSENIC	05/03/2011 .	17.0000	10.0000	2.0000	5.0000	UG/L
01002 ARSENIC	05/24/2011 .	5.1000	10.0000	2.0000	5.0000	UG/L
01002 ARSENIC	06/07/2011 .	7.0000	10.0000	2.0000	5.0000	UG/L
01002 ARSENIC	06/16/2011 .	6.1000	10.0000	2.0000	5.0000	UG/L
01002 ARSENIC	06/21/2011 .	4.0000	10.0000	2.0000	5.0000	UG/L
01002 ARSENIC	06/28/2011 .	5.9000	10.0000	2.0000	5.0000	UG/L
01002 ARSENIC	07/07/2011 .	3.9000	10.0000	2.0000	5.0000	UG/L
01002 ARSENIC	07/12/2011 <	2.0000	10.0000	2.0000	5.0000	UG/L
01002 ARSENIC	07/19/2011 .	2.7000	10.0000	2.0000	5.0000	UG/L
01002 ARSENIC	07/26/2011 .	17.0000	10.0000	2.0000	5.0000	UG/L

NOTE1: = RESULT IS EQUAL TO OR GREATER THAN TRIGGER

NOTE2: .000 = RESULT WAS REPORTED AS NON-DETECTED EXCEPT FOR RAD

DATE: 05/11/15
REPORT: R-040/2-3

STATE OF CALIFORNIA
DRINKING WATER PROGRAM

PAGE: 2

DRINKING WATER ANALYSES RESULTS REPORT
ALL SAMPLES FOR SELECTED CONSTITUENTS - ALL RESULTS
FOR SAMPLE DATE RANGE OF 19940101 THRU 20150511
REPORT OF COUNTY: 24 MERCED

SYSTEM NO: 2400170 NAME: HILMAR CHEESE COMPANY COUNTY: MERCED
SOURCE NO: 018 NAME: Treated Water - ATEC Arsenic R PSCODE: 2400170-018 CLASS: OTHR STATUS: AT

GROUP IDENTIFICATION CONSTITUENT IDENTIFICATION	SAMPLE DATE	RESULT	MCL	DLR	TRIGGER	UNIT
01002 ARSENIC	08/09/2011 .	7.6000	10.0000	2.0000	5.0000	UG/L
01002 ARSENIC	08/16/2011 .	7.5000	10.0000	2.0000	5.0000	UG/L
01002 ARSENIC	08/23/2011 .	5.3000	10.0000	2.0000	5.0000	UG/L
01002 ARSENIC	08/30/2011 .	8.9000	10.0000	2.0000	5.0000	UG/L
01002 ARSENIC	09/06/2011 .	7.0000	10.0000	2.0000	5.0000	UG/L
01002 ARSENIC	09/13/2011 .	10.0000	10.0000	2.0000	5.0000	UG/L
01002 ARSENIC	09/20/2011 .	6.4000	10.0000	2.0000	5.0000	UG/L
01002 ARSENIC	09/27/2011 .	8.8000	10.0000	2.0000	5.0000	UG/L
01002 ARSENIC	11/29/2011 .	11.0000	10.0000	2.0000	5.0000	UG/L
01002 ARSENIC	12/06/2011 <	2.0000	10.0000	2.0000	5.0000	UG/L
01002 ARSENIC	12/13/2011 .	4.3000	10.0000	2.0000	5.0000	UG/L
01002 ARSENIC	12/20/2011 .	5.4000	10.0000	2.0000	5.0000	UG/L
01002 ARSENIC	01/17/2012 .	2.9000	10.0000	2.0000	5.0000	UG/L
01002 ARSENIC	01/27/2012 .	5.1000	10.0000	2.0000	5.0000	UG/L
01002 ARSENIC	01/31/2012 .	5.2000	10.0000	2.0000	5.0000	UG/L
01002 ARSENIC	02/07/2012 .	28.0000	10.0000	2.0000	5.0000	UG/L
01002 ARSENIC	02/14/2012 .	9.0000	10.0000	2.0000	5.0000	UG/L
01002 ARSENIC	02/21/2012 .	3.6000	10.0000	2.0000	5.0000	UG/L
01002 ARSENIC	02/28/2012 .	2.8000	10.0000	2.0000	5.0000	UG/L
01002 ARSENIC	03/06/2012 .	5.5000	10.0000	2.0000	5.0000	UG/L
01002 ARSENIC	03/13/2012 .	3.7000	10.0000	2.0000	5.0000	UG/L
01002 ARSENIC	03/20/2012 .	4.7000	10.0000	2.0000	5.0000	UG/L
01002 ARSENIC	03/27/2012 .	5.9000	10.0000	2.0000	5.0000	UG/L

NOTE1: = RESULT IS EQUAL TO OR GREATER THAN TRIGGER

NOTE2: .000 = RESULT WAS REPORTED AS NON-DETECTED EXCEPT FOR RAD

DATE: 05/11/15
REPORT: R-040/2-3

STATE OF CALIFORNIA
DRINKING WATER PROGRAM

PAGE: 3

DRINKING WATER ANALYSES RESULTS REPORT
ALL SAMPLES FOR SELECTED CONSTITUENTS - ALL RESULTS
FOR SAMPLE DATE RANGE OF 19940101 THRU 20150511
REPORT OF COUNTY: 24 MERCED

SYSTEM NO: 2400170 NAME: HILMAR CHEESE COMPANY COUNTY: MERCED
SOURCE NO: 018 NAME: Treated Water - ATEC Arsenic R PSCODE: 2400170-018 CLASS: OTHR STATUS: AT

GROUP IDENTIFICATION CONSTITUENT IDENTIFICATION	SAMPLE DATE	RESULT	MCL	DLR	TRIGGER	UNIT
01002 ARSENIC	04/10/2012 .	2.5000	10.0000	2.0000	5.0000	UG/L
01002 ARSENIC	04/17/2012 .	4.0000	10.0000	2.0000	5.0000	UG/L
01002 ARSENIC	04/24/2012 <	2.0000	10.0000	2.0000	5.0000	UG/L
01002 ARSENIC	05/01/2012 .	7.3000	10.0000	2.0000	5.0000	UG/L
01002 ARSENIC	05/08/2012 .	7.2000	10.0000	2.0000	5.0000	UG/L
01002 ARSENIC	05/22/2012 .	4.0000	10.0000	2.0000	5.0000	UG/L
01002 ARSENIC	05/29/2012 .	5.2000	10.0000	2.0000	5.0000	UG/L
01002 ARSENIC	06/05/2012 .	27.0000	10.0000	2.0000	5.0000	UG/L
01002 ARSENIC	06/12/2012 .	6.8000	10.0000	2.0000	5.0000	UG/L
01002 ARSENIC	06/19/2012 .	3.9000	10.0000	2.0000	5.0000	UG/L
01002 ARSENIC	06/26/2012 .	5.2000	10.0000	2.0000	5.0000	UG/L
01002 ARSENIC	07/17/2012 .	10.0000	10.0000	2.0000	5.0000	UG/L
01002 ARSENIC	07/24/2012 .	4.0000	10.0000	2.0000	5.0000	UG/L
01002 ARSENIC	08/14/2012 .	8.6000	10.0000	2.0000	5.0000	UG/L
01002 ARSENIC	08/14/2012 .	3.3000	10.0000	2.0000	5.0000	UG/L
01002 ARSENIC	08/21/2012 .	4.7000	10.0000	2.0000	5.0000	UG/L
01002 ARSENIC	08/28/2012 .	4.5000	10.0000	2.0000	5.0000	UG/L
01002 ARSENIC	09/04/2012 .	5.0000	10.0000	2.0000	5.0000	UG/L
01002 ARSENIC	09/11/2012 .	140.0000	10.0000	2.0000	5.0000	UG/L
01002 ARSENIC	09/18/2012 .	3.6000	10.0000	2.0000	5.0000	UG/L
01002 ARSENIC	09/25/2012 .	3.3000	10.0000	2.0000	5.0000	UG/L
01002 ARSENIC	10/02/2012 .	33.0000	10.0000	2.0000	5.0000	UG/L
01002 ARSENIC	10/02/2012 .	7.1000	10.0000	2.0000	5.0000	UG/L

NOTE1: = RESULT IS EQUAL TO OR GREATER THAN TRIGGER

NOTE2: .000 = RESULT WAS REPORTED AS NON-DETECTED EXCEPT FOR RAD

DATE: 05/11/15
REPORT: R-040/2-3

STATE OF CALIFORNIA
DRINKING WATER PROGRAM

PAGE: 4

DRINKING WATER ANALYSES RESULTS REPORT
ALL SAMPLES FOR SELECTED CONSTITUENTS - ALL RESULTS
FOR SAMPLE DATE RANGE OF 19940101 THRU 20150511
REPORT OF COUNTY: 24 MERCED

SYSTEM NO: 2400170 NAME: HILMAR CHEESE COMPANY COUNTY: MERCED
SOURCE NO: 018 NAME: Treated Water - ATEC Arsenic R PSCODE: 2400170-018 CLASS: OTHR STATUS: AT

GROUP IDENTIFICATION CONSTITUENT IDENTIFICATION	SAMPLE DATE	RESULT	MCL	DLR	TRIGGER	UNIT
01002 ARSENIC	10/09/2012 .	7.1000	10.0000	2.0000	5.0000	UG/L
01002 ARSENIC	10/16/2012 .	5.9000	10.0000	2.0000	5.0000	UG/L
01002 ARSENIC	10/23/2012 .	25.0000	10.0000	2.0000	5.0000	UG/L
01002 ARSENIC	10/30/2012 .	12.0000	10.0000	2.0000	5.0000	UG/L
01002 ARSENIC	11/06/2012 .	5.2000	10.0000	2.0000	5.0000	UG/L
01002 ARSENIC	11/13/2012 .	6.9000	10.0000	2.0000	5.0000	UG/L
01002 ARSENIC	11/20/2012 .	7.7000	10.0000	2.0000	5.0000	UG/L
01002 ARSENIC	11/27/2012 .	7.6000	10.0000	2.0000	5.0000	UG/L
01002 ARSENIC	12/04/2012 .	8.2000	10.0000	2.0000	5.0000	UG/L
01002 ARSENIC	05/24/2013 .	13.0000	10.0000	2.0000	5.0000	UG/L
01002 ARSENIC	05/31/2013 .	15.0000	10.0000	2.0000	5.0000	UG/L
01002 ARSENIC	06/05/2013 .	12.0000	10.0000	2.0000	5.0000	UG/L
01002 ARSENIC	06/11/2013 .	13.0000	10.0000	2.0000	5.0000	UG/L
01002 ARSENIC	06/18/2013 .	64.0000	10.0000	2.0000	5.0000	UG/L
01002 ARSENIC	06/25/2013 .	9.6000	10.0000	2.0000	5.0000	UG/L
01002 ARSENIC	07/02/2013 .	26.0000	10.0000	2.0000	5.0000	UG/L
01002 ARSENIC	07/09/2013 .	9.3000	10.0000	2.0000	5.0000	UG/L
01002 ARSENIC	07/16/2013 .	11.0000	10.0000	2.0000	5.0000	UG/L
01002 ARSENIC	07/23/2013 .	8.7000	10.0000	2.0000	5.0000	UG/L
01002 ARSENIC	08/20/2013 .	7.1000	10.0000	2.0000	5.0000	UG/L
01002 ARSENIC	08/27/2013 .	10.0000	10.0000	2.0000	5.0000	UG/L
01002 ARSENIC	09/03/2013 .	9.6000	10.0000	2.0000	5.0000	UG/L
01002 ARSENIC	09/10/2013 .	8.0000	10.0000	2.0000	5.0000	UG/L

NOTE1: = RESULT IS EQUAL TO OR GREATER THAN TRIGGER

NOTE2: .000 = RESULT WAS REPORTED AS NON-DETECTED EXCEPT FOR RAD

DRINKING WATER ANALYSES RESULTS REPORT
 ALL SAMPLES FOR SELECTED CONSTITUENTS - ALL RESULTS
 FOR SAMPLE DATE RANGE OF 19940101 THRU 20150511
 REPORT OF COUNTY: 24 MERCED

SYSTEM NO: 2400170 NAME: HILMAR CHEESE COMPANY COUNTY: MERCED
 SOURCE NO: 018 NAME: Treated Water - ATEC Arsenic R PSCODE: 2400170-018 CLASS: OTHR STATUS: AT

GROUP IDENTIFICATION CONSTITUENT IDENTIFICATION	SAMPLE DATE	RESULT	MCL	DLR	TRIGGER	UNIT
01002 ARSENIC	09/17/2013 .	8.8000	10.0000	2.0000	5.0000	UG/L
01002 ARSENIC	09/24/2013 .	7.0000	10.0000	2.0000	5.0000	UG/L
01002 ARSENIC	10/01/2013 .	31.0000	10.0000	2.0000	5.0000	UG/L
01002 ARSENIC	10/08/2013 .	7.4000	10.0000	2.0000	5.0000	UG/L
01002 ARSENIC	10/15/2013 .	8.5000	10.0000	2.0000	5.0000	UG/L
01002 ARSENIC	10/22/2013 .	9.5000	10.0000	2.0000	5.0000	UG/L
01002 ARSENIC	10/29/2013 .	6.9000	10.0000	2.0000	5.0000	UG/L
01002 ARSENIC	11/05/2013 .	6.1000	10.0000	2.0000	5.0000	UG/L
01002 ARSENIC	11/12/2013 .	5.0000	10.0000	2.0000	5.0000	UG/L
01002 ARSENIC	11/26/2013 .	4.9000	10.0000	2.0000	5.0000	UG/L
01002 ARSENIC	12/03/2013 .	5.6000	10.0000	2.0000	5.0000	UG/L
01002 ARSENIC	12/10/2013 .	4.7000	10.0000	2.0000	5.0000	UG/L
01002 ARSENIC	12/17/2013 .	7.3000	10.0000	2.0000	5.0000	UG/L
01002 ARSENIC	01/07/2014 .	5.9000	10.0000	2.0000	5.0000	UG/L
01002 ARSENIC	01/14/2014 .	4.5000	10.0000	2.0000	5.0000	UG/L
01002 ARSENIC	02/04/2014 .	5.1000	10.0000	2.0000	5.0000	UG/L
01002 ARSENIC	03/11/2014 .	6.0000	10.0000	2.0000	5.0000	UG/L
01002 ARSENIC	03/18/2014 .	6.0000	10.0000	2.0000	5.0000	UG/L
01002 ARSENIC	03/25/2014 .	6.8000	10.0000	2.0000	5.0000	UG/L
01002 ARSENIC	04/08/2014 .	6.7000	10.0000	2.0000	5.0000	UG/L
01002 ARSENIC	04/14/2014 .	6.9000	10.0000	2.0000	5.0000	UG/L
01002 ARSENIC	04/22/2014 .	6.4000	10.0000	2.0000	5.0000	UG/L
01002 ARSENIC	04/25/2014 .	5.4000	10.0000	2.0000	5.0000	UG/L

NOTE1: = RESULT IS EQUAL TO OR GREATER THAN TRIGGER

NOTE2: .000 = RESULT WAS REPORTED AS NON-DETECTED EXCEPT FOR RAD

DRINKING WATER ANALYSES RESULTS REPORT
ALL SAMPLES FOR SELECTED CONSTITUENTS - ALL RESULTS
FOR SAMPLE DATE RANGE OF 19940101 THRU 20150511
REPORT OF COUNTY: 24 MERCED

SYSTEM NO: 2400170 NAME: HILMAR CHEESE COMPANY COUNTY: MERCED
SOURCE NO: 018 NAME: Treated Water - ATEC Arsenic R PSCODE: 2400170-018 CLASS: OTHR STATUS: AT

GROUP IDENTIFICATION	CONSTITUENT IDENTIFICATION	SAMPLE DATE	RESULT	MCL	DLR	TRIGGER	UNIT
01002	ARSENIC	05/06/2014 .	6.6000	10.0000	2.0000	5.0000	UG/L
01002	ARSENIC	05/13/2014 .	6.0000	10.0000	2.0000	5.0000	UG/L
01002	ARSENIC	05/19/2014 .	4.7000	10.0000	2.0000	5.0000	UG/L
01002	ARSENIC	05/27/2014 .	7.1000	10.0000	2.0000	5.0000	UG/L
01002	ARSENIC	06/03/2014 .	6.9000	10.0000	2.0000	5.0000	UG/L
01002	ARSENIC	06/10/2014 .	7.3000	10.0000	2.0000	5.0000	UG/L
01002	ARSENIC	06/17/2014 .	6.8000	10.0000	2.0000	5.0000	UG/L
01002	ARSENIC	06/24/2014 .	7.1000	10.0000	2.0000	5.0000	UG/L
01002	ARSENIC	07/01/2014 .	15.0000	10.0000	2.0000	5.0000	UG/L
01002	ARSENIC	07/08/2014 .	6.8000	10.0000	2.0000	5.0000	UG/L
01002	ARSENIC	07/15/2014 .	5.5000	10.0000	2.0000	5.0000	UG/L
01002	ARSENIC	08/12/2014 .	7.8000	10.0000	2.0000	5.0000	UG/L
01002	ARSENIC	08/26/2014 .	11.0000	10.0000	2.0000	5.0000	UG/L
01002	ARSENIC	09/02/2014 .	13.0000	10.0000	2.0000	5.0000	UG/L
01002	ARSENIC	09/09/2014 .	11.0000	10.0000	2.0000	5.0000	UG/L
01002	ARSENIC	09/16/2014 .	18.0000	10.0000	2.0000	5.0000	UG/L
01002	ARSENIC	09/23/2014 .	16.0000	10.0000	2.0000	5.0000	UG/L
01002	ARSENIC	10/07/2014 .	14.0000	10.0000	2.0000	5.0000	UG/L
01002	ARSENIC	10/14/2014 .	16.0000	10.0000	2.0000	5.0000	UG/L
01002	ARSENIC	10/28/2014 .	15.0000	10.0000	2.0000	5.0000	UG/L
01002	ARSENIC	11/04/2014 .	12.0000	10.0000	2.0000	5.0000	UG/L
01002	ARSENIC	12/09/2014 .	11.0000	10.0000	2.0000	5.0000	UG/L
01002	ARSENIC	12/16/2014 .	13.0000	10.0000	2.0000	5.0000	UG/L

NOTE1: = RESULT IS EQUAL TO OR GREATER THAN TRIGGER
NOTE2: .000 = RESULT WAS REPORTED AS NON-DETECTED EXCEPT FOR RAD

DRINKING WATER ANALYSES RESULTS REPORT
ALL SAMPLES FOR SELECTED CONSTITUENTS - ALL RESULTS
FOR SAMPLE DATE RANGE OF 19940101 THRU 20150511
REPORT OF COUNTY: 24 MERCED

SYSTEM NO: 2400170 NAME: HILMAR CHEESE COMPANY COUNTY: MERCED
SOURCE NO: 018 NAME: Treated Water - ATEC Arsenic R PSCODE: 2400170-018 CLASS: OTHR STATUS: AT

GROUP IDENTIFICATION	CONSTITUENT IDENTIFICATION	SAMPLE DATE	RESULT	MCL	DLR	TRIGGER	UNIT
	01002 ARSENIC	12/19/2014 .	18.0000	10.0000	2.0000	5.0000	UG/L
	01002 ARSENIC	12/23/2014 .	17.0000	10.0000	2.0000	5.0000	UG/L
	01002 ARSENIC	12/30/2014 .	19.0000	10.0000	2.0000	5.0000	UG/L
	01002 ARSENIC	12/30/2014 .	18.0000	10.0000	2.0000	5.0000	UG/L
	01002 ARSENIC	01/06/2015 .	23.0000	10.0000	2.0000	5.0000	UG/L
	01002 ARSENIC	01/13/2015 .	21.0000	10.0000	2.0000	5.0000	UG/L
	01002 ARSENIC	01/20/2015 .	22.0000	10.0000	2.0000	5.0000	UG/L
	01002 ARSENIC	01/20/2015 .	26.0000	10.0000	2.0000	5.0000	UG/L
	01002 ARSENIC	01/27/2015 .	23.0000	10.0000	2.0000	5.0000	UG/L
	01002 ARSENIC	02/03/2015 .	22.0000	10.0000	2.0000	5.0000	UG/L
	01002 ARSENIC	02/10/2015 .	20.0000	10.0000	2.0000	5.0000	UG/L
	01002 ARSENIC	02/17/2015 .	22.0000	10.0000	2.0000	5.0000	UG/L
	01002 ARSENIC	02/24/2015 .	29.0000	10.0000	2.0000	5.0000	UG/L
	01002 ARSENIC	03/03/2015 .	24.0000	10.0000	2.0000	5.0000	UG/L
	01002 ARSENIC	03/10/2015 .	24.0000	10.0000	2.0000	5.0000	UG/L
	01002 ARSENIC	03/17/2015 .	24.0000	10.0000	2.0000	5.0000	UG/L
	01002 ARSENIC	03/24/2015 .	24.0000	10.0000	2.0000	5.0000	UG/L

NOTE1: = RESULT IS EQUAL TO OR GREATER THAN TRIGGER
NOTE2: .000 = RESULT WAS REPORTED AS NON-DETECTED EXCEPT FOR RAD