

Sean Powers
Community Development Agency Director

Amy Irani, REHS
Director of Environmental Health



**COUNTY OF NEVADA
COMMUNITY DEVELOPMENT AGENCY
ENVIRONMENTAL HEALTH DEPARTMENT**

950 MAIDU AVENUE, SUITE 170, NEVADA CITY, CA 95959-8617
(530) 265-1222 FAX (530) 265-9853 www.mynevadacounty.com

August 01, 2016

System No. **2900551**

Temoc Rios
US Forest Service – TNF
White Cloud Admin/Campground
15924 Highway 49
Camptonville, CA. 95922

CITATION NO. 08-01-16-CIT-010

**TOTAL COLIFORM MAXIMUM CONTAMINANT LEVEL VIOLATION
CALIFORNIA CODE OF REGULATIONS, TITLE 22, SECTION 64426.1
FOR JULY 2016**

Enclosed is a Citation issued to the **White Cloud Admin/Campground** (hereinafter "**Water System**") public water system.

The **Water System** will be billed at the Department of Environmental Health's (hereinafter "Department") hourly rate (currently estimated at \$166.04) for the time spent on issuing this Citation. California Health and Safety Code, Section 116577, provides that a public water system must reimburse the Department for actual costs incurred by the Department for specified enforcement actions, including but not limited to, preparing, issuing and monitoring compliance with a citation.

If you have any questions regarding this matter, please contact Catrie Levenson at 530-265-1753 or myself at 530-265-1222

Sincerely,

Handwritten signature of Amy Irani in black ink.

Amy Irani, REHS
Director of Environmental Health
County of Nevada
Environmental Health Division

Certified Mail No: 7015 0640 0003 6915 0876

Cc: Ali R. Rezvani, P.E.
Sacramento District Engineer
State Water Resources Control Board
Division of Drinking Water

Bruce Berger, P.E.
Sanitary Engineer
State Water Resources Control Board
Division of Drinking Water

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28

**County of Nevada
Community Development Agency
Environmental Health Department**

Name of Public Water System: White Cloud Admin/Campground

Water System No: 2900551

**Attention: Temoc Rios
US Forest Service – TNF
White Cloud Admin/Campground
15924 Highway 49
Camptonville, CA 95922**

Issued: August 01, 2016

**CITATION FOR NONCOMPLIANCE
TOTAL COLIFORM MAXIMUM CONTAMINANT LEVEL VIOLATION
CALIFORNIA CODE OF REGULATIONS, TITLE 22,
SECTIONS 64426.1
July 2016**

The California Health and Safety Code, Section 116650 (hereinafter “CHSC”), authorizes the issuance of a Citation to a public water system for violation of the California Safe Drinking Water Act when it is determined that the public water system has violated or is violating the California Safe Drinking Water Act (hereinafter “California SDWA”), (CHSC, Division 104,

1 Part 12, Chapter 4, commencing with Section 116270), or any regulation,
2 standard, permit, or order issued or adopted thereunder.

3 The County of Nevada Department of Environmental Health (hereinafter
4 "Department"), through its Local Primacy Agency Agreement with the State
5 Water Resources Control Board Division of Drinking Water, hereby issues
6 this citation pursuant to Section 116650 of the CHSC to the **White Cloud**
7 **Admin/Campground Water System** (hereinafter "**Water System**") for
8 violation of CHSC, Section 116555(a)(1) and, California Code of
9 Regulations (hereinafter "CCR"), Title 22, Section 64426.1.

10
11 Section 116650 (d) and 116650 (e) of the CHSC allow for the assessment of
12 a civil penalty for failure to comply with the requirements of the SDWA.
13 Failure to comply with any provision of this Citation may result in the
14 Department imposing an administrative penalty not to exceed \$1000 (one
15 thousand dollars) per day for each day that violation has occurred, and for
16 each day that a violation continues to occur. A separate penalty may be
17 assessed for each violation.

18
19 A copy of the applicable statutes and regulations are included in Appendix 1,
20 which is attached hereto and incorporated by reference.

21 22 **STATEMENT OF FACTS**

23 The **Water System** is classified as a transient non-community water system
24 that serves a fire station and a campground. On July 08, 2016, the
25 Department received laboratory results for one (1) bacteriological samples
26 from the **Water System**. The sample was collected from distribution at the
27 campground vault. The sample was analyzed for the presence of total
28 coliform bacteria and *Escherichia coli* (*E. coli*) bacteria. The one (1) sample

1 that was analyzed was positive for total coliform bacteria. On July 11, 2016
2 the **Water System** collected four (4) repeat samples. These four (4) repeat
3 samples were analyzed for the presence of total coliform bacteria and
4 *Escherichia coli* (*E. coli*) bacteria. Three (3) of the four (4) repeat samples
5 that were analyzed were positive for total coliform bacteria.

6 7 **DETERMINATION**

8 Title 22, CCR, Section 64426.1, Total Coliform Maximum Contaminant Level
9 (MCL), states that a public water system is in violation of the total coliform
10 MCL if a public water system, which collects fewer than forty (40) samples
11 per month, has more than one (1) sample collected during any month that is
12 total coliform positive.

13
14 Therefore, the Department has determined that the **Water System** violated
15 CCR, Title 22, Section 64426.1 during July 2016.

16 17 **DIRECTIVES**

18 The **Water System** is hereby directed to take the following actions:

- 19
- 20 1. Comply with CCR, Title 22, Section 64426.1 in all future monitoring
21 periods.
 - 22 2. The **Water System** shall notify the Department in the future, in
23 accordance CCR, Title 22, Section 64426.1(c), by end of the
24 business day in which it is determined the **Water System** is not in
25 compliance or within 24 hours if determination occurs when the
26 Department is closed.
 - 27 3. Pursuant to California Federal Regulations (CFR), Title 40, Chapter I,
28 Part 141, Subpart Y, Section 141.859 perform a level one

1 assessment on the **Water System**, and submit the assessment to
2 this Department on or before **August 12, 2016**.

3 4. Pursuant to CCR, Title 22, Section 64424(d), collect and have
4 analyzed for total coliform bacteria five (5) routine bacteriological
5 samples on or before **August 31, 2016**.

6 5. Complete Appendix 2: Compliance Certification Form. Submit a copy
7 of this certification form to the Department on or before **September**
8 **10, 2016**.

9 6. Public Notification requirements associated with these violations, in
10 accordance with CCR, Title 22, Section 64481(g)(1), shall be in the
11 form of including this information in the 2016 Consumer Confidence
12 Report.

13 All submittals required by this Citation shall be submitted to the Department
14 of Environmental Health at the following address:

15
16
17 Catrie Levenson, REHS, PHM
18 Environmental Health Specialist
19 County of Nevada
20 Environmental Health Department
21 950 Maidu Avenue, Suite 170
22 Nevada City, CA 95959
23 (530) 265-1753
24

25 The Department reserves the right to make such modifications to this
26 Citation as it may deem necessary to protect public health and safety. Such
27 modifications may be issued as amendments to this Citation and shall be
28 effective upon issuance.

29
30 Nothing in this Citation relieves the **Water System** of its obligation to meet
31 the requirements of the California SDWA (CHSC, Division 104, Part 12,

1 Chapter 4, commencing with Section 116270), or any regulation, standard,
2 permit or order issued or adopted thereunder.

3
4 **PARTIES BOUND**

5 This Citation shall apply to and be binding upon the **Water System**, its
6 owners, shareholders, officers, directors, agents, employees, contractors,
7 successors, and assignees.


8
9 **SEVERABILITY**

10 The directives of this Citation are severable, and the **Water System** shall
11 comply with each and every provision thereof notwithstanding the
12 effectiveness of any provision.

13
14
15
16 **FURTHER ENFORCEMENT ACTION**

17 The California SDWA authorizes the Department of Environmental Health,
18 through its Local Primacy Agency Agreement with The State Water
19 Resources Control Board Division of Drinking Water, to: issue a citation with
20 assessment of administrative penalties to a public water system for violation
21 or continued violation of the requirements of the California SDWA or any
22 regulation, permit, standard, citation, or order issued or adopted thereunder
23 including, but not limited to, failure to correct a violation identified in a
24 citation or compliance order. The California SDWA also authorizes the
25 Department, through its Local Primacy Agency Agreement with The State
26 Water Resources Control Board Division of Drinking Water, to take action to
27 suspend or revoke a permit that has been issued to a public water system if
28 the public water system has violated applicable law or regulations or has

1 failed to comply with an order of the Department, and to petition the superior
2 court to take various enforcement measures against a public water system
3 that has failed to comply with an order of the Department. The Department
4 does not waive any further enforcement action by issuance of this Citation.

5
6 

7 **Amy Irani, REHS**
8 Director of Environmental Health
9 County of Nevada
10 Environmental Health Department

8/1/16

Date

11 Appendices (3):

- 12 1. Applicable Statutes and Regulations
- 13 2. Notification Template
- 14 3. Compliance Certification Form

15 Certified Mail No. 7015 0640 0003 6915 0876

APPENDIX 1. APPLICABLE STATUTES AND REGULATIONS FOR CITATION NO. 08-01-16-CIT-010

Violation of Total Coliform Rule MCL

Section 116271 of the CHSC states in relevant part:

- (a) The State Water Resources Control Board succeeds to and is vested with all of the authority, duties, powers, purposes, functions, responsibilities, and jurisdiction of the State Department of Public Health, its predecessors, and its director for purposes of all of the following:
- (1) The Environmental Laboratory Accreditation Act (Article 3 (commencing with Section 100825) of Chapter 4 of Part 1 of Division 101).
 - (2) Article 3 (commencing with Section 106875) of Chapter 4 of Part 1.
 - (3) Article 1 (commencing with Section 115825) of Chapter 5 of Part 10.
 - (4) This chapter and the Safe Drinking Water State Revolving Fund Law of 1997 (Chapter 4.5 (commencing with Section 116760)).
 - (5) Article 2 (commencing with Section 116800), Article 3 (commencing with Section 116825), and Article 4 (commencing with Section 116875) of Chapter 5.
 - (6) Chapter 7 (commencing with Section 116975).
 - (7) The Safe Drinking Water, Water Quality and Supply, Flood Control, River and Coastal Protection Bond Act of 2006 (Division 43 (commencing with Section 75001) of the Public Resources Code).
 - (8) The Water Recycling Law (Chapter 7 (commencing with Section 13500) of Division 7 of the Water Code).
 - (9) Chapter 7.3 (commencing with Section 13560) of Division 7 of the Water Code.
 - (10) The California Safe Drinking Water Bond Law of 1976 (Chapter 10.5 (commencing with Section 13850) of Division 7 of the Water Code).
 - (11) Wholesale Regional Water System Security and Reliability Act (Division 20.5 (commencing with Section 73500) of the Water Code).
 - (12) Water Security, Clean Drinking Water, Coastal and Beach Protection Act of 2002 (Division 26.5 (commencing with Section 79500) of the Water Code).
- (b) The State Water Resources Control Board shall maintain a drinking water program and carry out the duties, responsibilities, and functions described in this section. Statutory reference to "department," "state department," or "director" regarding a function transferred to the State Water Resources Control Board shall refer to the State Water Resources Control Board. This section does not impair the authority of a local health officer to enforce this chapter or a county's election not to enforce this chapter, as provided in Section 116500...
- (k)
- (1) The State Water Resources Control Board shall appoint a deputy director who reports to the executive director to oversee the issuance and enforcement of public water system permits and other duties as appropriate. The deputy director shall have public health expertise.
 - (2) The deputy director is delegated the State Water Resources Control Board's authority to provide notice, approve notice content, approve emergency notification plans, and take other action pursuant to Article 5 (commencing with Section 116450), to issue, renew, reissue, revise, amend, or deny any public water system permits pursuant to Article 7 (commencing with Section 116525), to suspend or revoke any public water system permit pursuant to Article 8 (commencing with Section 116625), and to issue citations, assess penalties, or issue orders pursuant to Article 9 (commencing with Section 116650). Decisions and actions of the deputy director taken pursuant to Article 5 (commencing with Section 116450) or Article 7 (commencing with Section 116525) are deemed decisions and actions taken, but are not subject to reconsideration, by the State Water Resources Control Board. Decisions and actions of the deputy director taken pursuant to Article 8 (commencing with Section 116625) and Article 9 (commencing with Section 116650) are deemed decisions and actions taken by the State Water Resources Control Board, but any aggrieved person may petition the State Water Resources Control Board for reconsideration of the decision or action. This subdivision is not a limitation on the State Water Resources Control Board's authority to delegate any other powers and duties.

Section 116650 of the CHSC states in relevant part:

- (a) If the department determines that a public water system is in violation of this chapter or any regulation, permit, standard, citation, or order issued or adopted thereunder, the department may issue a citation to the public water system. The citation shall be served upon the public water system personally or by certified mail. Service shall be deemed effective as of the date of personal service or the date of receipt of the certified mail. If a person to whom a citation is directed refuses to accept delivery of the certified mail, the date of service shall be deemed to be the date of mailing.

- (b) Each citation shall be in writing and shall describe the nature of the violation or violations, including a reference to the statutory provision, standard, order, citation, permit, or regulation alleged to have been violated.
- (c) A citation may specify a date for elimination or correction of the condition constituting the violation.
- (d) A citation may include the assessment of a penalty as specified in subdivision (e).
- (e) The department may assess a penalty in an amount not to exceed one thousand dollars (\$1,000) per day for each day that a violation occurred, and for each day that a violation continues to occur. A separate penalty may be assessed for each violation.

Section 64424 (Repeat Sampling) of the CCR states in relevant part:

(a) If a routine sample is total coliform-positive, the water supplier shall collect a repeat sample set as described in paragraph (1) within 24 hours of being notified of the positive result. The repeat samples shall all be collected within the same 24 hour time period. A single service connection system may request that the State Board allow the collection of the repeat sample set over a four-day period.

(1) For a water supplier that normally collects more than one routine sample a month, a repeat sample set shall be at least three samples for each total coliform-positive sample. For a water supplier that normally collects one or fewer samples per month, a repeat sample set shall be at least four samples for each total coliform-positive sample.

(2) If the water supplier is unable to collect the samples within the 24-hour time period specified in subsection (a) or deliver the samples to the laboratory within 24 hours after collection because of circumstances beyond its control, the water supplier shall notify the State Board within 24 hours. The State Board will then determine how much time the supplier will have to collect the repeat samples.

(d) If a public water system for which **fewer than five routine samples/month** are collected has one or more total coliform-positive samples, the water supplier shall collect at least five routine samples the following month. If the supplier stops supplying water during the month after the total coliform-positive(s), at least five samples shall be collected during the first month the system resumes operation. A water supplier may request the State Board waive the requirement to collect at least five routine samples the following month, but a waiver will not be granted solely on the basis that all repeat samples are total coliform-negative. To request a waiver, one of the following conditions shall be met:

(1) The State Board conducts a site visit before the end of the next month the system provides water to the public to determine whether additional monitoring and/or corrective action is necessary to protect public health.

(2) The State Board determines why the sample was total coliform-positive and establishes that the system has corrected the problem or will correct the problem before the end of the next month the system serves water to the public. If a waiver is granted, a system shall collect at least one routine sample before the end of the next month it serves water to the public and use it to determine compliance with Section 64426.1.

Section 64426 (Significant Rise in Bacterial Count) of the CCR states in relevant part:

(a) Any of the following criteria shall indicate a possible significant rise in bacterial count:

- (1) A system collecting at least 40 samples per month has a total coliform-positive routine sample followed by two total coliform-positive repeat samples in the repeat sample set;
- (2) A system has a sample which is positive for fecal coliform or *E. coli*; or
- (3) A system fails the total coliform Maximum Contaminant Level (MCL) as defined in Section 64426.1.

(b) When the coliform levels specified in subsection (a) are reached or exceeded, the water supplier shall:

(1) Contact the State Board by the end of the day on which the system is notified of the test result or the system determines that it has exceeded the MCL, unless the notification or determination occurs after the State Board office is closed, in which case the supplier shall notify the State Board within 24 hours; and

(2) Submit to the State Board information on the current status of physical works and operating procedures which may have caused the elevated bacteriological findings, or any information on community illness suspected of being waterborne. This shall include, but not be limited to:

- (A) Current operating procedures that are or could potentially be related to the increase in bacterial count;
- (B) Any interruptions in the treatment process;
- (C) System pressure loss to less than 5 psi;
- (D) Vandalism and/or unauthorized access to facilities;
- (E) Physical evidence indicating bacteriological contamination of facilities;
- (F) Analytical results of any additional samples collected, including source samples;
- (G) Community illness suspected of being waterborne; and
- (H) Records of the investigation and any action taken.

Section 64426.1 (Total Coliform Maximum Contaminant Level (MCL)) of CCR states in relevant part:

- (b) A public water system is in violation of the total coliform MCL when any of the following occurs:
 - (1) For a public water system which collects at least 40 samples per month, more than 5.0 percent of the samples collected during any month are total coliform-positive; or
 - (2) For a public water system which collects fewer than 40 samples per month, more than one sample collected during any month is total coliform-positive; or
 - (3) Any repeat sample is fecal coliform-positive or *E. coli*-positive; or
 - (4) Any repeat sample following a fecal coliform-positive or *E. coli*-positive routine sample is total coliform-positive.
- (c) If a public water system is not in compliance with paragraphs (b)(1) through (4), during any month in which it supplies water to the public, the water supplier shall notify the State Board by the end of the business day on which this is determined, unless the determination occurs after the State Board office is closed, in which case the supplier shall notify the State Board within 24 hours of the determination. The water supplier shall also notify the consumers served by the water system. A Tier 2 Public Notice shall be given for violations of paragraph (b)(1) or (2), pursuant to section 64463.4. A Tier 1 Public Notice shall be given for violations of paragraph (b)(3) or (4), pursuant to section 64463.1.

Section 64463.1 (Tier 1 Public Notice) of CCR states in relevant part:

- (a) A water system shall give public notice pursuant to this section and section 64465 if any of the following occurs:
 - (1) Violation of the total coliform MCL when:
 - (A) Fecal coliform or *E. coli* are present in the distribution system; or
 - (B) When any repeat sample tests positive for coliform and the water system fails to test for fecal coliforms or *E. coli* in the repeat sample;...
- (b) As soon as possible within 24 hours after learning of any of the violations in subsection (a) or being notified by the State Board that it has determined there is a potential for adverse effects on human health [pursuant to paragraph (a)(4), (5), or (6)], the water system shall:
 - (1) Give public notice pursuant to this section;
 - (2) Initiate consultation with the State Board within the same timeframe; and
 - (3) Comply with any additional public notice requirements that are determined by the consultation to be necessary to protect public health.
- (c) A water system shall deliver the public notice in a manner designed to reach residential, transient, and nontransient users of the water system and shall use, as a minimum, one of the following forms:
 - (1) Radio or television;
 - (2) Posting in conspicuous locations throughout the area served by the water system;
 - (3) Hand delivery to persons served by the water system; or
 - (4) Other method approved by the State Board, based on the method's ability to inform water system users.

Section 64463.4 (Tier 2 Public Notice) of CCR states in relevant part:

- (a) A water system shall give public notice pursuant to this section if any of the following occurs:
 - (1) Any violation of the MCL, MRDL, and treatment technique requirements, except:
 - (A) Where a Tier 1 public notice is required under section 64463.1; or
 - (B) Where the State Board determines that a Tier 1 public notice is required, based on potential health impacts and persistence of the violations;
 - (2) All violations of the monitoring and testing procedure requirements in sections 64421 through 64426.1, article 3 (Primary Standards – Bacteriological Quality), for which the State Board determines that a Tier 2 rather than a Tier 3 public notice is required, based on potential health impacts and persistence of the violations;
 - (3) Other violations of the monitoring and testing procedure requirements in this chapter, and chapters 15.5, 17 and 17.5, for which the State Board determines that a Tier 2 rather than a Tier 3 public notice is required, based on potential health impacts and persistence of the violations; or
 - (4) Failure to comply with the terms and conditions of any variance or exemption in place.
- (b) A water system shall give the notice as soon as possible within 30 days after it learns of a violation or occurrence specified in subsection (a), except that the water system may request an extension of up to 60 days for providing the notice. This extension would be subject to the State Board's written approval based on the violation or occurrence having been resolved and the State Board's determination that public health and welfare would in no way be adversely affected. In addition, the water system shall:
 - (1) Maintain posted notices in place for as long as the violation or occurrence continues, but in no case less than seven days;
 - (2) Repeat the notice every three months as long as the violation or occurrence continues. Subject to the State Board's written approval based on its determination that public health would in no way be adversely affected, the water system may be allowed to notice less frequently but in no case

less than once per year. No allowance for reduced frequency of notice shall be given in the case of a total coliform MCL violation or violation of a Chapter 17 treatment technique requirement; and (3) For turbidity violations pursuant to sections 64652.5(c)(2) and 64653(c), (d) and (f), as applicable, a water system shall consult with the State Board as soon as possible within 24 hours after the water system learns of the violation to determine whether a Tier 1 public notice is required. If consultation does not take place within 24 hours, the water system shall give Tier 1 public notice within 48 hours after learning of the violation.

(c) A water system shall deliver the notice, in a manner designed to reach persons served, within the required time period as follows:

(1) Unless otherwise directed by the State Board in writing based on its assessment of the violation or occurrence and the potential for adverse effects on public health and welfare, **community** water systems shall give public notice by;

(A) Mail or direct delivery to each customer receiving a bill including those that provide their drinking water to others (e.g., schools or school systems, apartment building owners, or large private employers), and other service connections to which water is delivered by the water system; and

(B) Use of one or more of the following methods to reach persons not likely to be reached by a mailing or direct delivery (renters, university students, nursing home patients, prison inmates, etc.):

1. Publication in a local newspaper;
2. Posting in conspicuous public places served by the water system, or on the Internet; or
3. Delivery to community organizations.

(2) Unless otherwise directed by the State Board in writing based on its assessment of the violation or occurrence and the potential for adverse effects on public health and welfare, **noncommunity** water systems shall give the public notice by:

(A) Posting in conspicuous locations throughout the area served by the water system; and

(B) Using one or more of the following methods to reach persons not likely to be reached by a public posting:

1. Publication in a local newspaper or newsletter distributed to customers;
2. E-mail message to employees or students;
3. Posting on the Internet or intranet; or
4. Direct delivery to each customer.

Section 64465 (Public Notice Content and Format) of the CCR states in relevant part:

(a) Each public notice given pursuant to this article, except Tier 3 public notices for variances and exemptions pursuant to subsection (b), shall contain the following:

- (1) A description of the violation or occurrence, including the contaminant(s) of concern, and (as applicable) the contaminant level(s);
- (2) The date(s) of the violation or occurrence;
- (3) Any potential adverse health effects from the violation or occurrence, including the appropriate standard health effects language from appendices 64465-A through G;
- (4) The population at risk, including subpopulations particularly vulnerable if exposed to the contaminant in drinking water;
- (5) Whether alternative water supplies should be used;
- (6) What actions consumers should take, including when they should seek medical help, if known;
- (7) What the water system is doing to correct the violation or occurrence;
- (8) When the water system expects to return to compliance or resolve the occurrence;
- (9) The name, business address, and phone number of the water system owner, operator, or designee of the water system as a source of additional information concerning the public notice;
- (10) A statement to encourage the public notice recipient to distribute the public notice to other persons served, using the following standard language: —Please share this information with all the other people who drink this water, especially those who may not have received this public notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this public notice in a public place or distributing copies by hand or mail; and
- (11) For a water system with a monitoring and testing procedure violation, this language shall be included: “We are required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not your drinking water meets health standards. During [compliance period dates], we [‘did not monitor or test’ or ‘did not complete all monitoring or testing’] for [contaminant(s)], and therefore, cannot be sure of the quality of your drinking water during that time.” ...

(c) A public water system providing notice pursuant to this article shall comply with the following multilingual-related requirements:

(2) For a Tier 2 or Tier 3 public notice:

(A) The notice shall contain information in Spanish regarding the importance of the notice, or contain a telephone number or address where Spanish-speaking residents may contact the public water system to obtain a translated copy of the notice or assistance in Spanish; and

(B) When a non-English speaking group other than Spanish-speaking exceeds 1,000 residents or 10 percent of the residents served by the public water system, the notice shall include:

1. Information in the appropriate language(s) regarding the importance of the notice; or
2. A telephone number or address where such residents may contact the public water system to obtain a translated copy of the notice or assistance in the appropriate language; and

(3) For a public water system subject to the Dymally-Alatorre Bilingual Services Act, Chapter 17.5, Division 7, of the Government Code (commencing with section 7290), meeting the requirements of this Article may not ensure compliance with the Dymally-Alatorre Bilingual Services Act.

(d) Each public notice given pursuant to this article shall:

(1) Be displayed such that it catches people's attention when printed or posted and be formatted in such a way that the message in the public notice can be understood at the eighth-grade level;

(2) Not contain technical language beyond an eighth-grade level or print smaller than 12 point; and

(3) Not contain language that minimizes or contradicts the information being given in the public notice.

Appendix 64465-A. Health Effects Language- Microbiological Contaminants.

Contaminant	Health Effects Language
Total Coliform	Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially-harmful, bacteria may be present. Coliforms were found in more samples than allowed and this was a warning of potential problems.
Fecal coliform/ <i>E. coli</i>	Fecal coliforms and <i>E. coli</i> are bacteria whose presence indicates that the water may be contaminated with human or animal wastes. Microbes in these wastes can cause short-term effects, such as diarrhea, cramps, nausea, headaches, or other symptoms. They may pose a special health risk for infants, young children, some of the elderly, and people with severely compromised immune systems.
Turbidity	Turbidity has no health effects. However, high levels of turbidity can interfere with disinfection and provide a medium for microbial growth. Turbidity may indicate the presence of disease-causing organisms. These organisms include bacteria, viruses, and parasites that can cause symptoms such as nausea, cramps, diarrhea, and associated headaches.

Section 64469 (Reporting Requirements) of CCR states in relevant part:

(d) Within 10 days of giving initial or repeat public notice pursuant to Article 18 of this Chapter, except for notice given under section 64463.7(d), each water system shall submit a certification to the State Board that it has done so, along with a representative copy of each type of public notice given.

APPENDIX 2. COMPLIANCE CERTIFICATION

Citation Number: **08-01-16-CIT-010**

Name of Water System: **White Cloud Admin/Campground Water System**

System Number: **2900551**

Certification

I certify that the users of the water supplied by this water system were notified of the bacteriological violation of California Code of Regulations, Title 22, Section 64426.1 for the compliance period of July 2016 and the required actions listed below were completed.

Required Action	Date Completed
<i>(Citation Directive 2) Public Notification – Mail or direct delivery and by Secondary Notification Method completed. List Secondary Method Used:</i>	

Signature of Water System Representative

Date

Attach a copy of the notice distributed to the system customers.

THIS FORM MUST BE COMPLETED AND RETURNED TO THE DEPARTMENT OF ENVIRONMENTAL HEALTH, NO LATER THAN September 10TH, 2016

Disclosure: Be advised that the California Health and Safety Code, Sections 116725 and 116730 state that any person who knowingly makes any false statement on any report or document submitted for the purpose of compliance with the Safe Drinking Water Act may be liable for, respectively, a civil penalty not to exceed five thousand dollars (\$5,000) for each separate violation or, for continuing violations, for each day that violation continues, or be punished by a fine of not more than \$25,000 for each day of violation, or by imprisonment in the county jail not to exceed one year, or by both the fine and imprisonment.