CALIFORNIA
Water Boards

EDMUND G. BROWN JR.
GOVERNOR

MATTHEW RODRIQUEZ
SECRETARY FOR
ENVIRONMENTAL PROTECTION

State Water Resources Control Board
Division of Drinking Water

August 17, 2016
System No.: 5400624

Ms. Sherry Martin, Superintendent
Kings River Elementary School
3961 Avenue 400
Kingsburg, CA 93631

RE: **Citation No. 03-24-16C-019**
Violation of Title 22, California Code of Regulations, Section 64426.1,
For June & July 2016

Dear Ms. Martin:

Enclosed is a Citation issued to the Kings River Elementary School (Water System) public water system.

The Water System will be billed at the Division's hourly rate (currently estimated at $153.00) for the time spent on issuing this Citation. The California Health and Safety Code Section 116577 provides that a public water system must reimburse the Division for actual costs incurred by the Division for specific enforcement actions, including but not limited to, preparing, issuing and monitoring compliance with a citation. At this time, the Division has spent approximately one hour on enforcement activities associated with this violation.

The Water System will receive a bill sent from the Division of Drinking Water Fee Billing Unit in August of the next fiscal year. This bill will contain fees for any enforcement time spent on Kings River Elementary School for the current fiscal year.

If you have any questions regarding this letter and the enclosed citation, please contact the Tulare District office at (559) 447-3300.

Sincerely,

Chad Fischer, P.E.
Senior Sanitary Engineer, Tulare District
SOUTHERN CALIFORNIA BRANCH
DRINKING WATER FIELD OPERATIONS

CJF/MRC
cc: Tulare County Environmental Health Department
Ms. Pamela Proctor, Dellavalle Labs (422 N. Douty St., Hanford, CA 93230)

Citation No. 03-24-16C-019

STATE OF CALIFORNIA
WATER RESOURCES CONTROL BOARD
DIVISION OF DRINKING WATER

IN RE: **KINGS RIVER ELEMENTARY SCHOOL**
Water System No. 5400624

TO: Ms. Sherry Martin, Superintendent
Kings River Elementary School
3961 Avenue 400
Kingsburg, CA 93631

CC: Tulare County Environmental Health Services Department

CITATION FOR VIOLATION OF
CALIFORNIA CODE OF REGULATIONS, TITLE 22, SECTION 64426.1
June & July 2016

Issued on August 17, 2016

Section 116650 of the California Health and Safety Code authorizes the issuance of a citation to a public water system for violation of the California Safe Drinking Water Act (Health and Safety Code, Division 104, Part 12, Chapter 4, commencing with Section 116270) (hereinafter "California SDWA"), or any regulation, standard, permit or order issued or adopted thereunder.

The State Water Resources Control Board (hereinafter "Board"), acting by and through its Division of Drinking Water (hereinafter "Division") and the Deputy Director for the Division (hereinafter "Deputy Director"), hereby issues a citation to the Kings River Elementary School (hereinafter "Water System") (3961 Ave 400, Kingsburg, CA 93631) for violation of California Code of Regulations (CCR), Title 22, Section 64426.1.

APPLICABLE AUTHORITIES

The applicable statutes and regulations are provided in Appendix A, attached hereto and incorporated by reference.

STATEMENT OF FACTS

The Water System is a nontransient noncommunity water system serving a population of 600 students and staff through 10 service connections.

The Water System is required to collect a minimum of one distribution system bacteriological samples per month. The bacteriological water analysis results submitted by the Water System reported the presence of total coliform bacteria in thirteen of eighteen samples collected in June & July 2016. The samples were negative for *E.coli* bacteria.

Upon being informed of the presence of total coliform bacteria in the routine sample collected on June 7, 2016, staff collected a total of four repeat samples on June 9, 2016. All of the samples were positive for total coliform bacteria and were negative for *E.coli* bacteria. The Water System was issued a Boil Water Notice by the Division on June 10, 2016 and directed the system to conduct an emergency disinfection of the well and the distribution system. The system collected a second set of three repeat samples on June 15, 2016. All of the samples were negative for coliform bacteria. The Water System collected five investigative samples on June 29, 2016 which were all positive for total coliform bacteria and negative for *E.coli* bacteria. The system was directed to conduct a second emergency disinfection of the distribution system. A single investigative sample was collected on July 6, 2016 at the pressure tank and was positive for total coliform bacteria and negative for *E.coli* bacteria. The system was directed to conduct an emergency disinfection of the pressure tank. The Water System collected four repeat samples on July 18, 2016. Two of the four samples were positive for coliform bacteria and negative for *E.coli* bacteria. The Water System was directed to install permanent

chlorination equipment in August 2016. The Division rescinded the Boil Water Notice on August 16, 2016 after two rounds of four samples were submitted and were negative for coliform bacteria. The samples had chlorine residuals ranging between 0.13 to 0.6 mg/L. All water samples for coliform bacteria collected during June & July 2016 are summarized in Attachment A.

The source of contamination is believed to be from the well and from the pressure tank. A source sample collected on June 9, 2016 showed total coliform bacteria at a level of 1986.3 MPN/100mL. Source repeat samples collected on June 15, 2016 and July 18, 2016 were negative for coliform bacteria. A sample collected from the pressure tank on July 6, 2016 was positive for total coliform bacteria and negative for *E.coli* bacteria.

Public notification to the Division and consumers of a water system is required whenever a violation of the Total Coliform MCL occurs. Notification to the Division is required by the end of the business day on which the violation has been determined. If the Division is closed, notification shall be within 24 hours of the determination. The Division was notified on June 10, 2016 of the Total Coliform MCL violation.

Public notification to the consumers of the water system has not been conducted. Attachment B is a copy of a public notice that the Water System may use to notify its customers. This notice fulfills the total coliform MCL notification requirements and includes the mandatory language. Proof of notification is required (Attachment C).

DETERMINATION

Title 22, CCR, Section 64426.1, Total Coliform Maximum Contaminant Level (MCL) provides that a public water system that collects fewer than 40 bacteriological samples per month has

violated the regulation if more than one sample collected during any month is total coliform positive.

The Division has determined that the Water System failed to comply with Title 22, CCR, Section 64426.1, Total Coliform MCL for the months of June & July 2016 due to the presence of total coliform bacteria in thirteen of eighteen samples collected in June & July 2016.

DIRECTIVES

The Water System is hereby directed to take the following actions:

1. Comply with Title 22, CCR, Section 64426.1, in all future monitoring periods.

2. On or before **September 15, 2016**, notify all persons served by the Water System of the TCR MCL violation by utilizing the Tier 2 Public Notice for violations of Section 64426.1. Public notice shall be given pursuant to Sections 64463.4 [lists method, time frame and delivery] and 64465 [content & format]. The Water System shall use the public notification template appended as Attachment B to fulfill the public notification requirements. Section 64463.4 allows nontransient noncommunity water systems to give public notice by posting the notice in conspicuous locations throughout the area served by the water system and by the use of one or more of the following methods in order to reach persons not likely to be reached by a public posting: publication in a local newspaper or newsletter distributed to customers, e-mailing the public notice to water system customers, post the public notice on the internet, or by delivery to each customer.

3. Within ten days of the provision of public notification as outlined above in Directive No. 2, the Water System shall provide to the Division certification of public notification using the

enclosed Proof of Notification form (Attachment C). A copy of the final notice that was posted shall also be submitted to the Division with the proof of notification form.

4. The Water System shall notify the Division of any further violations of the total coliform MCL by the end of the business day on which the violation has been determined, or, if the Division is closed, within 24 hours of the determination.

The Division reserves the right to make such modifications to the Citation as it may deem necessary to protect public health and safety. Such modifications may be issued as amendments to this Citation and shall be effective upon issuance.

Nothing in this Citation relieves the Water System of its obligation to meet the requirements of the California Safe Drinking Water Act or any regulation, standard, permit or order issued thereunder.

All submittal required by this Citation shall be submitted to the Division at the following address:

Chad Fischer, P.E.
Senior Sanitary Engineer
State Water Resources Control Board
Division of Drinking Water
265 W. Bullard Avenue, Suite 101
Fresno, CA 93704

PARTIES BOUND

This Citation shall apply to and be binding upon the Kings River Elementary School , its officers, directors, agents, employees, contractors, successors, and assignees.

SEVERABILITY

The Directives of this Citation are severable, and the Water System shall comply with each and every provision thereof notwithstanding the effectiveness of any provision.

FURTHER ENFORCEMENT ACTION

The California SDWA authorizes the Board to: issue citation with assessment of administrative penalties to a public water system for violation or continued violation of the requirements of the California SDWA or any permit, regulation or order issued or adopted thereunder including, but not limited to, failure to correct a violation identified in a citation or compliance order. The California SDWA also authorizes the Board to take action to suspend or revoke a permit that has been issued to a public water system if the system has violated applicable law or regulations or has failed to comply with an order of the Board; and to petition the superior court to take various enforcement measures against a public water system that has failed to comply with an order of the Board. The Board does not waive any further enforcement action by issuance of this citation.

8-18-2016
Date

Chad Fischer, P.E.
Senior Sanitary Engineer, Tulare District
DRINKING WATER FIELD OPERATIONS BRANCH

CJF/MRC
Attachments:
Attachment A: Summary of Distribution Bacteriological Samples from June & July 2016
Attachment B: Public Notice for June & July 2016
Attachment C: Proof of Public Notification Form

Certified Mail: 7015 1660 0000 0781 871

03_24_16C_019_5400624_22

APPENDIX A

Applicable Statues and Regulations for Citation No. 03-24-16C-019

Section 116650 of the CHSC states in relevant part:

§116650. Citations

(a) If the Division determines that a public water system is in violation of this chapter or any regulation, permit, standard, citation, or order issued or adopted thereunder, the Division may issue a citation to the public water system. The citation shall be served upon the public water system personally or by certified mail. Service shall be deemed effective as of the date of personal service or the date of receipt of the certified mail. If a person to whom a citation is directed refuses to accept delivery of the certified mail, the date of service shall be deemed to be the date of mailing.

(b) Each citation shall be in writing and shall describe the nature of the violation or violations, including a reference to the statutory provision, standard, order, citation, permit, or regulation alleged to have been violated.

(c) A citation may specify a date for elimination or correction of the condition constituting the violation.

(d) A citation may include the assessment of a penalty as specified in subdivision (e).

(e) The Division may assess a penalty in an amount not to exceed one thousand dollars ($1,000) per day for each day that a violation occurred, and for each day that a violation continues to occur. A separate penalty may be assessed for each violation.

Section 64424 of Title 22, California Code of Regulations (CCR) states in relevant part:

§64424. Repeat Sampling.

(a) If a routine sample is total coliform-positive, the water supplier shall collect a repeat sample set as described in paragraph (a)(1) within 24 hours of being notified of the positive result. The repeat samples shall all be collected within the same 24 hour time period. A single service connection system may request that the Division allow the collection of the repeat sample set over a four-day period.
   (1) For a water supplier that normally collects more than one routine sample a month, a repeat sample set shall be at least three samples for each total coliform-positive sample. For a water supplier that normally collects one or fewer samples per month, a repeat sample set shall be at least four samples for each total coliform-positive sample.
   (2) If the water supplier is unable to collect the samples within the 24-hour time period specified in subsection (a) or deliver the samples to the laboratory within 24 hours after collection because of circumstances beyond its control, the water supplier shall notify the Department within 24 hours. The Department will then determine how much time the supplier will have to collect the repeat samples.

(b) When collecting the repeat sample set, the water supplier shall collect at least one repeat sample from the sampling tap where the original total coliform-positive sample was taken. Other repeat samples shall be collected within five service connections upstream or downstream of the original site. At least one sample shall be from upstream and one from downstream unless there is no upstream and/or downstream service connection.

(c) If one or more samples in the repeat sample set is total coliform-positive, the water supplier shall collect and have analyzed an additional set of repeat samples as

specified in subsections (a) and (b). The supplier shall repeat this process until either no coliforms are detected in one complete repeat sample set or the supplier determines that the MCL for total coliforms specified in §64426.1 has been exceeded and notifies the Department.

(d) If a public water system for which fewer than five routine samples/month are collected has one or more total coliform-positive samples, the water supplier shall collect at least five routine samples the following month. If the supplier stops supplying water during the month after the total coliform-positive(s), at least five samples shall be collected during the first month the system resumes operation. A water supplier may request the Department waive the requirement to collect at least five routine samples the following month, but a waiver will not be granted solely on the basis that all repeat samples are total coliform-negative. To request a waiver, one of the following conditions shall be met:
   (1) The Department conducts a site visit before the end of the next month the system provides water to the public to determine whether additional monitoring and/or corrective action is necessary to protect public health.
   (2) The Department determines why the sample was total coliform-positive and establishes that the system has corrected the problem or will correct the problem before the end of the next month the system serves water to the public. If a waiver is granted, a system shall collect at least one routine sample before the end of the next month it serves water to the public and use it to determine compliance with §64426.1.

Section 64426.1 of Title 22, California Code of Regulations (CCR) states in relevant part:
§64426.1. Total Coliform Maximum Contaminant Level (MCL).

(a) Results of all samples collected in a calendar month pursuant to Sections 64423, 64424, and 64425 that are not invalidated by the Department or the laboratory shall be included in determining compliance with the total coliform MCL. Special purpose samples such as those listed in §64421(b) and samples collected by the water supplier during special investigations shall not be used to determine compliance with the total coliform MCL.

(b) A public water system is in violation of the total coliform MCL when any of the following occurs:
   (1) For a public water system which collects at least 40 samples per month, more than 5.0 percent of the samples collected during any month are total coliform-positive; or
   (2) For a public water system which collects fewer than 40 samples per month, more than one sample collected during any month is total coliform-positive; or
   (3) Any repeat sample is fecal coliform-positive or E. coli-positive; or
   (4) Any repeat sample following a fecal coliform-positive or E. coli-positive routine sample is total coliform-positive.

(c) If a public water system is not in compliance with paragraphs (b)(1) through (4), during any month in which it supplies water to the public, the water supplier shall notify the Department by the end of the business day on which this is determined, unless the determination occurs after the Department office is closed, in which case the supplier shall notify the Department within 24 hours of the determination. The water supplier shall also notify the consumers served by the water system. A Tier 2 Public Notice shall be given for violations of paragraphs (b)(1) or (2), pursuant to section 64463.4. A Tier 1 Public Notice shall be given for violations of paragraphs (b)(3) or (4), pursuant to section 64463.1.

Section 64463.4 of Title 22, California Code of Regulations (CCR) states in relevant part:
§64463.4. Tier 2 Public Notice.

(a) A water system shall give public notice pursuant to this section if any of the following occurs:
  (1) Any violation of the MCL, MRDL, and treatment technique requirements, except:
    (A) Where a Tier 1 public notice is required under section 64463.1; or
    (B) Where the Department determines that a Tier 1 public notice is required, based on potential health impacts and persistence of the violations;
  (2) All violations of the monitoring and testing procedure requirements in sections 64421 through 64426.1, article 3 (Primary Standards – Bacteriological Quality), for which the Department determines that a Tier 2 rather than a Tier 3 public notice is required, based on potential health impacts and persistence of the violations;

. . . .

(b) A water system shall give the notice as soon as possible within 30 days after it learns of a violation or occurrence specified in subsection (a), except that the water system may request an extension of up to 60 days for providing the notice. This extension would be subject to the Department's written approval based on the violation or occurrence having been resolved and the Department's determination that public health and welfare would in no way be adversely affected. In addition, the water system shall:
  (1) Maintain posted notices in place for as long as the violation or occurrence continues, but in no case less than seven days;
  (2) Repeat the notice every three months as long as the violation or occurrence continues. Subject to the Department's written approval based on its determination that public health would in no way be adversely affected, the water system may be allowed to notice less frequently but in no case less than once per year. No allowance for reduced frequency of notice shall be given in the case of a total coliform MCL violation or violation of a Chapter 17 treatment technique requirement; and

. . . . .

(c) A water system shall deliver the notice, in a manner designed to reach persons served, within the required time period as follows:
  (1) Unless otherwise directed by the Department in writing based on its assessment of the violation or occurrence and the potential for adverse effects on public health and welfare, community water systems shall give public notice by;
    (A) Mail or direct delivery to each customer receiving a bill including those that provide their drinking water to others (e.g., schools or school systems, apartment building owners, or large private employers), and other service connections to which water is delivered by the water system; and
    (B) Use of one or more of the following methods to reach persons not likely to be reached by a mailing or direct delivery (renters, university students, nursing home patients, prison inmates, etc.):
      1. Publication in a local newspaper;
      2. Posting in conspicuous public places served by the water system, or on the Internet; or
      3. Delivery to community organizations.
  (2) Unless otherwise directed by the Department in writing based on its assessment of the violation or occurrence and the potential for adverse effects on public health and welfare, noncommunity water systems shall give the public notice by:

(A) Posting in conspicuous locations throughout the area served by the water system; and
(B) Using one or more of the following methods to reach persons not likely to be reached by a public posting:
1. Publication in a local newspaper or newsletter distributed to customers;
2. E-mail message to employees or students;
3. Posting on the Internet or intranet; or
4. Direct delivery to each customer.

Section 64465. of Title 22, California Code of Regulations (CCR) states in relevant part:
§64465. Public Notice Content and Format.

(a) Each public notice given pursuant to this article, except Tier 3 public notices for variances and exemptions pursuant to subsection (b), shall contain the following:
(1) A description of the violation or occurrence, including the contaminant(s) of concern, and (as applicable) the contaminant level(s);
(2) The date(s) of the violation or occurrence;
(3) Any potential adverse health effects from the violation or occurrence, including the appropriate standard health effects language from appendices 64465-A through G;
(4) The population at risk, including subpopulations particularly vulnerable if exposed to the contaminant in drinking water;
(5) Whether alternative water supplies should be used;
(6) What actions consumers should take, including when they should seek medical help, if known;
(7) What the water system is doing to correct the violation or occurrence;
(8) When the water system expects to return to compliance or resolve the occurrence;
(9) The name, business address, and phone number of the water system owner, operator, or designee of the water system as a source of additional information concerning the public notice;
(10) A statement to encourage the public notice recipient to distribute the public notice to other persons served, using the following standard language: "Please share this information with all the other people who drink this water, especially those who may not have received this public notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this public notice in a public place or distributing copies by hand or mail"; and
(11) For a water system with a monitoring and testing procedure violation, this language shall be included: "We are required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not your drinking water meets health standards. During [*compliance period dates*], we *['did not monitor or test'* or *'did not complete all monitoring or testing']* for *[contaminant(s)]*, and therefore, cannot be sure of the quality of your drinking water during that time."

. . . . .

(c) Each public notice given pursuant to this article shall contain information in Spanish regarding the importance of the notice, or contain a telephone number or address where Spanish-speaking residents may contact the water system to obtain a translated copy of the public notice or assistance in Spanish. For each non-English speaking group other than Spanish-speaking that exceeds 1,000 residents or 10% of the residents in the community served, whichever is less, the public notice shall:

(1) Contain information in the appropriate language(s) regarding the importance of the notice, or
(2) Contain a telephone number or address where such residents may contact the water system to obtain a translated copy of the notice or assistance in the appropriate language.

(d) Each public notice given pursuant to this article shall:
(1) Be displayed such that it catches people's attention when printed or posted and be formatted in such a way that the message in the public notice can be understood at the eighth-grade level;
(2) Not contain technical language beyond an eighth-grade level or print smaller than 12 point; and
(3) Not contain language that minimizes or contradicts the information being given in the public notice.

Ground Water Rule

Section 64430. of Title 22, California Code of Regulations (CCR) states in relevant part:

§64430. Requirements.

A public water system that uses ground water shall comply with the following provisions of 40 Code of Federal Regulations as they appear in the Ground Water Rule published in 71 Federal Register 65574 (November 8, 2006) and amended in 71 Federal Register 67427 (November 21, 2006) and 74 Federal Register 30953 (June 29, 2009), which are hereby incorporated by reference: Sections 141.21(d)(3), 141.28(a), 141.153(h)(6), Appendix A to Subpart O (Consumer Confidence Reports), 141.202(a)(8), 141.203(a)(4), Appendices A and B to Subpart Q (Public Notification), and 141.400 through 141.405, except that in:

(a) sections 141.402(a)(1)(ii), (a)(2), (a)(2)(ii), (a)(4), (a)(4)(ii)(A), (a)(5)(i), and (a)(5)(ii), the phrase —§141.21(a)‖ is replaced by —22 California Code of Regulations sections 64422 and 64423‖,
(b) sections 141.402(a)(1)(ii) and 141.405(b)(4), the phrase —§141.21(c)‖ is replaced by —22 California Code of Regulations section 64425‖, and
(c) section 141.402(a)(2)(iii), the phrase —§141.21(b)‖ is replaced by —22 California Code of Regulations section 64424‖.

[Note: The text reflecting this section is provided in Addendum A of this book.]

Addendum A

§141.402. Ground water source microbial monitoring and analytical methods.

(a) *Triggered source water monitoring —*
(1) *General requirements.* A ground water system must conduct triggered source water monitoring if the conditions identified in paragraphs (a)(1)(i) and (a)(1)(ii) of this section exist.
(i) The system does not provide at least 4-log treatment of viruses (using inactivation, removal, or a State-approved combination of 4-log virus inactivation and removal) before or at the first customer for each ground water source; and
(ii) The system is notified that a sample collected under 22 California Code of Regulations sections 64422 and 64423 is total coliform-positive and the sample is not invalidated under 22 California Code of Regulations section 64425.
(2) *Sampling requirements.* A ground water system must collect, within 24 hours of notification of the total coliform-positive sample, at least one ground water source sample from each ground water source in use at the time the total coliform-positive sample was collected under 22 California Code of Regulations sections 64422 and 64423, except as provided in paragraph (a)(2)(ii) of this section.

(i) The State may extend the 24-hour time limit on a case-by-case basis if the system cannot collect the ground water source water sample within 24 hours due to circumstances beyond its control. In the case of an extension, the State must specify how much time the system has to collect the sample.
(ii) If approved by the State, systems with more than one ground water source may meet the requirements of this paragraph (a)(2) by sampling a representative ground water source or sources. If directed by the State, systems must submit for State approval a triggered source water monitoring plan that identifies one or more ground water sources that are representative of each monitoring site in the system's sample siting plan under 22 California Code of Regulations sections 64422 and 64423 and that the system intends to use for representative sampling under this paragraph.
(iii) A ground water system serving 1,000 people or fewer may use a repeat sample collected from a ground water source to meet both the requirements of 22 California Code of Regulations section 64424 and to satisfy the monitoring requirements of paragraph (a)(2) of this section for that ground water source only if the State approves the use of *E. coli* as a fecal indicator for source water monitoring under this paragraph (a). If the repeat sample collected from the ground water source is *E.coli* positive, the system must comply with paragraph (a)(3) of this section.

(3) *Additional requirements.* If the State does not require corrective action under §141.403(a)(2) for a fecal indicator-positive source water sample collected under paragraph (a)(2) of this section that is not invalidated under paragraph (d) of this section, the system must collect five additional source water samples from the same source within 24 hours of being notified of the fecal indicator-positive sample.

(4) *Consecutive and wholesale systems —*
(i) In addition to the other requirements of this paragraph (a), a consecutive ground water system that has a total coliform-positive sample collected under 22 California Code of Regulations sections 64422 and 64423 must notify the wholesale system(s) within 24 hours of being notified of the total coliform-positive sample.
(ii) In addition to the other requirements of this paragraph (a), a wholesale ground water system must comply with paragraphs (a)(4)(ii)(A) and (a)(4)(ii)(B) of this section.

(A) A wholesale ground water system that receives notice from a consecutive system it serves that a sample collected under 22 California Code of Regulations sections 64422 and 64423 is total coliform-positive must, within 24 hours of being notified, collect a sample from its ground water source(s) under paragraph (a)(2) of this section and analyze it for a fecal indicator under paragraph (c) of this section.

(B) If the sample collected under paragraph (a)(4)(ii)(A) of this section is fecal indicator-positive, the wholesale ground water system must notify all consecutive systems served by that ground water source of the fecal indicator source water positive within 24 hours of being notified of the ground water source sample monitoring result and must meet the requirements of paragraph (a)(3) of this section.

(5) *Exceptions to the triggered source water monitoring requirements.* A ground water system is not required to comply with the source water monitoring requirements of paragraph (a) of this section if either of the following conditions exists:

(i) The State determines, and documents in writing, that the total coliform-positive sample collected under 22 California Code of Regulations sections 64422 and 64423 is caused by a distribution system deficiency; or
(ii) The total coliform-positive sample collected under 22 California Code of Regulations sections 64422 and 64423 is collected at a location that meets State criteria for distribution system conditions that will cause total coliform-positive samples.

Bacteriological Distribution Monitoring Report

5400624 Kings River School

Distribution System Freq: 1/M

Sample Date	*Location*	*T Coli*	*E Coli*	*F Coli*	*HPC*	*Type*	*Cl2*	*Cl2 Avg*	*Viol. Type*	*GWR Satisfied?*	*Comments*
8/10/2016	OHB @ S/Side R26	<1	<1			Repeat	0.02				
8/10/2016	OHB @ N/Side R16	<1	<1			Repeat	0.14				
8/10/2016	OHB @ N/Side R10	<1	<1			Repeat	0.2				
8/10/2016	OHB @ S/Staff RR	<1	<1			Repeat	0.13				BWO Cancelled 8/16/16
8/9/2016	OHB @ N/Side R10	<1	<1			Repeat	0.6				
8/9/2016	OHB @ S/Staff RR	<1	<1			Repeat	0.2				
8/9/2016	OHB @ N/Side R16	<1	<1			Repeat	0.4				
8/9/2016	OHB @ S/Side R26	<1	<1			Repeat	0.2				
7/18/2016	Nurse's Station	4.1	<1			Repeat	0.42				
7/18/2016	Sink in Cafeteria	2.0	<1			Repeat	0				
7/18/2016	Site - Fountain @ R14	<1	<1			Repeat	0.15				
7/18/2016	Well	<1	<1			Repeat	0.15				
7/6/2016	Pressure Tank	13.4	<1			Other	0		MCL		Level 2 Assessment
6/29/2016	Nurses Station	5.2	<1			Repeat	0.24				
6/29/2016	Fount @ R4	34.1	<1			Repeat	0.31				
6/29/2016	Fount @ R6	34.5	<1			Repeat	0.73				
6/29/2016	Sink in Cafeteria	9.6	<1			Repeat	0.92				
6/29/2016	Fountain @ R14	25.3	<1			Repeat	0.2				
6/15/2016	Well	A	A			Repeat					
6/15/2016	Nurses Station	A	A			Repeat					
6/15/2016	Sink in Cafeteria	A	A			Repeat					
6/10/2016	See notes										Pierce called to report TCR MCL for June 2016. Directed to superchlorinate system, flush and resample next week.
6/9/2016	Nurses Station	866.4	<1			Repeat					BWO Issued 6/10/16
6/9/2016	Well	1986.3	<1			Source Repeat					
6/9/2016	Sink in Cafeteria	816.4	<1			Repeat					
6/9/2016	Site - Fountain @ R14	461.1	<1			Repeat			MCL		Level 1 Assessment Sent 6/28/16 by Maria Carlson
6/7/2016	Site - Fountain @ R14	P	A			Routine					

Violation Key

MCL	Exceeds the maximum contaminant level
MR1	No monthly sample for the report month
MR2	No quarterly sample for the report month
MR3	Incorrect number of routine samples for the report month
MR4	Did not collect 5 routine samples for previous month's positive sample
MR5	Incorrect number of repeat samples as follow-up to a positive sample
MR6	No source sample
MR7	No summary report submitted
MR8	Other comments and/or info
MR9	Cl2 not reported

IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

Este informe contiene información muy importante sobre su agua potable.
Tradúzcalo o hable con alguien que lo entienda bien.

Kings River Elementary School Had Levels of Coliform Bacteria Above the Drinking Water Standard

Our water system recently failed a drinking water standard. Although this incident was not an emergency, as our customers, you have a right to know what you should do, what happened and what we did to correct this situation.

We routinely monitor for drinking water contaminants. We collected eighteen (18) samples to test for the presence of coliform bacteria in June & July 2016. Thirteen (13) of these samples showed the presence of total coliform bacteria. The standard is that no more than 1 sample per month may show the presence of coliform bacteria.

What should I do?

- **You <u>do not</u> need to boil your water or take other corrective actions.**
- This is not an emergency. If it had been, you would have been notified immediately. Total coliform bacteria are generally not harmful themselves. C*oliforms are bacteria which are naturally present in the environment and are used as an indicator that other; potentially-harmful, bacteria may be present. Coliforms were found in more samples than allowed and this was a warning of potential problems.*
- Usually, coliforms are a sign that there could be a problem with the treatment or distribution system (pipes). Whenever we detect coliform bacteria in any sample, we do follow-up testing to see if other bacteria of greater concern, such as fecal coliform or *E. coli*, are present. **We did not find any of these bacteria in our subsequent testing.**
- People with severely compromised immune systems, infants, and some elderly may be at increased risk. These people should seek advice about drinking water from their health care providers. General guidelines on ways to lessen the risk of infection by microbes are available from EPA's Safe Drinking Water Hotline at 1(800) 426-4791.
- If you have other health issues concerning the consumption of this water, you may wish to consult your doctor.

What happened? What is being done?

[Describe corrective action.]_____

_____

We anticipate resolving the problem within _____[estimated time frame].

For more information, please contact _____ at (_____) _____-_____ or at the following mailing address: _____.

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this public notice in a public place or distributing copies by hand or mail.

Secondary Notification Requirements

Upon receipt of notification from a person operating a public water system, the following notification must be given within 10 days [Health and Safety Code Section 116450(g)]:

- SCHOOLS: Must notify school employees, students, and parents (if the students are minors).
- RESIDENTIAL RENTAL PROPERTY OWNERS OR MANAGERS (including nursing homes and care facilities): Must notify tenants.
- BUSINESS PROPERTY OWNERS, MANAGERS, OR OPERATORS: Must notify employees of businesses located on the property.

This notice is being sent to you by Kings River Elementary School.
Date distributed: _____.

PROOF OF NOTIFICATION

(Return with copy of the Notice)

As required by Section 116450 of the California Health and Safety Code, I notified all users of water supplied by the **Kings River Elementary School** of the failure to meet the **total coliform bacteria MCL** for the months of **June & July 2016** as directed by the Division. At least one primary distribution method is required: mail, hand-delivery or posting in conspicuous locations. A second method is also required in order to reach persons not likely to be reached by a mailing, direct delivery or posting:

Notification was made on _____.
(date)

To summarize report delivery used and good-faith efforts taken, please check all items below that apply and fill-in where appropriate:

☐ The notice was distributed by mail delivery to each customer served by the water system.

☐ The notice was distributed by direct delivery to each customer served by the water system. Specify direct delivery method(s) used: _____

☐ Publication of the notice in a local newspaper or newsletter of general circulation (attach a copy of the published notice, including name of newspaper and date published).

☐ Posted the notice at the following conspicuous locations served by the water system (if needed, please attach a list of locations). _____

☐ Email message to employees or students._____

☐ Other method used to notify customers. _____

DISCLOSURE: Be advised that Section 116725 and 116730 of the California Health and Safety Code state that any person who knowingly makes any false statement on any report or document submitted for the purpose of compliance with the attached order may be liable for a civil penalty not to exceed five thousand dollars ($5,000) for separate violation for each day that violation continues. In addition, the violators may be prosecuted in criminal court and upon conviction, be punished by a fine of not more than $25,000 for each day of violation, or be imprisoned in the county jail not to exceed one year, or by both the fine and imprisonment.

Certified by Name and Title: _____

Date: _____ Signature: _____

Due to the Division of Drinking Water within 10 days of notification to the public
Total Coliform MCL Failure / Enforcement Action No.: 03-24-16C-019