COUNTY OF LOS ANGELES • DEPARTMENT OF PUBLIC HEALTH
ENVIRONMENTAL HEALTH
Branch of Environmental Protection
Drinking Water Program
5050 Commerce Drive, Baldwin Park, CA 91706
Phone: (626) 430-5420

COUNTY OF LOS ANGELES
Public Health

NOTICE OF VIOLATION

ENFORCEMENT NUMBER	CC0000159	DATE	09/27/2016
OWNER NAME	USDA-FOREST SERVICE	SYSTEM ID	1900586
SYSTEM NAME	USFS-CRYSTAL LAKE B-13 WATER	CLASS	TNC
SITE ADDRESS	9877 CRYSTAL LAKE RD, ANGELES NATIONAL FOREST, CA 91702-1455		
MAILING ADDRESS	701 N SANTA ANITA AVE, ARCADIA, CA 91006-2725		

California Health and Safety Code, Sections: 116275, 116650, 116555
California Code of Regulation, Title 22, Sections: 64422, 64423, 64424, 64463.7

Public water systems must comply with the Primary Standards for bacteriological quality.

To determine compliance with the Primary Standards for bacteriological quality, a public water system shall collect routine water sample(s) in accordance with the Bacteriological Sample Site Plan (BSSP) on file with the Los Angeles County Department of Public Health, Environmental Health Division (EH). The water sample(s) shall be analyzed by an approved laboratory for the presence of total coliform.

When a routine water sample is total coliform-positive, the water supplier shall collect repeat water samples within 24 hours of being notified of the positive routine sample result. A minimum of four (4) repeat samples shall be collected for <u>each</u> positive routine sample. Repeat water samples shall be collected in accordance with the BSSP.

When a public water system has a total coliform-positive result, the water system shall collect at least five (5) routine water samples the month following its return to compliance.

Public water systems that fail to collect the required number of routine / repeat water sample(s) shall issue a Tier 3 Public Notice. The Tier 3 Public Notice shall be delivered in a manner designed to reach persons served within the required time period by mail, direct delivery, and publication in a local newspaper or by posting in conspicuous public places served by the water system. Tier 3 Public Notices posted in a conspicuous public area shall remain in place for as long as the violation continues but in no case less than seven (7) days.

COUNTY OF LOS ANGELES ◆ DEPARTMENT OF PUBLIC HEALTH
ENVIRONMENTAL HEALTH
Branch of Environmental Protection
Drinking Water Program
5050 Commerce Drive, Baldwin Park, CA 91706
Phone: (626) 430-5420

COUNTY OF LOS ANGELES
Public Health

NOTICE OF VIOLATION

ENFORCEMENT NUMBER	CC0000159	DATE	09/27/2016
OWNER NAME	USDA-FOREST SERVICE	SYSTEM ID	1900586
SYSTEM NAME	USFS-CRYSTAL LAKE B-13 WATER	CLASS	TNC
SITE ADDRESS	9877 CRYSTAL LAKE RD, ANGELES NATIONAL FOREST, CA 91702-1455		
MAILING ADDRESS	701 N SANTA ANITA AVE, ARCADIA, CA 91006-2725		

VIOLATION DESCRIPTION:

The water system failed to collect five (5) routine water samples during the month of August, 2016.

CORRECTIVE ACTION:

You are hereby directed by EH to comply with the Primary Standards for bacteriological quality.

The attached Tier 3 Public Notice shall be posted in a conspicuous public area and remain in place for as long as the violation continues but in no case less than 7 days.

Certification of the delivery and/or posting of the Tier Public Notice must be completed and returned to EH at swsadmin@ph.lacounty.gov.

You may contact the Drinking Water Program at 626-430-5420 for any questions regarding this enforcement action.

Lusi Mkhitaryan
Chief Environmental Health Specialist

Enclosures: Tier 3 Public Notice
Certification for Tier Public Notice