

California Regional Water Quality Control Board
North Coast Region

MONITORING AND REPORTING PROGRAM NO. R1-2003-0008

FOR

MIRANDA COMMUNITY SERVICES DISTRICT
WASTEWATER TREATMENT FACILITY

Humboldt County

MONITORING

Samples shall be collected at the point of discharge after disinfection.

<u>Constituent</u>	<u>Units</u>	<u>Type of Sample</u>	<u>Sampling Frequency</u>
BOD (20°C, 5-day)	mg/l	grab	monthly
TSS	mg/l	grab	monthly
Settleable Solids	ml/l	grab	weekly
Hydrogen Ion	pH units	grab	weekly
Total Coliform Organisms	MPN/100 ml	grab	monthly
Total Chlorine	mg/l	grab	daily
Flow ^a	gpd	meter	continuous

The Discharger shall record and report any significant facility maintenance activities.

REPORTING

Monthly monitoring reports shall be submitted to the Regional Water Board by the first day of the second month following monitoring period. The results of all water quality monitoring performed shall be submitted in the monthly monitoring reports.

In reporting the monitoring data, the Discharger shall arrange the data in tabular form on an 8 1/2- by 11-inch sheet so that the date, the constituents, and the concentrations and location of the sampling point are readily discernible. The data shall be summarized in such a manner as to illustrate clearly the compliance with waste discharge requirements. If the Discharger is unable to collect samples for any reason, the monitoring report shall so indicate. The monitoring data and any necessary narrative reports shall be properly titled and referenced to this Order and shall be submitted to the Regional Water Board and certified to be true and correct by penalty of perjury.

Ordered by _____

Susan A. Warner
Executive Officer

February 27, 2003

MirandaCSD_M&R

^a Reported as a daily total