

California Regional Water Quality Control Board
North Coast Region

ORDER NO. R1-2003-0029

AMENDMENT OF WASTE DISCHARGE REQUIREMENTS
ORDER NO. 97-80
WDID NO. 1B97026RSON

FOR

CHANGE OF OWNERSHIP FROM
SHILOH MEADOW ASSOCIATION
TO
MAYACAMA GOLF CLUB, LLC
MAYACAMA WASTEWATER RECLAMATION FACILITY

Sonoma County

The California Regional Water Quality Control Board, North Coast Region, (hereinafter Regional Water Board) finds that:

1. This Order amends existing Regional Water Board Waste Discharge Requirements, Order No. 97-80, to recognize a change in the Mayacama Wastewater Reclamation Facility's ownership from Shiloh Meadow Association to Mayacama Golf Club, LLC (Discharger). The new owner of the Mayacama Wastewater Reclamation Facility (Facility) proposes no material changes to the character, location, or volume of discharges authorized by the existing Waste Discharge Requirements, Order No. 97-80, and none is authorized herein.
2. The Facility service area includes 31 single-family residential parcels and an 18-hole golf course. The golf course facilities include a clubhouse with dining facilities and 50 lodge units. The Facility is designed to provide advanced wastewater treatment for an influent average dry weather flow of 0.025 million gallons per day (MGD).
3. The Facility will include biological secondary treatment utilizing an aerated pond and a settling pond followed by advanced wastewater treatment using a microfiltration system. The treated effluent is disinfected with a sodium hypochlorite disinfection system. The treated wastewater is stored in a 5.9 million gallon storage pond and then used to irrigate 11.5 acres of the golf course.
4. The site is owned by the Discharger and located within the Mark West Springs drainage area; SE corner of Section 22 T8N, R8W; 38° 31' 45" latitude and 122° 43' 59" longitude. The address of the Facility is 525 Mayacama Club Drive, Santa Rosa.
5. The Regional Water Board has notified the Discharger and interested parties of its intent to amend the below-listed Regional Water Board Order by substituting therein the current ownership of the Facility.

6. The Regional Water Board heard and considered all comments pertaining to this Order.
7. This action is exempt from CEQA under Title 14, California Code of Regulations, Sections 15060(c)(2) and 15061(b)(3).

IT IS HEREBY CERTIFIED, that Waste Discharge Requirements Order No. 97-80 is hereby amended to reflect the new owner and operator of the site as follows:

<u>Order</u>	<u>Name of Facility</u>	<u>Owner</u>
97-80	Mayacama Wastewater Reclamation Facility	Mayacama Golf Club, LLC 525 Mayacama Club Drive Santa Rosa, CA 95403

Upon adoption of this Order, all references to Discharger or Shiloh Meadow Association in Waste Discharge Requirements Order No. 97-80 shall mean the Mayacama Golf Club, LLC.

Certification

I, Susan A. Warner, Executive Officer, do hereby certify that the foregoing is a full, true, and correct copy of an Order adopted by the California Regional Water Quality Control Board, North Coast Region, on March 27, 2003.

Susan A. Warner
Executive Officer