

California Regional Water Quality Control Board  
North Coast Region

MONITORING AND REPORTING PROGRAM NO. R1-2003-0034

FOR

LEIGH ROBINSON dba  
VALLEY OAKS MOBILE HOME PARK WASTEWATER TREATMENT FACILITY

Mendocino County

**Effluent Monitoring**

Composite effluent samples shall be collected at a point after treatment and before the leachfield disposal area.

<u>Constituent</u>	<u>Units</u>	<u>Type of Sample</u>	<u>Sampling Frequency</u>
BOD (20°C, 5-day)	mg/L	grab	every six months
Total Suspended Solids	mg/L	grab	monthly
Settleable Solids	mL/L	grab	monthly
pH	pH units	grab	monthly
Total Flow	gpd	meter	daily

**Groundwater Monitoring**

Depth to groundwater, in inches below ground surface, shall be measured at four monitoring wells placed in locations designated by "MW" on Attachment "C". The monitoring wells shall be installed in accordance with specifications shown on the attached Figure "1". Measurement frequency shall be according to the following schedule.

Minimum Measurement Frequency

<u>Time Period</u>	<u>Frequency</u>
October 1 through April 30	weekly
May 1 through September 31	monthly

**Septic Tank Inspections**

Sludge and scum levels in the septic tank shall be checked monthly to determine the need for pumping.

Receipts from a licensed septic hauler shall be submitted, as needed, as part of the monthly monitoring reports.

### **Disposal Field Inspections**

The discharger shall thoroughly inspect each disposal field once per week and shall note and record any odors, evidence of surfacing wastewater, or other signs of malfunction.

### **Maintenance and Operation**

Septic tank effluent filters shall be checked once per month and replaced or cleaned as necessary.

### **Reporting**

Monthly monitoring reports shall be submitted to the Regional Water Board for each month by the first day of the second month following the monthly monitoring period. The results of all water quality monitoring performed shall be submitted in the monthly monitoring reports. In reporting the monitoring data, the discharger shall arrange the data in tabular form on an 8 1/2- by 11-inch sheet so that the date, the constituents, and the concentrations and location of the sampling point are readily discernible. The data shall be summarized in such a manner as to illustrate clearly the compliance with waste discharge requirements.

Ordered by \_\_\_\_\_

Susan A. Warner  
Executive Officer

February 25, 2003