

California Regional Water Quality Control Board  
North Coast Region

Monitoring and Reporting Program No. R1-2004-0070

FOR

Crescent City Printing  
381 H Street  
Crescent City, California

Del Norte County

MONITORING

1. The presence of floating product shall be evaluated in each monitoring well quarterly. If detected, the thickness shall be measured to at least 0.01 foot increments quarterly.
2. The depth to groundwater in each monitoring well shall be determined to at least 0.01 foot increments quarterly. The results of each quarter's elevation shall be reported in tabular form indicating the surveyed elevations of each well reference point, depth to groundwater from reference point, and the actual groundwater elevation. The data generated from the elevation readings must be referenced to mean sea level.
3. Each monitoring well shall be sampled quarterly. The analyses shall be performed at a certified laboratory for Total Petroleum Hydrocarbons as diesel, benzene, toluene, ethylbenzene, xylene, and MTBE.

REPORTING

A groundwater elevation contour map shall be submitted for each quarterly set of measurements and include the facility, groundwater flow pattern including the direction of the groundwater gradient, and the location of the wells measured. Quarterly monitoring reports, including quarterly gradient data and quarterly sampling data, shall be submitted to this office in accordance with the following schedule:

**Reporting Period**

**Due Date**

January, February, March

April 15

April, May, June

July 15

July, August, September

October 15

October, November, December

January 15

Ordered by \_\_\_\_\_

Catherine E. Kuhlman  
Executive Officer

August 13, 2004