

California Regional Water Quality Control Board
North Coast Region

MONITORING AND REPORTING PROGRAM NO. R1-2003-0087

FOR

CITY OF EUREKA
MAD RIVER PIPELINE PROJECT

Humboldt County

MONITORING

A. Wastewater

The effluent from dewatering activities shall be monitored for the following:

<u>Parameter</u>	<u>Units</u>	<u>Type of Sample</u>	<u>Sampling Frequency¹</u>
Flow	gals/day	---	continuous
Turbidity	ntu	grab	daily
Conductivity	micromhos	---	daily

B. Receiving Water

The receiving water shall be monitored for the following:

<u>Parameter</u>	<u>Units</u>	<u>Type of Sample</u>	<u>Sampling Frequency¹</u>
Turbidity	ntu	grab	daily
Conductivity	micromhos	---	daily

C. Reporting

Monitoring reports shall be submitted to the Regional Water Board such that they are received by the first day of the second week following the completion of the project's dewatering activities. Monitoring reports shall contain all monitoring results that were obtained during the project duration. In reporting the monitoring data, the discharger shall arrange the data in tabular form so that the date and monitoring information are readily discernible. The data shall be summarized in such a manner as to illustrate clearly the compliance with Waste Discharge Requirements. Narrative reporting should be in a letter form and signed by the responsible representative.

Ordered by Frank Pearl Dfn
Susan A. Warner
Executive Officer

July 17, 2003

KLJ:js/Eureka_Monitoring

¹ When construction activities are occurring