
North Coast Regional Water Quality Control Board

**Change Sheet
Waste Discharge Requirements
Order No. R1-2023-0004
National Pollutant Discharge Elimination System (NPDES)
For the
Redway Community Services District
Wastewater Treatment Facility
Regional Water Quality Control Board, North Coast Region
February 2, 2023**

Staff Initiated Changes to Permit

Late changes to the Proposed Permit were made by Regional Water Board staff to identify that the new Toxicity Provisions included in the *Water Quality Control Plan for Inland Surface Waters, Enclosed Bays, and Estuaries of California*, as adopted by the State Water Board on December 1, 2020, have not yet been approved by U.S. EPA. Text added to the Proposed Permit is identified by underline and text to be deleted from the Proposed Permit is identified by strike-through in this document. Page numbers in parentheses reflect page numbers in the Proposed Order in the Agenda Package. The following are the changes made to the Proposed Order:

Change No. 1: Footnote 1 has been added to Section 4.1.4 of the Order (page 10) to identify that the Toxicity Provisions are still waiting for final approval from the U. S. EPA and reads as follows:

4.1.4. **Chronic Toxicity**¹. As measured at Monitoring Location EFF-001, there shall be no chronic toxicity in treated wastewater discharged to the South Fork Eel River at Discharge Point 001. Compliance with this chronic toxicity effluent limitation shall be determined in accordance with section 7.9 of this Order and sections 5.1 and 5.2 of the MRP, Attachment E of this Order.

¹ Chronic toxicity requirements included in this Order are included consistent with the Toxicity Provisions. The Toxicity Provisions were adopted by the State Water Resources Control Board on December 1, 2020 and approved by the California Office of Administrative Law on April 25, 2022. The permittee shall comply with the Toxicity Provisions upon approval by the U.S. EPA.