

ATTACHMENT A



City of Yreka
701 Fourth Street • Yreka, CA 96097
(530) 841-2386 • FAX (530) 842-4836

W 3 9 4 0 0 8

8 2 9 2 4 2 0 0 8



July 29, 2008

✓ KG

Kason Grady
California Regional Water Quality Control Board, North Coast Region
5550 Skylane Boulevard, Suite A
Santa Rosa, CA 95403

Dear Mr. Grady:

Subject: Administrative Civil Liability Complaint No. R1-2008-0059
Proposal for Project in Lieu of Portion of Penalty

The City of Yreka proposes to complete a Project in its wastewater collection system in lieu of the payment of \$25,750 of the total penalty of \$36,500 for the settlement of Administrative Liability Complaint No. R1-2008-0059.

The City proposes to repair certain deficiencies in its collection system that have caused problems in the past. These sections of pipe have been videoed and the condition of the pipes observed. The proposed solutions have been developed based on the video observations.

The scope of the project, including the locations, deficiencies, problems, and solutions are shown below. All work will be completed by November 1, 2009, and progress reports can be submitted as requested.

Location: Lane Street west of S. Gold Street
Deficiency: Broken pipe
Problem: Roots grow through broken pipe and cause blockages
Solution: Replace 60' of pipe

Location: South Street, 700 block
Deficiency: Broken pipe & offsets
Problem: Offsets catch debris and cause blockages
Solution: Replace 50' of pipe

Location: 305 South Street heading west
Deficiency: a) Broken pipe in beaver slide
b) Broken pipe with missing crown
Problem: a) Broken pipe catches debris and causes blockages
b) Roots and soil come thru missing crown and cause blockages
Solution: a) Replace 20' pipe & remove beaver slide
b) Replace 30' of pipe

Location: North Street between N. Gold & Pine Streets
Deficiency: Belly in line
Problem: Belly collects soap and grease and causes blockages
Solution: Replace 80' of pipe

Location: 500 W. Center Street to S. Gold Street
Deficiency: Broken pipe with missing crown
Problem: Roots and soil come through missing crown and cause blockages. 90° bend does not allow proper cleaning
Solution: Replace 80' of broken pipe & tight 90° bend

Location: S. Oregon Street between Lane & Butte Streets
Deficiency: Broken pipe
Problem: Roots grow through broken pipe and cause blockages, beaver slide does not allow proper cleaning
Solution: Replace 80' of pipe, remove beaver slide & install manhole

Location: Lane Street west of S. Oregon Street
Deficiency: Broken pipe with missing crown
Problem: Roots and soil come through missing crown and cause blockages
Solution: Replace 30' of pipe


Location: Yama Street & N. Fairchild Street intersection
Deficiency: Broken pipe (starting to collapse)
Problem: Soil comes through broken pipe and causes blockages
Solution: Replace 20' of pipe

Location: Turre Street & S. Main Street
Deficiency: Large belly
Problem: Belly collects soap and grease and causes blockages
Solution: Replace 60' of pipe

Location: Fairgrounds @ Maintenance Building
Deficiency: Broken pipe, pipe missing with rocks in line
Problem: Rocks come through broken pipe and cause blockages
Solution: Replace 100' of pipe

Thank you for your assistance with the development of this project. Please call me at (530) 841-2319 if you have any questions.

Sincerely,



Steven D. Neill, P.E.
Director of Public Works