

October 24, 2011

Notice of Proposed Corrective Action Plan

For

Humboldt County Department of Public Works
Sign Yard Maintenance Station
931 Second Street
Eureka, CA

Case No. 1THU113

Posted Date: October 24, 2011

Comment Period ends November 23, 2011

Problem Description

A Humboldt County Department of Public Works Maintenance Station exists and operates at 931 Second Street in Eureka, California (Site). The Site had one former 2,000-gallon underground storage tank (UST) that contained gasoline. This UST was removed in 1998. Subsurface investigative work revealed soil and groundwater impacts from fuel discharges. The contaminants of concern are gasoline constituents in concentrations exceeding water quality objectives. In addition, soil contamination exists at the Site.

Proposed Corrective Action

The proposed corrective action is to excavate contaminated soil and extract and treat groundwater. The excavation effort is not currently scheduled. Monitoring will follow these activities to determine if additional groundwater treatment is needed in the future using oxidation technology.

North Coast Regional Water Quality Control Board staff intends to concur with the proposed action without further notice unless significant public comment is received by November 23, 2011. Please contact David W. Parson PG 6037, CEG 1889 at (707) 576-2556 or at DParson@waterboards.ca.gov with any questions or comments regarding this project. You may also submit written comments to:

**North Coast Regional Water Quality Control Board
Attention: David W. Parson PG 6037, CEG 1889
5550 Skylane Boulevard, Suite A
Santa Rosa, CA 95403**

Additional information regarding this site can also be obtained through the Internet by going to the GeoTracker website at <http://geotracker.waterboards.ca.gov>, following the "Case Finder" link, and entering the case number for this Site (1THU113).

(111024_CAP_1THU113_PN)