

Notice of Proposed No Further Action

For

Fava Lane Property
2340 Laguna Road
Santa Rosa
Case No. 1TS0549

Sonoma County

Notice Posting Date: September 8, 2014

Comment Period Ends: November 7, 2014

Problem Description

The Regional Water Board was contacted by Sonoma County Public Health Department that an Underground Storage Tank was removed from the property in January 1993. It was noted that there were holes in the bottom of the tank.

Actions Completed

The Underground Storage Tank was removed from the property in January 1993. The analytical results from the soil samples collected from beneath the tank showed the presence of Total Petroleum Hydrocarbons as gasoline. Subsequent water testing of nearby wells were negative for contaminants. This site meets the State Water Resources Control Board's "Low-Threat Underground Storage Tank Case Closure Policy."

Proposed Action

Unless significant comments are received or new information is presented regarding this site, Regional Water Board staff plans to proceed with the "no further action" determination upon conclusion of the comment period. Please contact Keith Baldanza at (707) 576-6732 or e-mail, Keith.Baldanza@waterboards.ca.gov for all issues concerning the subject case. Written comments may also be submitted to:

North Coast Regional Water Quality Control Board
Attention: Keith Baldanza
5550 Skylane Blvd, Suite A
Santa Rosa, CA 95403

The Regional Water Board records for the site are contained in the file known as the Fava Lane Property, 2340 Laguna Road, Santa Rosa, Case No. 1TS0549. The file may be reviewed at the North Coast Regional Water Quality Control Board office from 8:00 am to 5:00 pm Monday through Friday. Appointments are recommended and can be arranged by calling (707) 576-2220.