

Notice of Proposed No Further Action

For

Lake Mendocino Marina
1299 Marina Drive
Calpella, CA
Case No. 1TMC366

Mendocino County

Notice Posting Date: October 30, 2014

Comment Period Ends: December 29, 2014

Problem Description

Lake Mendocino Marina (Site) is a former marina facility located at 1250 Marina Drive, Ukiah, California (Figure 1), which held two 1,000-gallon underground storage tanks (UST) and one 2,000-gallon UST. In 1997 there was a leak in the lines at the dock and gas was released into the water.

Actions Completed

In May 1999, all three tanks and their supply lines were removed. Three soil borings were advanced to between 39 and 41 feet below ground surface (bgs). Continuous soil cores were collected from the ground surface to the total depth of the boring. None of the borings penetrated to the site groundwater level. There was minor soil contamination of diesel and lead well below levels that could adversely affect human health.

Proposed Action

Unless significant comments are received or new information is presented regarding this site, Regional Water Board staff plans to proceed with the “no further action” determination upon conclusion of the comment period. Please contact Keith Baldanza at (707) 576-6732 or e-mail, Keith.Baldanza@waterboards.ca.gov for all issues concerning the subject case. Written comments may also be submitted to:

North Coast Regional Water Quality Control Board
Attention: Keith Baldanza
5550 Skylane Blvd, Suite A
Santa Rosa, CA 95403

The Regional Water Board records for the site are contained in the file known as Lake Mendocino Marina, 1299 Marina Drive, Calpella, CA, Case No. 1TMC366. The file may be reviewed at the North Coast Regional Water Quality Control Board office from 8:00am to 5:00pm Monday through Friday. Appointments are recommended and can be arranged by calling (707) 576-2220. Some file materials are also available on the Geotracker website at http://geotracker.waterboards.ca.gov/profile_report.asp?global_id=T0604500300