

STATE OF CALIFORNIA  
REGIONAL WATER QUALITY CONTROL BOARD  
SAN FRANCISCO BAY REGION

STAFF SUMMARY REPORT (Myriam Zech)  
MEETING DATE: November 17, 2004

ITEM: 7

SUBJECT: PACIFIC GAS AND ELECTRIC COMPANY, HUNTERS POINT POWER PLANT, San Francisco, San Francisco County - Hearing to Consider Mandatory Minimum Penalty for Discharge of Partially Treated Wastewater to Waters of the State

CHRONOLOGY: There have been no previous MMPs for this facility.

DISCUSSION: On July 14, 2000, Pacific Gas and Electric Company's Hunters Point Power Plant exceeded its NPDES permit's chlorine residual limit. This is a serious violation and subject to a \$3,000 MMP.

Pacific Gas and Electric Company has signed the waiver to a Board hearing and intends to remit the full penalty payment to the State Water Pollution Cleanup and Abatement Account.

RECOMMEN-  
DATION No action required

File No.: 2169.6003

Appendix: A. Complaint No. R2-2004-0083 and signed waiver.

## Appendix A