

ATTACHMENT 1

STATE OF CALIFORNIA
REGIONAL WATER QUALITY CONTROL BOARD
CENTRAL COAST REGION

RESOLUTION R3-2009-0011
CORRECTION OF ERRATA
WASTE DISCHARGE REQUIREMENTS ORDER NO. R3-2005-0035
(NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM NO. CA0048267)
BIG BASIN STATE PARK, SANTA CRUZ COUNTY

WHEREAS, on May 13, 2005, at a regularly scheduled public meeting, the Central Coast Water Board adopted Waste Discharge Requirements (WDRs) Order No. R3-2005-0035 (National Pollutant Discharge Elimination System Permit No. CA0048267), which regulates the discharge of treated domestic wastewater to Waddell Creek in Santa Cruz County, and

WHEREAS, WDRs Order No. R3-2005-0035 specifies effluent limitations for wastewater constituents including, in the Order's Table A, Biochemical Oxygen Demand (BOD), Total Suspended Solids (TSS), Oil and Grease (O&G), Methylene Blue Active Substances (MBAS), and unionized ammonia (as N) and, in Effluent Limitation No. D.2, the effluent daily dry weather flow, and

WHEREAS, Effluent Limitation No. D.2 incorrectly limits the flow to 0.03 million gallons per day (MGD), and Table A incorrectly limits the BOD and TSS Monthly Average, Weekly Average, and Daily Maximum discharges to 2.5, 3.76 and 6.26 pounds per day (lbs/day), respectively; incorrectly limits the O&G Monthly Average, Weekly Average, and Daily Maximum discharges to 6.26, 10 and 18.8 lbs/day, respectively; incorrectly limits the MBAS discharge to a daily maximum of 0.05 lbs/day and the unionized ammonia discharge to a daily maximum of 0.006 lbs/day, and

WHEREAS, the correct average daily dry weather monthly average flowrate limitation is 0.09 MGD, the correct BOD and TSS Monthly Average, Weekly Average, and Daily Maximum effluent limitations are 8, 11, and 19 lbs/day, respectively; the correct O&G Monthly Average, Weekly Average, and Daily Maximum effluent limitations are 19, 30, and 56 lbs/day, respectively; the correct Monthly Average MBAS discharge limitation is 0.015 lbs/day, and the correct unionized ammonia discharge limitation is 0.019 lbs/day, and

WHEREAS, on December 4, 2008, the Board notified the Discharger and interested agencies and persons of its intent to issue waste discharge requirements for the discharge and has provided them with a copy of the proposed Order and an opportunity to submit written views and comments, and

WHEREAS, after considering all comments pertaining to this discharge during a public hearing on March 20, 2009, this Order was found consistent with the above findings.

NOW, THEREFORE, BE IT RESOLVED, the Central Coast Water Board changes the Effluent Limitations for BOD, TSS, O&G, MBAS, unionized ammonia, and daily average dry weather flowrate in Waste Discharge Requirements Order No. R3-2005-0035 to the correct values.

Item No. 8, Attachment 1
Big Basin WWTP
March 19-20, 2009