

ATTACHMENT A

SCREENING LEVELS FOR POTENTIAL POLLUTANTS OF CONCERN
IN POTABLE WATER USED FOR HYDROSTATIC TESTING
(Screening to be conducted on a source water sample prior to issuance of permit)

Pollutant	Screening Criteria		Maximum Contaminant Levels	Minimum Levels (ML)
	MUN ^(a)	Others ^(b)		
	(µg/L)	(µg/L)	(µg/L)	(µg/L)
Arsenic	10.00	10.00	10	1
Cadmium (Cd)	2.4	9.4	5	0.5
Copper	9.4	3.7	1000	0.5
Lead (Pb)	3.2	8.5	50	0.5
Mercury (Hg)	0.050	0.051	2	0.2
Selenium (Se)	5.0	71	10	2
Silver (Ag)	4	2.2	50	0.25
Total Chromium	50	--	50	10
1,1 Dichloroethane	5	5	5	1
1,1 Dichloroethylene	0.057	3.2	6	0.5
1,1,1 Trichloroethane	200	200	200	2
1,1,2 Trichloroethane	0.60	42	5	0.5
1,1,2,2 Tetrachloroethane	0.17	1	1	0.5
1,2 Dichloroethane	0.38	99	0.5	0.5
1,2-Trans Dichloroethylene	10	10	10	1
1,4 Dichlorobenzene	5	0.5	5	0.5
Benzene	1	1	1	0.5
Carbon Tetrachloride	0.25	0.5	0.5	0.5
Ethylbenzene	700	700	700	2
Ethylene Dibromide	0.05	0.05	0.05	na
Methyl tertiary butyl ether (MTBE)	5	5	5	na
Tetrachloroethylene	0.8	8.85	5	0.5
Toluene	150	150	150	2
Total Trihalomethanes	--	--	80	--
Trichloroethylene	2.7	5	5	0.5
Vinyl Chloride	0.5	0.5	0.5	0.5
Xylenes	1750	1750	1750	na

(a) = Applies to water with Municipal and Domestic Supply (MUN)
(indicated with E and I in the Basin Plan) beneficial uses designations.

(b) = Applies to all other receiving waters.