

**CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
LOS ANGELES REGION**

582nd Regular Board Meeting
Thursday, November 6, 2014 – 9:00 a.m.

ITEM NO. 13.1

ORDER NO. R4-2014-XXXX
NPDES No. CA0059501

WASTE DISCHARGE REQUIREMENTS
FOR THE
Camrosa Water District
(CAMROSA WATER RECLAMATION FACILITY)

CHANGE SHEET

(Additions are underlined, deletions are lined over)

The following change to the revised Permit is a clarification suggested by the Regional Water Board staff.

1. Waste Discharge Requirements Section VI.C.6.b.i, Agenda Page 13.1-107, (WDR Page 23)
Clarify bacteria sampling for spills consistent with the Basin Plan Water Quality Objective

b. Monitoring

For spills, overflows and bypasses reported under section VI.C.6.a, the Permittee shall monitor as required below:

- i. To define the geographical extent of the spill's impact, the Permittee shall obtain grab samples (if feasible, accessible, and safe) for all spills, overflows or bypasses of any volume that reach any waters of the state (including surface and ground waters). The Permittee shall analyze the samples for total coliform~~and~~, fecal coliforms,~~or~~ E. coli, (if fecal coliform tests positive), ~~and~~ enterococcus (if the spill reaches the marine waters), and relevant pollutants of concern, upstream and downstream of the point of entry of the spill (if feasible, accessible, and safe). This monitoring shall be done on a daily basis from the time the spill is known until the results of two consecutive sets of bacteriological monitoring indicate the return to the background level or the County Department of Public Health authorizes cessation of monitoring.