

From: "Yulya Borroum" <borroum@ecologic-eng.com>
To: "Diana C Messina" <DCMessina@waterboards.ca.gov>
Date: 9/24/2008 2:15 PM
Subject: RE: Issuance of Tentative NPDES Permit - City of Colusa WastewaterTreatment Plant

Hi Diana,

I just noticed that there is a typo on page 14 of the tentative permit in section IV.A.1.o.i - the Nitrate + nitrite limit is listed as 10 ug/L. I believe it should be 10 mg/L.

Please, advice if we have to provide formal comments regarding this issue, or if you will just correct the typo.

Thanks,

Yulya Borroum, P.E.
916-773-8100 phone

-----Original Message-----

From: Diana C Messina [mailto:DCMessina@waterboards.ca.gov]
Sent: Tuesday, September 23, 2008 11:15 AM
To: citymanager@colusanet.com
Cc: Patty Hickel; Yulya Borroum
Subject: Issuance of Tentative NPDES Permit - City of Colusa WastewaterTreatment Plant

Dear Ms. McClintoch:

As a result of the Regional Water Quality Control Board's continuation of the July 2008 public hearing for the City of Colusa Wastewater Treatment Plant NPDES permit, a second Tentative Permit has been issued from our office. Attached are the electronic copies of the Notice of Continuation of Public Hearing and the corresponding tentative permit.

As instructed by the cover letter below (first attachment), the City must post a hardcopy of the Notice of Continuation of Public Hearing at the Wastewater Treatment Plant and at other official public locations by 24 September 2008 (tomorrow). This date is the beginning of a 30-day public comment period for the revisions made to the tentative permit since the July 2008 hearing. This item is proposed to be heard by the Regional Water Board for consideration of adoption at the 4/5 December 2008 Board Meeting.

We met with Patty Hickel of your staff, and both Patty and Yulya Borroum (consultant) have been kept up to date with the proposed changes. Please note that all public comments, including the City's, are due to this office by 24 October 2008.

Please let me know if you have any questions.

Diana Messina

Diana C. Messina, Senior Engineer
NPDES - Sacramento Watershed Unit
Central Valley Water Board
11020 Sun Center Drive, Suite 200
Rancho Cordova, CA 95670
dcmessina@waterboards.ca.gov
(916) 464-4828