

CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
CENTRAL VALLEY REGION

MONITORING AND REPORTING PROGRAM NO. R5-2010-____
FOR
CITY OF REEDLEY
WASTEWATER TREATMENT FACILITY
FRESNO COUNTY

This Monitoring and Reporting Program (MRP) is required pursuant to California Water Code (CWC) section 13267 and is incorporated in Waste Discharge Requirements Order No. R5-2010-____ (WDRs).

The Discharger shall not implement any changes to this MRP unless and until the Central Valley Water Board adopts or the Executive Officer issues a revised MRP. Changes to sample locations shall be established with concurrence of Central Valley Water Board staff, and a description of the revised stations shall be submitted for approval by the Executive Officer.

All samples shall be representative of the volume and nature of the discharge or matrix of material sampled. All analyses shall be performed in accordance with **Standard Provisions and Reporting Requirements for Waste Discharge Requirements**, dated 1 March 1991 (Standard Provisions)

Field test instruments (such as pH) may be used provided that the operator is trained in the proper use of the instrument and each instrument is serviced and/or calibrated at the recommended frequency by the manufacturer or in accordance with manufacturer instructions.

Analytical procedures shall comply with the methods and holding times specified in the following: *Methods for Organic Chemicals Analysis of Municipal and Industrial Wastewater* (EPA); *Test Methods for Evaluating Solid Waste* (EPA); *Methods for Chemical Analysis of Water and Wastes* (EPA); *Methods for Determination of Inorganic Substances in Environmental Samples* (EPA); *Standard Methods for the Examination of Water and Wastewater* (APHA/AWWA/WEF); and *Soil, Plant and Water Reference Methods for the Western Region* (WREP 125). Approved editions shall be those that are approved for use by the United States Environmental Protection Agency or the California Department of Public Health's Environmental Laboratory Accreditation Program). The Discharger may propose alternative methods for approval by the Executive Officer.

If monitoring consistently shows no significant variation in magnitude of a constituent concentration or parameter after at least 12 months of monitoring, the Discharger may request the MRP be revised to reduce monitoring frequency. The proposal must include adequate technical justification for reduction in monitoring frequency.

A glossary of terms used within this MRP is included on [page 9](#) and a list of the constituents required for the monitoring of Priority Pollutants is included in Table 1, which is on [page 10](#).

INFLUENT MONITORING

Influent samples shall be collected at the inlet of the headworks of the WWTF. Time of collection of the sample shall be recorded. Influent monitoring shall include at least the following:

<u>Frequency</u>	<u>Constituent/Parameter</u>	<u>Units</u>	<u>Sample Type</u>
Continuous	Flow	mgd	Meter
Weekly	pH	pH Units	Grab
Weekly	EC	µmhos/cm	Grab
Weekly	BOD ₅	mg/L	24-hour composite
Weekly	TSS	mg/L	24-hour composite
Monthly	Monthly Average Flow	mgd	Computed

EFFLUENT MONITORING

Effluent samples shall be collected at a point in the system following treatment and before discharge to the effluent percolation ponds. Time of collection of the sample shall be recorded. Effluent monitoring shall include the following:

<u>Frequency</u>	<u>Constituent/Parameter</u>	<u>Units</u>	<u>Sample Type</u>
Weekly	pH	pH Units	Grab
Weekly	EC	µmhos/cm	Grab
Weekly	BOD ₅	mg/L	24-hour composite
Weekly	TSS	mg/L	24-hour composite
Weekly	Nitrate (as N) ¹	mg/L	24-hour composite
Weekly	TKN ¹	mg/L	24-hour composite
Weekly	Total Nitrogen ¹	mg/L	Computed
Quarterly	General Minerals ²	mg/L	24-hour composite
Once every 5 years ³	Priority Pollutants (see Table 1)	Varies ⁴	Varies

¹ Weekly monitoring shall take place for at least one year. If monitoring results show that there are no significant variations in magnitude of a constituent concentration, and after approval by the Executive Officer, the monitoring frequency can be reduced to monthly.

² Quarterly monitoring shall take place for at least one year. If monitoring results show that there are no significant variations in magnitude of a constituent concentration, and after approval by the Executive Officer, the monitoring frequency can be reduced to annually.

³ Beginning in [60 days after adoption of this Order](#).

⁴ mg/L or µg/L, as appropriate.

POND MONITORING

Permanent markers (e.g., staff gages) shall be placed in all percolation ponds. The markers shall have calibrations indicating water level at the design capacity and available operational freeboard.

Effluent percolation pond monitoring shall include at least the following:

<u>Frequency</u>	<u>Constituent/Parameter</u>	<u>Units</u>	<u>Sample Type</u>
As Required ¹	DO	mg/L	Grab ²
Weekly	Freeboard	Feet ³	Observation

¹ If offensive odors are detected by or brought to the attention of WWTF personnel, the Discharger shall monitor affected pond(s) daily in the morning prior to 9:00 a.m. until dissolved oxygen concentrations equal or exceed 1.0 mg/L.

² Samples shall be collected at a depth of one foot from each pond, opposite the inlet. Time of sampling shall be reported.

³ To the nearest tenth of a foot

The Discharger shall inspect the condition of the percolation ponds weekly and record visual observations in a bound logbook. Notations shall include observations of whether weeds are developing in the water or along the bank, and their location; whether grease, dead algae, vegetation, scum, or debris are accumulating on the percolation pond surface and their location; whether burrowing animals or insects are present; and the color of the reservoirs (e.g., dark sparkling green, dull green, yellow, gray, tan, brown, etc.). A summary of the entries made in the log shall be included in the subsequent monitoring report.

GROUNDWATER MONITORING

After measuring water levels and prior to collecting samples, each monitoring well shall be adequately purged to remove water that has been standing within the well screen and casing that may not be chemically representative of formation water. Depending on the hydraulic conductivity of the geologic setting, the volume removed during purging is typically from 3 to 5 volumes of standing water within the well casing and screen, or additionally the filter pack pore volume.

The Discharger shall monitor all wells in its Groundwater Monitoring Network, and any additional wells installed pursuant to this MRP, for the following:

<u>Frequency</u>	<u>Constituent/Parameter</u>	<u>Units</u>	<u>Sample Type</u>
Quarterly	Depth to groundwater	Feet ¹	Measured
Quarterly	Groundwater Elevation	Feet ²	Computed
Quarterly	pH	pH Units	Grab
Quarterly	EC	µmhos/cm	Grab
Quarterly	Nitrate (as N)	mg/L	Grab
Quarterly	TKN	mg/L	Grab

<u>Frequency</u>	<u>Constituent/Parameter</u>	<u>Units</u>	<u>Sample Type</u>
Quarterly	Ammonia	mg/L	Grab
Quarterly	Total Nitrogen	mg/L	Calculated
Quarterly	Total Organic Carbon	mg/L	Grab
Annually	Arsenic ³	mg/L	Grab
Annually	Iron ³	mg/L	Grab
Quarterly	Manganese ³	mg/L	Grab
Quarterly	General Minerals	mg/L	Grab
Annually	Total Coliform Organisms ⁴	MPN/100 mL	Grab

¹ To nearest tenth of a foot

² To nearest tenth of a foot above Mean Sea Level

³ Groundwater samples placed in an acid-preserved bottle for metals analysis must first be filtered. If filtering in the field is not feasible, sampling shall be collected in unpreserved containers and submitted to the laboratory within 24 hours with a request (on the chain of custody form) to immediately filter then preserve the sample.

⁴ Quarterly groundwater monitoring for total coliform monitoring is required for monitoring well MW-16.

SOURCE WATER MONITORING

For each source (either well or surface water supply), the Discharger shall calculate the flow-weighted average concentrations for the specified constituents utilizing monthly flow data and the most recent chemical analysis conducted in accordance with Title 22 drinking water requirements. Alternatively, the Discharger may establish representative sampling stations within the distribution system serving the same area as is served by the WWTF.

<u>Frequency</u>	<u>Constituent/Parameter</u>	<u>Units</u>	<u>Sample Type</u>
Quarterly	Flow-Weighted EC	µmhos/cm	Computed average
Annually	General Minerals	mg/L	Computed average

SLUDGE MONITORING

Sludge shall be sampled for the following constituents:

Arsenic	Copper	Nickel
Cadmium	Lead	Selenium
Molybdenum	Mercury	Zinc

Monitoring shall be conducted: using the methods is “Test Methods for Evaluating Solid Waste, Physical/Chemical Methods” (SW-846), as required in Title 40 of the Code of Federal Regulations (40 CFR), Part 503.8(b)(4). The constituents listed above shall be monitored at the following frequency, depending on volume generated:

<u>Volume Generated (dry metric tons/year)</u>	<u>Frequency</u>
0 to 290	Annually
290 to 1,500	Quarterly
1,500 to 15,000	Bimonthly (six samples per year)
Greater than 15,000	Monthly

The Discharger needs to comply with Title 40 CFR, Part 503 and demonstrate that the facility where sludge is hauled to also complies with these regulations.

INDUSTRIAL PRETREATMENT PROGRAM MONITORING

The Discharger shall submit an annual report to the Regional Water Board, with copies to the EPA Regional Administrator and the State Water Resources Control Board, describing the Discharger's pretreatment activities over the previous 12 months. In the event that the Discharger is not in compliance with any conditions or requirements of this Order, the Discharger shall include the reasons for noncompliance and state how and when the Discharger shall comply with such conditions and requirements. This annual report shall be submitted by **28 February** and shall contain, but not limited to items E.7.a through E.7.j of Standard Provisions dated 1 March 1991 (Standard Provisions).

In addition to the information required in the annual report, the Discharger shall report quarterly the information in E.7.d (1) through (7) of Standard Provisions. Quarterly reports shall also describe progress towards compliance with audit or pretreatment compliance inspection requirements. Quarterly reports shall be submitted by **1st day of the second month following the end of each quarter**. The fourth quarterly report may be included as part of the annual report. If none of the aforementioned conditions exists, at a minimum, the Discharger must submit a letter certifying that all industries are in compliance and no violations or changes to the pretreatment program have occurred during the quarter.

REPORTING

All monitoring results shall be reported in **Quarterly Monitoring Reports** which are due by the first day of the second month after the calendar quarter. Therefore, monitoring reports are due as follows:

First Quarter Monitoring Report:	1 May
Second Quarter Monitoring Report:	1 August
Third Quarter Monitoring Report:	1 November
Fourth Quarter Monitoring Report:	1 February

A transmittal letter shall accompany each monitoring report. The transmittal letter shall discuss any violations that occurred during the reporting period and all actions taken or planned for correcting violations, such as operation or facility modifications. If the Discharger has previously submitted a report describing corrective actions or a time schedule for implementing the corrective actions, reference to the previous correspondence is satisfactory.

The following information is to be included on all monitoring and annual reports, as well as report transmittal letters, submitted to the Central Valley Water Board:

City of Reedley
Reedley WWTF
MRP No. R5-2010-____
Chief Plant Operator
(559) 637-4233

In reporting monitoring data, the Discharger shall arrange the data in tabular form so that the date, the constituents, and the concentrations are readily discernible. The data shall be summarized in such a manner that illustrates clearly, whether the Discharger complies with waste discharge requirements.

In addition to the details specified in Standard Provision C.3, monitoring information shall include the method detection limit (MDL) and the reporting limit (RL) or practical quantitation limit (PQL). If the regulatory limit for a given constituent is less than the RL (or PQL), then any analytical results for that constituent that are below the RL (or PQL) but above the MDL shall be reported and flagged as estimated.

Laboratory analysis reports do not need to be included in the monitoring reports; however, the laboratory reports must be retained for a minimum of three years in accordance with Standard Provision C.3.

All monitoring reports shall comply with the signatory requirements in Standard Provision B.3. Monitoring data or discussions submitted concerning WWTF performance must also be signed and certified by the chief plant operator. If the chief plant operator is not in direct line of supervision of the laboratory function for a Discharger conducting any of its own analyses, reports must also be signed and certified by the chief of the laboratory.

All monitoring reports that involve planning, investigation, evaluation, or design, or other work requiring interpretation and proper application of engineering or geologic sciences, shall be prepared by or under the direction of persons registered to practice in California pursuant to California Business and Professions Code sections 6735, 7835, and 7835.1.

A. All Quarterly Monitoring Reports shall include the following:

Wastewater reporting

1. The results of influent, effluent, and percolation pond monitoring specified on [page 2 and 3](#).
2. For each month of the quarter, calculation of the maximum daily flow and the monthly average flow.

3. For each month of the quarter, calculation of the 12-month rolling average EC of the discharge using the EC values recorded for that month averaged with the monthly average EC values for the previous 11 months.
4. For each month of the quarter, calculation of the monthly average effluent BOD and TSS concentrations, and calculation of the percent removal of BOD and TSS compared to the influent.
5. A summary of the notations made in the percolation pond monitoring log during each quarter. Copies of log pages covering the quarterly reporting period shall not be submitted unless requested by Central Valley Water Board staff.

Groundwater reporting

1. The results of groundwater monitoring specified on [page 3 and 4](#).
2. For each monitoring well, a table showing constituent concentrations for at least five previous years, up through the current quarter.
3. A groundwater contour map based on groundwater elevations for that quarter. The map shall show the gradient and direction of groundwater flow under/around the facility and/or effluent disposal area(s). The map shall also include the locations of monitoring wells and wastewater discharge areas.

Source water reporting

1. The result of source water monitoring specified on [page 4](#).
2. For each month of the quarter, calculation of the flow-weighted 12-month rolling average EC of the source water using monthly flow data and the source water EC values for the most recent four quarters.

B. Fourth Quarter Monitoring Reports, in addition to the above, shall include the following:

Wastewater treatment facility information

1. The names, certificate grades, and general responsibilities of all persons in charge of wastewater treatment and disposal.
2. The names and telephone numbers of persons to contact regarding the WWTF for emergency and routine situations.
3. A statement certifying when the flow meter and other monitoring instruments and devices were last calibrated, including identification of who performed the calibrations (Standard Provision C.4).

4. A statement whether the current operation and maintenance manual, sampling plan, and contingency plan, reflect the WWTF as currently constructed and operated, and the dates when these documents were last reviewed for adequacy.
5. The results of an annual evaluation conducted pursuant to Standard Provision E.4 and a figure depicting monthly average discharge flow for the previous five calendar years.
6. A summary of percolation pond maintenance operations during the calendar year. The summary should identify the percolation ponds that were in service during the calendar year and percolation ponds that were taken out of service for maintenance.
7. Identification of the available percolation pond capacity on or about 1 October and a statement certifying that the available capacity was sufficient to comply with Discharge Specification C.5.

Solids/Sludge monitoring

1. Annual production totals in dry tons or cubic yards.
2. A description of disposal methods, including the following information related to the disposal methods used. If more than one method is used, include the percentage disposed of by each method.
 - a. For landfill disposal, include: the name and location of the landfill, and the Order number of WDRs that regulate it.
 - b. For land application, include: the location of the site, and the Order number of any WDRs that regulate it.
 - c. For incineration, include: the name and location of the site where incineration occurs, the Order number of WDRs that regulate the site, the disposal method of ash, and the name and location of the facility receiving ash (if applicable).
 - d. For composting, include: the location of the site, and the Order number of any WDRs that regulate it.

The Discharger shall implement the above monitoring program on the first day of the month following adoption of this Order.

Ordered by: _____
PAMELA C. CREEDON, Executive Officer

(Date)

GLOSSARY

BOD ₅	Five-day biochemical oxygen demand
CBOD	Carbonaceous BOD
DO	Dissolved oxygen
EC	Electrical conductivity at 25° C
FDS	Fixed dissolved solids
NTU	Nephelometric turbidity unit
TKN	Total Kjeldahl nitrogen
TDS	Total dissolved solids
TSS	Total suspended solids
Continuous	The specified parameter shall be measured by a meter continuously.
24-Hour Composite	Samples shall be a flow-proportioned composite consisting of at least eight aliquots.
Daily	Samples shall be collected at least every day.
Twice Weekly	Samples shall be collected at least twice per week on non-consecutive days.
Weekly	Samples shall be collected at least once per week.
Twice Monthly	Samples shall be collected at least twice per month during non-consecutive weeks.
Monthly	Samples shall be collected at least once per month.
Bimonthly	Samples shall be collected at least once every two months (i.e., six times per year) during non-consecutive months.
Quarterly	Samples shall be collected at least once per calendar quarter. Unless otherwise specified or approved, samples shall be collected in January, April, July, and October.
Semiannually	Samples shall be collected at least once every six months (i.e., two times per year). Unless otherwise specified or approved, samples shall be collected in April and October.
Annually	Samples shall be collected at least once per year. Unless otherwise specified or approved, samples shall be collected in October.
mg/L	Milligrams per liter
mL/L	milliliters [of solids] per liter
µg/L	Micrograms per liter
µmhos/cm	Micromhos per centimeter
mgd	Million gallons per day
MPN/100 mL	Most probable number [of organisms] per 100 milliliters
General Minerals	Analysis for General Minerals shall include at least the following:
	Alkalinity
	Bicarbonate
	Calcium
	Carbonate
	Chloride
	Hardness
	Magnesium
	Potassium
	Sodium
	Sulfate
	TDS
	General Minerals analyses shall be accompanied by documentation of cation/anion balance.

Table 1. Priority Pollutant Scan

<u>Inorganics</u> ¹			<u>Pesticides</u>
Antimony	1,2-Dichloropropane	Bis(2-chloroisopropyl) ether	Aldrin
Arsenic	1,3-Dichloropropylene	Bis(2-Ethylhexyl)phthalate	alpha-BHC
Beryllium	Ethylbenzene	4-Bromophenyl phenyl ether	beta-BHC
Cadmium	Methyl Bromide	Butylbenzyl Phthalate	gamma-BHC (Lindane)
Chromium (III)	Methyl Chloride	2-Chloronaphthalene	delta-BHC
Chromium (VI)	Methylene Chloride	4-Chlorophenyl Phenyl Ether	Chlordane
Copper	1,1,2,2-Tetrachloroethane	Chrysene	4,4'-DDT
Lead	Tetrachloroethylene (PCE)	Dibenzo(a,h)Anthracene	4,4'-DDE
Mercury	Toluene	1,2-Dichlorobenzene	4,4'-DDD
Nickel	1,2-Trans-Dichloroethylene	1,3-Dichlorobenzene	Dieldrin
Selenium	1,1,1-Trichloroethane	1,4-Dichlorobenzene	alpha-Endosulfan
Silver	1,1,2-Trichloroethane	3,3'-Dichlorobenzidine	beta-Endosulfan
Thallium	Trichloroethylene (TCE)	Diethyl phthalate	Endosulfan Sulfate
Zinc	Vinyl chloride	Dimethyl phthalate	Endrin
Cyanide	2-Chlorophenol	Di-n-Butyl Phthalate	Endrin Aldehyde
Asbestos	2,4-Dichlorophenol	2,4-Dinitrotoluene	Heptachlor
	2,4-Dimethylphenol	2,6-Dinitrotoluene	Heptachlor epoxide
	2-Methyl-4,6-Dinitrophenol	Di-n-Octyl Phthalate	Polychlorinated biphenyls
<u>Dioxin Congeners</u>	2,4-Dinitrophenol	1,2-Diphenylhydrazine	Toxaphene
2,3,7,8-TCDD	2-Nitrophenol	Fluoranthene	
	4-Nitrophenol	Fluorene	
<u>Organics</u>	3-Methyl-4-Chlorophenol	Hexachlorobenzene	
Acrolein	Pentachlorophenol	Hexachlorobutadiene	
Acrylonitrile	Phenol	Hexachlorocyclopentadiene	
Benzene	2,4,6-Trichlorophenol	Hexachloroethane	
Bromoform	Acenaphthene	Indeno(1,2,3-c,d)pyrene	
Carbon tetrachloride	Acenaphthylene	Isophorone	
Chlorobenzene	Anthracene	Naphthalene	
Chlorodibromomethane	Benzidine	Nitrobenzene	
Chloroethane	Benzo(a)Anthracene	N-Nitrosodimethylamine	
2-Chloroethylvinyl Ether	Benzo(a)pyrene	N-Nitrosodi-n-Propylamine	
Chloroform	Benzo(b)fluoranthene	N-Nitrosodiphenylamine	
Dichlorobromomethane	Benzo(g,h,i)perylene	Phenanthrene	
1,1-Dichloroethane	Benzo(k)fluoranthene	Pyrene	
1,2-Dichloroethane	Bis(2-chloroethoxy) methane	1,2,4-Trichlorobenzene	
1,1-Dichloroethylene	Bis(2-chloroethyl) ether		

¹ With the exception of wastewater samples, samples placed in an acid-preserved bottle for metals analysis must first be filtered. If filtering in the field is not feasible, samples shall be collected in unpreserved containers and submitted to the laboratory within 24 hours with a request (on the chain of custody form) to immediately filter then preserve the sample.