

**LATE REVISIONS
CITY OF SHASTA LAKE
FISHERMAN'S POINT WATER TREATMENT PLANT
SHASTA COUNTY
NPDES Permit Renewal (NPDES No. CA0004693)
Regional Water Quality Control Board, Central Valley Region
Board Meeting – 30 March 2012
ITEM # 8**

Changes to Proposed NPDES Permit Renewal

1. **NPDES Permit, Monitoring Program.** Section IV.A.2. Page E-6.
Modify as shown in underline/strikeout format below:

If the discharge is intermittent rather than continuous, then on the first day of each such intermittent discharge, the Discharger shall monitor and record data for all of the constituents listed above, ~~except for priority pollutants,~~ whose monitoring frequency is 2/month or more frequent after which the frequencies of analysis given in the schedule shall apply for the duration of each such intermittent discharge. In no event shall the Discharger be required to monitor and record data more often than twice the frequencies listed in the schedule.

2. **NPDES Permit, Monitoring Program.** Table E-4. Page E-10.
Modify the footnotes to Table E-4 as follows:

³ Aluminum and manganese shall be monitored at Monitoring Location RSW-001 only for 3 years as part of the special studies described in Section VI.C.2.b and VI.C.2.c, of this Order. Samples shall be collected on the same date as the effluent metals samples.

⁷ Priority pollutants shall be sampled semi-annually during the third or fourth year following the date of permit adoption at Monitoring Location RSW-001 only and shall be conducted concurrently with effluent monitoring for priority pollutants. See Attachment I for more detailed requirements related to performing priority pollutant monitoring.