

ITEM:

SUBJECT City of Williams Wastewater Treatment Plant, Colusa County

BOARD ACTION Consideration of Rescission of Time Schedule Order R5-2007-0096 and Resolution R5-2008-0139

BACKGROUND On 27 August 2007, the Central Valley Water Board adopted Time Schedule Order (TSO) R5-2007-0096 and on 11 September 2008 adopted Resolution R5-2008-0139 for the City of Williams Wastewater Treatment Plant (WWTP). The TSO and Resolution required the City of Williams to comply with effluent limitations for ammonia, biochemical oxygen demand, total suspended solids, turbidity, total coliform organisms, chlorine residual. The TSO also required wastewater to be oxidized, coagulated, and filtered or equivalent treatment, and required 85 percent removal of BOD and TSS.

The Discharger has achieved compliance by expending in excess of \$23 million on a new wastewater treatment plant, which commenced operation in June 2011. Therefore, Order R5-2007-0096 and Resolution R5-2008-0139 are no longer necessary.

RECOMMENDATION Rescind Time Schedule Order R5-2007-0096 and Resolution R5-2008-0139.

Mgmt. Review \_\_\_WSW\_\_\_\_\_

Legal Review\_\_\_\_\_

6/7 December 2012

11020 Sun Center Drive, Suite 200

Rancho Cordova, CA 95670