

**LATE REVISIONS**

**CITY OF MT. SHASTA AND U.S. DEPARTMENT OF AGRICULTURE FOREST SERVICE  
CITY OF MT. SHASTA WASTEWATER TREATMENT PLANT  
SISKIYOU COUNTY**

**Proposed Waste Discharge Requirements  
NPDES No. CA0078051  
Regional Water Quality Control Board, Central Valley Region  
Board Meeting – 27/28 April 2023  
ITEM #12**

The proposed Order for the City of Mt. Shasta (Discharger) Wastewater Treatment Plant has late revisions to correct the units listed in two separate tables and a typographical error in the Special Provisions.

1. Make corrections to units in Waste Discharge Requirements (WDRs) Attachment E (Monitoring and Reporting Program), Table E-10 as follows:

<b>Parameter</b>	<b>Units</b>	<b>Sample Type</b>	<b>Minimum Sampling Frequency</b>
<i>Total Trihalomethanes</i>	<del>mg/L</del> <u>µg/L</u>	<i>Grab</i>	<i>1/Quarter</i>
<i>Arsenic, Dissolved</i>	<del>mg/L</del> <u>µg/L</u>	<i>Grab</i>	<i>1/Quarter</i>

2. Make corrections to units in WDRs Attachment F (Fact Sheet), Table F-17 as follows:

<b>Constituent</b>	<b>Units</b>	<b>Effluent</b>	<b>Upgradient RGW-001</b>	<b>Down- gradient RGW-002</b>	<b>Down- gradient RGW-004</b>	<b>WQOs</b>
<i>Boron, Total</i>	<del>mg/L</del> <u>µg/L</u>	182	8.4	23.5	22.4	--

3. Correct typographical errors in WDRs, Provision VI.C.2.d as follows:

***“Within 12 months of the permit effective date, the Discharger shall submit an Overflow Pond Operating Plan that describes, at minimum, the operation of the overflow pond, expected quality of water routed to the pond, plan for re-routing water back to the treatment train, and conditions at the treatment facility that necessitate its use. The Plan should also include the approximate size and overall condition of the pond.”***