

CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD  
COLORADO RIVER BASIN REGION

ORDER NO. 90-043

WASTE DISCHARGE REQUIREMENTS  
FOR  
PALM LAKES GOLF COURSE  
WASTEWATER RECLAMATION  
Palm Desert - Riverside County

The California Regional Water Quality Control Board, Colorado River Basin Region, finds that:

1. Palm Lakes Golf Course, Inc., 81750 Avenue 50, Indio, California 92201, (hereinafter also referred to as the discharger), submitted a Report of Waste Discharge dated April 11, 1990, for the proposed irrigation of the Palm Lakes Golf Course and common areas located in Palm Desert, California, using tertiary treated reclaimed wastewater provided by Coachella Valley Water District.
2. The maximum irrigation design flow would be 0.5 mgd, and the average design flow would be 0.3 mgd. The golf course and common areas are located within Section 16, T5S, R6E, SBB&M.
3. The Water Quality Control Plan for the Colorado River Basin Region of California designates the beneficial uses of ground and surface waters in this Region.
4. The beneficial uses of ground waters in the Coachella Hydrologic Subunit are:
  - a. Municipal supply (MUN)
  - b. Industrial supply (IND)
  - c. Agricultural supply (AGR)
5. The Board has notified the discharger and all known interested agencies and persons of its intent to prescribe waste discharge requirements for this discharge.
6. The Board in a public meeting heard and considered all comments pertaining to this discharge.
7. The requirements prescribed below establish acceptable levels of constituents of reclaimed water in accordance with Division 4, Title 22 of the California Code of Regulations.

*Change of  
Name/Ownership  
Board Ord. # 97-024  
3/26/97*

8. These waste discharge requirements govern a minor alteration to land and therefore are exempt from provisions of the California Environmental Quality Act in accordance with Section 15304, Chapter 3, Title 14 of the California Code of Regulations.

IT IS HEREBY ORDERED, that the discharger shall comply with the following:

A. Specifications

1. Reclaimed water shall only be used for landscape irrigation of the common areas and golf course described in the Findings of this Board Order. Prior to making use of reclaimed water purveyed by the Coachella Valley Water District (CVWD) for any other purposes or at any other location, the discharger shall obtain any necessary authorization from CVWD.
2. Irrigation with reclaimed wastewater shall be under the direct control of the discharger at all times.
3. The discharger shall allow the Regional Board, or an authorized representative from State or local agencies, upon the presentation of credentials and other documents as may be required by law, to:
  - a. Enter upon the discharger's premises where a regulated facility or activity is located or conducted, or where records must be kept under the conditions of this Board Order;
  - b. Have access to and copy, at reasonable times, any records that must be kept under the conditions of this Board Order;
  - c. Inspect at reasonable times any facilities, equipment (including monitoring and control equipment), practices, or operations regulated or required under this Board Order; and
  - d. Sample or monitor at reasonable times, for the purpose of assuring compliance with this Board Order or as otherwise authorized by the California Water Code, any substances or parameters at any location.
4. An on-site supervisor responsible for operation of the reclaimed wastewater system shall be designated by the discharger. The supervisor shall be responsible for the installation, operation and maintenance of the irrigation system, enforcing this Board Order, prevention of potential hazards, maintenance of the distribution system plans in "as-built" form, and for the distribution of the reclaimed wastewater in accordance with this Board Order. The name of the on-site supervisor shall be furnished to the Regional Board at least 30 days prior to commencement of the use of reclaimed wastewater.

5. The designated supervisor shall report any noncompliance with this Board Order to the Regional Board office as soon as possible. A written submittal shall also be provided to the Regional Board within five days of the time the on-site supervisor becomes aware of the circumstances. The written submittal shall contain:
  - a. A description of the noncompliance and its cause;
  - b. The period of noncompliance, including exact dates and times, and if the noncompliance has not been corrected, the anticipated time it is expected to continue; and
  - c. Steps taken or planned to reduce, eliminate, and prevent recurrence of the noncompliance.
6. The name of the designated on-site supervisor shall be furnished to the Regional Board at the following address:

Executive Officer  
California Regional Water Quality Control Board  
Colorado River Basin Region  
73-271 Highway 111, Suite 21  
Palm Desert, CA 92260  
Telephone: (619) 346-7491
7. A freeboard depth of at least 2 feet shall be maintained in any infiltrations basins and/or holding basins.

B. Provisions

1. The treatment and discharge of wastewater shall not cause pollution or nuisance as defined in Sections 13050 (1) and 13050 (m) of the California Water Code.
2. The discharger shall assure that notification of the use of reclaimed wastewater is provided to people who reside adjacent to irrigation reuse areas and to golf course patrons. The content of the notice and method of notification shall be approved by the Executive Officer. The public shall be notified at least 30 days prior to commencement of golf course irrigation with reclaimed water.

I, Philip A. Gruenberg, Executive Officer, do hereby certify the foregoing is a full, true and correct copy of an Order adopted by the California Regional Water Quality Control Board, Colorado River Basin Region, on June 27, 1990.

  
Executive Officer

CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD  
COLORADO RIVER BASIN REGION

MONITORING AND REPORTING PROGRAM NO. 90-043

FOR

PALM LAKES GOLF COURSE  
WASTEWATER RECLAMATION  
Palm Desert - Riverside County

Location of Discharge: Section 16, T5S, R6E, SBB&M

MONITORING

Palm Lakes Golf Course (discharger) shall submit to the Regional Board an annual report containing the following:

- A. Total number of gallons of tertiary wastewater used in the previous 12-month period.
- B. An estimation of the number of gallons of tertiary wastewater that will be used in the next 12-month period.

REPORTING

Annual reports shall be submitted to the Regional Board by January 15th of each year to:


California Regional Water Quality Control Board  
Colorado River Basin Region  
73-271 Highway 111, Suite 21  
Palm Desert, CA 92260

ORDERED BY:

Philip A. Gruenberg  
Executive Officer

June 27, 1990

Date



**SITE MAP**

PALM LAKES GOLF COURSE  
 WASTEWATER RECLAMATION  
 Palm Desert - Riverside County  
 Section 16, T5S, R6E, SBB&M

1 Inch = 1/2 Mile

