

**CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
COLORADO RIVER BASIN REGION**

**MONITORING AND REPORTING PROGRAM R7-2013-0007
FOR
HEBER PUBLIC UTILITIES DISTRICT, OWNER, OPERATOR
STANDBY BASIN
Heber – Imperial County**

Location of Discharge:
NW ¼, NE ¼ of Section 28, T16S, R14E, SBB&M

MONITORING AND REPORTING

1. The Discharger shall inspect the general condition of the standby basin (e.g., structural integrity, whether weeds are growing in it and along its banks, signs of erosion, etc.) weekly and maintain a log at the POTW regarding the condition and use of the standby basin. The log shall be available for inspection by the Regional Water Board and its representatives upon request.
2. For an anticipated discharge to the standby basin (e.g., scheduled unit maintenance), the Discharger shall, prior to discharge to the basin, submit to the Regional Water Board a report **two (2) working days before the proposed discharge is to take place**. The report shall:
 - a. Describe the structural integrity of the basin;
 - b. Describe the reasons for the proposed discharge to the basin and the anticipated volume of wastewater that is to be discharged to the basin; and
 - c. Note whether there is any wastewater in the basin and record the available freeboard if there is wastewater in it.
3. For an emergency discharge to the standby basin, the Discharger shall notify the Regional Water Board via telephone (760 346-7491) within 24-hours from the time the discharge took place. The notification shall include when and why the discharge took place.
4. Following any discharge to the standby basin, the Discharger shall submit to the regional Water Board a report that:
 - a. Estimates the volume of wastewater discharged (gallons),
 - b. Describes the quality of discharge (e.g., raw sewage, primary effluent, etc.),
 - c. Includes the dates and times when the discharge began and ended;
 - d. The dates and times when the pumping of the wastewater from the basin back into the POTW began and ended.
5. Monitoring reports shall be certified under penalty of perjury to be true and correct, and shall contain the required information at the frequency designated in this monitoring and reporting program (MRP).

6. Each report required herein shall contain the following statement:

"I declare under the penalty of law that I have personally examined and am familiar with the information submitted in this document, and that based on my inquiry of those individuals responsible for obtaining the information, I believe that the information is true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of a fine and imprisonment for knowing violations."

7. The MRP, and other information requested by the Regional Water Board, shall be signed by the District Manager or Chief Plant Operator.

8. Other duly authorized representative of the Discharger may sign the documents if:

a. Authorization is made in writing by the either one of the person described above;

b. Authorization specifies an individual or person having responsibility for the overall operation of the regulated disposal system; and

c. Written authorization is submitted to the Regional Water Board Executive Officer.

9. The Discharger shall submit monitoring reports to:

California Regional Water Quality Control Board
Colorado River Basin Region
73-720 Fred Waring, Suite 100
Palm Desert, CA 92260

Ordered by:




ROBERT PERDUE
Executive Officer

January 17, 2013

Date

CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
COLORADO RIVER BASIN REGION

Heber Public Utility District, Owner/Operator
Wastewater Treatment Facility Emergency Standby Basin
Imperial County



Attachment A – Location and Vicinity Map

NW ¼, NE ¼ Section 28, T16S, R14E, SBB&M
USGS Heber 15 min.