

August 2006

Applicant: Valley Sanitary District (VSD)

Project Name: VSD Wastewater Treatment Plant (WWTP) Expansion

Receiving Water: Coachella Valley Stormwater Channel

Location: The project is located within Sections 19 & 30, Township 5 South, Range 8 East, SBB&M, in the City of Indio.
(33° 42' 30" N. Latitude, 116° 12' 00" W. Longitude)

Project Description: VSD proposes to expand its WWTP from 8.5 MGD to 17.2 MGD. These improvements would result in expansion of the existing outfall structure from 21-inches to 54-inches. The existing outfall structure is designed to transmit approximately 12 MGD of effluent from the treatment plant to the Coachella Valley Stormwater Channel. The new 54-inch outfall structure will also include a 20-foot wide by 250-foot long ribbon gutter. VSD will construct the expanded outfall structure in an area approximately 150-feet northwest of the existing outfall structure.

Action: Pending

Regional Board
Contact: Kirk Larkin, Water Resources Control Engineer
(760) 776-8964