

SUPPLEMENTAL ERRATA SHEET

TENTATIVE ORDER NO. R9-2009-0080 NPDES NO. CA0109151 WASTE DISCHARGE REQUIREMENTS BAE SYSTEMS SAN DIEGO SHIP REPAIR INC. DISCHARGE TO THE SAN DIEGO BAY

The following revisions will be made to tentative Order No. R9-2009-0080. Some changes/corrections below are shown in underline/~~strikeout~~ format to indicate added and removed language, respectively.

Errata #	SECTION	REVISION
1.	Limitations and Discharge Requirements Section V.A. Page 18	V. RECEIVING WATER LIMITATIONS The discharge of waste shall not cause, have the reasonable potential to cause, or contribute to an excursion above the following water quality objectives in the receiving water:
2.	Effluent Limitations and Discharge Specifications Section IV.A.2 Page 15	See changes in table 6 below.

Table 6. Effluent Limitations For All Discharges Identified in Section IV.A.2.

Parameter	Units	Effluent Limitations		
		Average Monthly	Weekly Average	Instantaneous Maximum
Oil and Grease	mg/L	25	40	75
Settleable Solids	ml/L	1.0	1.5	3.0
Turbidity	NTU	75	100	225
pH	pH units	--	--	¹
Temperature	°F	--	--	²
Acute Toxicity	--	--	--	³

¹ Within limits of 7.0 – 9.0 at all times.

² At no time shall any discharge be greater than 20°F over the natural temperature of the receiving water.

³ Discharges ~~of storm water~~ shall achieve a rating of “Pass” for acute toxicity with compliance determined as specified in section VII.~~A-I~~ of this Order.