

Violation ID	Violation Date	Violation Type	Description
916026	11/7/2011	Category 2 Pollutant (Effluent Violation for Group 2 Pollutant)	Total Residual Chlorine Instantaneous Maximum limit is 5.7 mg/L and reported value was 21.2 mg/L.
926891	8/31/2008	Deficient Monitoring	Monitoring location was not representative of the SBWRP effluent discharged to the SBOO.
926889	7/31/2008	Deficient Monitoring	Monitoring location was not representative of the SBWRP effluent discharged to the SBOO.
926888	6/30/2008	Deficient Monitoring	Monitoring location was not representative of the SBWRP effluent discharged to the SBOO.
926887	5/31/2008	Deficient Monitoring	Monitoring location was not representative of the SBWRP effluent discharged to the SBOO.
924972	9/30/2007	Deficient Monitoring	The daily 24-hour composite sample for Benzidine and 3,3-dichlororbenzidine should be reported quarterly. Benzidine and 3,3-dichlororbenzidine were not reported in the July – September 2007 quarter.
926880	9/30/2007	Deficient Monitoring	Monitoring location was not representative of the SBWRP effluent discharged to the SBOO.
926869	8/31/2007	Deficient Monitoring	Monitoring location was not representative of the SBWRP effluent discharged to the SBOO.
924962	7/31/2007	Deficient Monitoring	The daily 24-hour composite sample for BOD/TSS should be provided. On July 26, 2007, BOD and TSS were not sampled.
926866	7/31/2007	Deficient Monitoring	Monitoring location was not representative of the SBWRP effluent discharged to the SBOO
924959	1/31/2007	Deficient Monitoring	The daily 24-hour composite sample for BOD and TSS should be provided. On January 21, 2007, BOD and TSS were not sampled. The instantaneous maximum and the average weekly mass emissions of BOD and TSS should be provided. These were not reported for the month of January 2007. The maximum daily, instantaneous maximum and 6 month median for ammonia-nitrogen should be provided. These were not reported for the month of January 2007.