Item 14
Doc. No. 4

Laboratory Constituents

KB Homes, Mar Lado Pump Station, Oceanside, CA
For the operating month of January 2004
Flow discontinued effective January 7, 2004.
File no. IC:14-1033.01:komec

Constituent	Results	Discharge Limits	Method Detection Limits/Units
Flowrate	See attached chart		
Total Nitrogen	2.9 mg/L	2.0 mg/L	0.25 mg/L
Total Phosphorus	0.29 mg/L	0.2 mg/L	0.005 mg/L
Setteable Solids	ND	50 mg/L	0.1 mg/L
Total Suspended Solids	ND	N/A	2.6 mg/L
Hydrogen Sulfide	ND	10 ug/L	0.1 mg/L
Total petroleum hydrocarbons	0.058 mg/L	0.5 mg/L	.050 mg/L
MTBE	14 ug/L	N/A	0.18 ug/L
pH	7.30	7.0 – 8.5	N/A
Turbidity, 100' upstream	1.2 NTU	N/A	0.05 NTU
Turbidity 100' downstream	22 NTU	N/A	0.05 NTU