Appendix D

Violation Table No. 3

City of Escondido
Wet Weather Discharge
to Escondido Creek

Violation Number	Violation Date	Constituent	Effluent Limitation	Unit	Reported Value	Violation Catetory	Serious Violation?	Penalty
1	1/9/2005	Turbidity-Daily Average	2	NTU	3.0	1	Yes	$3,000
2	1/9/2005	Nitrite-Daily Maximum	1.0	mg/L	4.0	1	Yes	$3,000
3	1/10/2005	Turbidity-Daily Average	2	NTU	6.3	1	Yes	$3,000
4	1/11/2005	Turbidity-Daily Average	2	NTU	7.1	1	Yes	$3,000
5	1/12/2005	Turbidity-Daily Average	2	NTU	5.0	1	Yes	$3,000
6	1/13/2005	Turbidity-Daily Average	2	NTU	2.9	1	Yes	$3,000
7	2/22/2005	Turbidity-Daily Average	2	NTU	7.9	1	Yes	$3,000
8	2/22/2005	Nitrate-Daily Maximum	10	mg/L	12.8	1	No	$3,000
9	2/23/2005	Turbidity-Daily Average	2	NTU	7.7	1	Yes	$3,000
10	2/24/2005	Turbidity-Daily Average	2	NTU	6.0	1	Yes	$3,000
11	2/25/2005	Turbidity-Daily Average	2	NTU	6.5	1	Yes	$3,000
								$33,000