Appendix I

Violation Table No. 7

City of Escondido
Recycled Water Requirements

Violation Number	Violation Date	Constituent	Effluent Limitation	Unit	Reported Value	Violation Catetory	Serious Violation?	Penalty
1	1/9/2005	Turbidity-Daily Average	2	NTU	2.3	1	No	$300
2	1/18/2005	Turbidity-Daily Average	2	NTU	3.0	1	Yes	$300
3	2/1/2005	Turbidity-Daily Average	2	NTU	3.3	1	Yes	$300
4	2/21/2005	Turbidity-Daily Average	2	NTU	3.3	1	Yes	$300
5	2/22/2005	Turbidity-Daily Average	2	NTU	3.2	1	Yes	$300
6	3/3/2005	Turbidity-Daily Average	2	NTU	2.3	1	No	$300
7	3/7/2005	Turbidity-Daily Average	2	NTU	2.1	1	No	$300
8	4/11/2005	Manganese-Daily Max	0.06	mg/L	0.13	1	Yes	$300
9	5/2/2005	Manganese-Daily Max	0.06	mg/L	0.127	1	Yes	$300
10	6/5/2005	Manganese-Daily Max	0.06	mg/L	0.089	1	Yes	$300
11	7/7/2005	Manganese-Daily Max	0.06	mg/L	0.125	1	Yes	$300
12	8/30/2005	Manganese-Daily Max	0.06	mg/L	0.075	1	No	$300
13	9/1/2005	Manganese-Daily Max	0.06	mg/L	0.075	1	No	$300
14	9/1/2005	Manganese 12-Month Average	0.05	mg/L	0.066	1	No	$300
15	10/2/2005	Manganese-Daily Max	0.06	mg/L	0.075	1	No	$300
16	10/2/2005	Manganese 12-Month Average	0.05	mg/L	0.073	1	No	$300
								$4,800