



Linda S. Adams
Secretary for
Environmental Protection

California Regional Water Quality Control Board

San Diego Region

Over 50 Years Serving San Diego, Orange, and Riverside Counties
Recipient of the 2004 Environmental Award for Outstanding Achievement from USEPA



Arnold Schwarzenegger
Governor

9174 Sky Park Court, Suite 100, San Diego, California 92123-4353
(858) 467-2952 • Fax (858) 571-6972
[http:// www.waterboards.ca.gov/sandiego](http://www.waterboards.ca.gov/sandiego)

July 7, 2010

In reply refer to:
adai:240177

Mr. Dennis Lamb
General Manager
Vallecitos Water District
201 Vallecitos de Oro
San Marcos, CA 92069-1453

Dear Mr. Lamb:

SUBJECT: MEADOWLARK WATER RECLAMATION PLANT (WRP)

The California Regional Water Quality Control Board, San Diego Region (San Diego Water Board) has reviewed the August 2009 - May 2010 monthly monitoring reports submitted by the Vallecitos Water District (District) in accordance with Monitoring and Reporting Program No. R9-2007-0018.

The San Diego Water Board identified the following violations of Order No. R9-2007-0018:

1. The minimum modal chlorine contact time of Facility Design and Operation Specification C.6, established at 90 minutes, was not met on April 27, 2010 with a reported value of 82 minutes.
2. Monitoring and Reporting Program Section D requires reporting of constituents with a reporting frequency of once every five years to be submitted by February 1st once every five years. The San Diego Water Board received the report on February 26, 2010, 25 days late.

Please be aware these violations subject you to possible further enforcement action by the San Diego Water Board, including administrative enforcement orders requiring the you to cease and desist from violations, or to clean up waste and abate existing or threatened conditions of pollution or nuisance; administrative assessment of civil liability in amounts of up to \$5,000 per day per violation;¹ referral to the State Attorney General for injunctive relief; and referral to the District Attorney for criminal prosecution.

¹ Under authority of California Water Code section 13350.

Mr. Lamb


- 2 -

July 7, 2010

The next monitoring report to be submitted is the June 2010 monthly monitoring report due by August 1, 2010.

In the subject line of any response, please include the requested "In reply refer to:" information located in the heading of this letter. For questions pertaining to the subject matter, please contact Amanda Dai at (858) 627-3977 or adai@waterboards.ca.gov.

Sincerely,



Robert Morris, P.E.
Senior Water Resource Control Engineer
Groundwater Branch

Regulatory Measure #: 374605

CIWQS Violation ID: 874919, 874920