



California Regional Water Quality Control Board

San Diego Region

Over 50 Years Serving San Diego, Orange, and Riverside Counties

Recipient of the 2004 Environmental Award for Outstanding Achievement from USEPA



Arnold Schwarzenegger
Governor

Linda S. Adams
Secretary for
Environmental Protection

9174 Sky Park Court, Suite 100, San Diego, California 92123-4353

(858) 467-2952 • Fax (858) 571-6972

[http:// www.waterboards.ca.gov/sandiego](http://www.waterboards.ca.gov/sandiego)

June 24, 2010

In reply refer to:

Adai:224057

Mr. Chuck Duffy
Fairbanks Ranch Community Services District
605 Third Street
Encinitas, CA 92024

Dear Mr. Duffy:

**SUBJECT: FAIRBANKS RANCH WATER POLLUTION CONTROL FACILITY
(W.P.C.F.)**

The California Regional Water Quality Control Board, San Diego Region (San Diego Water Board) has reviewed the April-June 2009 quarterly, July-September 2009 quarterly, October-December 2009 quarterly, January-March 2010 quarterly, and January-December 2009 annual monitoring reports submitted by the Fairbanks Ranch Community Services District in accordance with Monitoring and Reporting Program of Order No. 93-05.

The following violation of the Order No. 93-05 was identified in the April-June quarterly monitoring report:

The daily maximum of Discharge Specification B.1 for total dissolved solids, established at 1300 milligrams per liter (mg/L), was exceeded on April 8, 2009 with a reported value of 1383 mg/L.

Please be aware this violation subjects you to possible further enforcement action by the San Diego Water Board, including administrative enforcement orders requiring the you to cease and desist from violations, or to clean up waste and abate existing or threatened conditions of pollution or nuisance; administrative assessment of civil liability in amounts of up to \$5,000 per day per violation;¹ referral to the State Attorney General for injunctive relief; and referral to the District Attorney for criminal prosecution.

The next monitoring report to be submitted is the April – June 2009 Quarterly Monitoring Report due by July 30, 2010.

¹ Under authority of California Water Code section 13350.

Mr. Duffy
Fairbanks Ranch W.P.C.F.

- 2 -

June 24, 2010

In the subject line of any response, please include the requested **"In reply refer to:"** information located in the heading of this letter. For questions pertaining to the subject matter, please contact Amanda Dai at (858) 627-3977 or adai@waterboards.ca.gov.

Sincerely,

Robert Morris

Robert Morris, P.E.
Senior Water Resource Control Engineer
Groundwater Branch

Regulatory Measure ID 374507
Violation ID 872861

California Environmental Protection Agency