



Linda S. Adams  
Secretary for  
Environmental Protection

# California Regional Water Quality Control Board San Diego Region

Over 50 Years Serving San Diego, Orange, and Riverside Counties  
Recipient of the 2004 Environmental Award for Outstanding Achievement from USEPA



Arnold Schwarzenegger  
Governor

9174 Sky Park Court, Suite 100, San Diego, California 92123-4353  
(858) 467-2952 • Fax (858) 571-6972  
[http:// www.waterboards.ca.gov/sandiego](http://www.waterboards.ca.gov/sandiego)

October 27, 2010

In reply refer to:  
**248439:adai**

Ms. Milica Kaludjerski  
Department of Public Works  
County of San Diego  
5555 Overland Ave., Suite 2188  
San Diego, CA 92123-1295

Dear Ms. Kaludjerski:

**SUBJECT: REVIEW OF MONITORING REPORTS FOR THE  
PINE VALLEY SANITATION DISTRICT**

The California Regional Water Quality Control Board, San Diego Region (San Diego Water Board) has reviewed the April-June 2010 quarterly monitoring report submitted by the County of San Diego (County) in accordance with Monitoring and Reporting Program Order No. 94-161.

The following violation of Order No. 94-161 were identified in the report submitted:

1. The 12-month average Discharge Specification B.1 for total dissolved solids, established at 750 milligrams per liter (mg/L), was exceeded for the month of June with reported values of 830 mg/L.

Please be aware this violation subjects the County to possible further enforcement action by the San Diego Water Board, including administrative enforcement orders requiring the County to cease and desist from violations, or to clean up waste and abate existing or threatened conditions of pollution or nuisance; administrative assessment of civil liability in amounts of up to \$5,000 per day per violation;<sup>1</sup> referral to the State Attorney General for injunctive relief; and referral to the District Attorney for criminal prosecution.

The next monitoring report to be submitted is the July-September 2010 quarterly monitoring report, which is due by October 30, 2010.

<sup>1</sup> Under authority of California Water Code section 13350.

For questions pertaining to the subject matter, please contact Amanda Dai at (858) 627-3977 or via email at [adai@waterboards.ca.gov](mailto:adai@waterboards.ca.gov).

**PLEASE INCLUDE "248439:ADAI" IN THE SUBJECT LINE OF FUTURE CORRESPONDANCE.**

Sincerely,

*Robert Morris*

Robert W. Morris, P.E.  
Senior Water Resource Control Engineer  
Cleanup and Land Discharge Branch

Regulatory Measure ID	142494
Place ID	248439
Enforcement ID	376352
Violation ID	883504