



California Regional Water Quality Control Board, San Diego Region

August 20, 2012

Mr. Kevin M. Hardy
General Manager
Encina Wastewater Authority
6200 Avenida Encinas
Carlsbad, CA 92011-1095

In reply refer to / attn:
Place ID 222754:JLLim

SUBJECT: Violation of Order No. R9-2011-0019, NPDES No. CA0107395

Mr. Hardy:

The California Regional Water Quality Control Board, San Diego Region (San Diego Water Board) has noted the following violation for the August 2011 monthly self-monitoring report:

The Monitoring and Reported Program of Order No. R9-2011-0019 requires a monitoring frequency of three days per week for carbonaceous biochemical oxygen demand (CBOD5) at Monitoring Location M-001. For the week of August 21-27, 2011, at Monitoring Location M-001, only two monitoring results were provided for CBOD5.

In the subject line of any response, please include the reference "Place ID 222754:JLLim. For questions or comments, please contact Joann Lim by phone at 858-637-5589 or by email at jllim@waterboards.ca.gov.

Respectfully,

Robert Morris (handwritten signature)

Robert W. Morris
Senior WRC Engineer

RWM: jll

Table with 2 columns: Label and Value. Row 1: Order No. R9-2011-0019. Row 2: Party ID 14804 (Encina Wastewater Authority). Row 3: File No. 01-030. Row 4: WDID 9 000000030. Row 5: NPDES No. CA0107395. Row 6: Reg. Measure No. 378933 (R9-2011-0019), 387078 (SEL). Row 7: Place ID 222754 (Encina Ocean Outfall). Row 8: Person ID 535784 (Hardy), 525853 (Brian Benjamin). Row 9: Violation ID 910158.

